

EHC

ASSOCIATES, INC.

Environmental Consultants & Abatement Contractors

June 15, 2016

Mr. Glenn Davis
c/o Lampeter-Strasburg School District
1600 Book Road, P.O. Box 428
Lampeter, PA 17537

Re: Lead In Water Testing Services
EHC Project No. 008735-003

Dear Mr. Davis:


Please review the enclosed analytical report in regard to the water samples collected from Lampeter-Strasburg High School, Martin Meylin Middle School, Hans Herr Elementary and Lampeter Elementary on May 26, 2016. The samples were analyzed for lead content by Suburban Water Testing Labs, using the EPA 200 Method. The following provides a summary of the results:

<u>Building / Sample Type</u>	<u>Location/Description</u>	<u>Results</u>
LS High School/Standing	Kitchen Island Sink	0.001 mg/L
LS High School/Standing	Fountain at Rm. 265 (W)	<0.001 mg/L
LS High School/Flush	Fountain at Rm. 265 (M)	<0.001 mg/L
Martin Meylin/Standing	Kitchen Sink	0.002 mg/L
Martin Meylin/Standing	Fountain Outside Cafeteria	<0.001 mg/L
Martin Meylin/Flush	Fountain Outside Cafeteria	<0.001 mg/L
Hans Herr/Standing	Kitchen Island Sink	0.002 mg/L
Hans Herr/Standing	Fountain Outside Kitchen	<0.001 mg/L
Hans Herr/Flush	Fountain Outside Kitchen	<0.001 mg/L
Lampeter Elem./Standing	Kitchen at 3-Bay Sink	0.002 mg/L
Lampeter Elem./Standing	Cafeteria Fountain	<0.001 mg/L
Lampeter Elem./Flush	Cafeteria Fountain	<0.001 mg/L

Laboratory analysis confirms that the water samples collected on May 26, 2016 are below the recommended acceptable level of 0.015 mg/L.

Please review the enclosed fact sheet provided by Suburban Testing Labs, along with the analytical report and contact our office with questions, or if further information is needed.

Sincerely,



John Hartman
President/Partner

Enclosures

2502 HORSESHOE ROAD, LANCASTER, PA 17601 717-656-3008 ♦ 800-338-3424 ♦ FAX: 717-656-7134
EMAIL: OFFICE@EHCASSOCIATES.COM WWW.EHCASSOCIATES.COM



SUBURBAN TESTING LABS

Results Report

Order ID: 6054197

EHC Associates, Inc.
2502 Horseshoe Road
Lancaster, PA 17601

Project: Lampety School SD

Attn: Barb King

Regulatory ID:

Sample Number: 6054197-01
Collector: JDH

Site: H.S Kitchen Island Sink
Collect Date: 05/26/2016 5:40 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing	0.001	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 14:31	RPV
----------------	-------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 6054197-02
Collector: JDH

Site: H.S Fountain by room 265
Collect Date: 05/26/2016 5:45 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing	< 0.001	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 14:37	RPV
----------------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 6054197-03
Collector: JDH

Site: HS Fountain by Room 265
Collect Date: 05/26/2016 5:47 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 14:39	RPV
---------------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 6054197-04
Collector: JDH

Site: MM Kitchen Sink
Collect Date: 05/26/2016 5:57 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing	0.002	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 14:41	RPV
----------------	-------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 6054197-05
Collector: JDH

Site: MM-fountain outside cafeteria
Collect Date: 05/26/2016 6:04 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing	< 0.001	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 14:43	RPV
----------------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Report Generated On: 06/13/2016 2:26 pm
STL_Results Revision #1.6

6054197
Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6054197-06

Site: MM-fountain outside cafeteria

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:04 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Flushed < 0.001 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 14:49 RPV

Sample Number: 6054197-07

Site: H.H Kitchen Island Sink

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:10 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing 0.002 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 14:45 RPV

Sample Number: 6054197-08

Site: H.H Kitchen Outside Kitchen

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:13 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing < 0.001 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 15:24 RPV

Sample Number: 6054197-09

Site: H.H Kitchen Outside Kitchen

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:15 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Flushed < 0.001 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 15:26 RPV

Sample Number: 6054197-10

Site: L.E Kitchen 3 Bay Sink

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:25 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing 0.002 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 15:32 RPV

Sample Number: 6054197-11

Site: L.E Cafeteria Fountain

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:27 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing < 0.001 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 15:34 RPV

Report Generated On: 06/13/2016 2:26 pm

6054197

STL_Results Revision #1.6

Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605

Phone: 800-433-6595

Fax: 610-375-4090

suburbantestinglabs.com



PADEP 06-00208



SUBURBAN TESTING LABS

Sample Number: 6054197-12	Site: L.E Cafeteria Fountain	Sample ID:							
Collector: JDH	Collect Date: 05/26/2016 6:34 am	Sample Type: Grab							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 15:36	RPV
---------------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Data Qualifiers:

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
CSR

Report Generated On: 06/13/2016 2:26 pm 6054197
STL_Results Revision #1.6 Effective: 07/09/2014



**Suburban Water Testing Labs**4600 Kutztown Road, Temple PA 19560
610-929-3666 - Fax: 610-929-8321 - h2otest.com0054197
Rachel LuckhartTAT (Circle One): Standard - 24hr - 48hr - 72hr - Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: 0054197

Client Name:

Address: EHC Associates
2502 Horseshoe Road
Lancaster, PA 17601

Contact Name:

Comments:

Fax:

Email:

Payment / P.O. Info:

008735-003

Lampeter-Sharkey Sch Dist
School Complex - Building

SWTL Sample Number	Sample Description / Site ID	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested	Bottle Quantity	See Codes Below				Comments / Field Data
							Matrix	Sample Type	Bottle Type	Preservative	
	HH-Kitchen	5-26-16	6:10	JDH	Lead Standing	1		G	P	H	PH=2.0
	HH-Island Sink		6:13	JDH	Lead Standing	1		G	P	H	PH=2.0
	HH-Front outside Kitchen		6:15	JDH	Lead Flush	1		G	P	H	PH=2.0
	HH-Front-Outside Kitchen		6:25	JDH	Lead Standing	1		G	P	H	PH=2.0
	LE-Kitchen 3 Bay Sink		6:27	JDH	Lead Standing	1		G	P	H	PH=2.0
	LE-CAF. Fountain		6:34	JDH	Lead Standing	1		G	P	H	PH=2.0
	LE-CAF Fountain				Lead Flush	1		G	P	H	PH=2.0

Requisitioned By: Received By: Requisitioned By: Received in Lab By:	Date: 5-26-16 Time: 9:45 AM Date: 5-26-16 Time: 08:45 Date: 5-26-16 Time: 11:00	On ice Y / N If no, Temp °C: On ice Y / N If no, Temp °C: 7.0 On ice Y / N If no, Temp °C: 7.0	Sample Conditions: Subfilled with DCC? <input checked="" type="checkbox"/> N Number of containers match number on DCC? <input checked="" type="checkbox"/> Y / N All containers in lot? <input checked="" type="checkbox"/> Y / N Tests within holding time? <input checked="" type="checkbox"/> Y / N VOC Vials free of headspace? <input checked="" type="checkbox"/> Y / N	Matrix Key: NPW = Non-Potable Water SWS = Raw Surface, Dechlorinated surface, not lab reported as mg/l PW = Potable Water SDWA = Safe Drinking Water Act Potable Sample Sample Type Key: G = Grab 2HC = 2 Hr Composite 24HC = 24 Hr Composite	Bottle Type Key: P = Plastic G = Glass O = Other Preservative Key: N = None A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options: <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
---	--	---	--	---	--	--

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF009 Rev. 1.1 Effective March 15, 2009
 Shaded areas are for SWTL use only.

PH=2.0 5-26-16

**Suburban Water Testing Labs**4600 Kulztown Road, Temple PA 19560
610-929-3666 - Fax: 610-929-8321 - h2otest.com9054197
Rachel LuckhartTAT (Circle One): Standard - 24hr - 48hr - 72hr - Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: _____

Address: _____
EHC Associates
2502 Horseshoe Road
Lancaster, PA 17601

Contact Name: _____

Comments: _____

Phone: _____

Fax: _____

Email: _____

Address: _____

Payment / P.O. Info: _____

008735-003

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	H.S. - Kitchen - Island Sink	5/26/16	5:40	JDH	lead (standing)	1		G	P	H	1st - lead
	HS - Front. by Rm 245 (w)		5:45	JDH	lead (standing)	1		G	P	H	1st - lead
	HS - Front. by Rm 245 (w)		5:47	JDH	lead (flush)	1		G	P	H	1st - lead
	MM - Kitchen Sink		5:57	JDH	lead (standing)	1		G	P	H	1st - lead
	mm - Front. outside CAF		6:04	JDH	lead (standing)	1		G	P	H	1st - lead
	mm Front outside CAF		6:07	JDH	lead (flush)	1		G	P	H	1st - lead

Relinquished By:	Date: 5-26-16 Time: 7:05 AM	On ice Y / N If no, Temp °C: _____	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y / N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Discolored Sludge, soil, etc. (reported as mg/kg) FW = Potable Water SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SCWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Received By:	Date: 5-26-16 Time: 8:45	On ice Y / N <input checked="" type="checkbox"/> Y / N If no, Temp °C: 12.1	Number of containers (match number on COC) <input checked="" type="checkbox"/> Y / N	Sample Type Key G = Grab BUC = Bifurcated Composite 24HC = 24 Hr Composite	SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Spectral M = Microbiological Residue	
Relinquished By:	Date: 5-26-16 Time: 11:00	On ice Y / N <input checked="" type="checkbox"/> Y / N If no, Temp °C: 7.0	Alcohol/water intact? <input checked="" type="checkbox"/> Y / N			
Received in Lab By:	Date: 5/26/16 Time: 11:00	On ice Y / N <input checked="" type="checkbox"/> Y / N If no, Temp °C: 12.1	Tests with holding times <input checked="" type="checkbox"/> Y / N			
			VOC Vials free of headspace? <input checked="" type="checkbox"/> Y / N			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.1 Effective March 15, 2009
Shaded areas are for SWTL use only.



LEAD FACT SHEET

Brief Overview:

Category:	Inorganic
Acceptable Level:	0.015 mg/L
Source:	Lead pipe, lead-based solder, and brass fixtures
Effect:	Physical/mental development, kidney problems, high blood pressure
Follow up:	Treat water, and then retest.
Treatment:	Corrosion control; Filter

Details:

Source:

Lead is a metal found in natural deposits. It is sometimes used in household plumbing materials or in water service lines used to bring water from the water main to the home. Lead may occur in drinking water either by contamination of the source water used by the water system or by corrosion of lead plumbing or brass fixtures, which is the most common cause of elevated lead levels. Corrosion (dissolving or wearing away of metal) caused by a chemical reaction between water and the metal in the pipes. All water will corrode metal plumbing materials to some degree.

Lead is a highly toxic metal that was used for many years in products found in and around our homes, including plumbing pipes and fitting. Homes built before 1986 are more likely to have lead pipes, fixtures and solder. However, new homes are also at risk: even legally "lead-free" items contain up to 8% lead. The most common problem is with brass or chrome-plated brass faucets and fixtures, which can leach significant amounts of lead into the water, especially hot water.

Effect:

The health effects of lead are most severe for infants and children. In babies and children, exposure to lead in drinking water above the acceptable level can result in interference with red blood cell chemistry, delays in physical and mental development along with slight deficits in attention span, hearing and learning abilities. In adults, it can cause increases in blood pressure. Adults who drink this water over many years could develop kidney problems, high blood pressure, stroke and cancer.

Follow up:

Often, results for standing water (water that has been sitting in pipes or plumbing fixtures) are over the acceptable level and results for flushed water (water that has ran through the pipes) are below the acceptable level. This is usually caused by corrosive water. Refrain from consuming water that has been in contact with your home's plumbing for more than six hours. Before using water for drinking or cooking, flush the cold-water faucet by allowing the water to run until it has become as cold as it will get. Do not use water taken from the hot tap for cooking or drinking, and especially not for making baby formula. Boiling water actually increases the concentration of lead. If both results are over the acceptable level, do not use the water for cooking or drinking. Treat water, then retest.

If you are experiencing elevated lead levels in drinking water, it may be likely that the copper levels are also elevated. This is especially true if the plumbing system in your home or apartment contains copper pipes or brass fixtures. Treat water, then retest.

Treatment:

We recommend contacting a water treatment professional for corrosion control.

For further technical assistance, call Suburban Testing Labs at 1-610-375-8378, or call the U. S. Environmental Protection Agency Safe Drinking Water Hotline at 1-800-426-4791.



SUBURBAN TESTING LABS

Results Report

Order ID: 6054197

EHC Associates, Inc.
2502 Horseshoe Road
Lancaster, PA 17601

Project: Lampety School SD

Attn: Barb King

Regulatory ID:

Sample Number: 6054197-01

Site: H.S Kitchen Island Sink

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 5:40 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing	0.001	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 14:31	RPV
----------------	-------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 6054197-02

Site: H.S Fountain by room 265

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 5:45 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing	< 0.001	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 14:37	RPV
----------------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 6054197-03

Site: HS Fountain by Room 265

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 5:47 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 14:39	RPV
---------------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 6054197-04

Site: MM Kitchen Sink

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 5:57 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing	0.002	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 14:41	RPV
----------------	-------	------	-----------	-------	---	----------	-----	----------------	-----

Sample Number: 6054197-05

Site: MM-fountain outside cafeteria

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:04 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing	< 0.001	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 14:43	RPV
----------------	---------	------	-----------	-------	---	----------	-----	----------------	-----

Report Generated On: 06/13/2016 12:36 pm

6054197

STL_Results Revision #1.6

Effective: 07/09/2014

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605

Phone: 800-433-6595

Fax: 610-375-4090

suburbantestinglabs.com



PADEP 06-00208



SUBURBAN TESTING LABS

Sample Number: 6054197-06

Site: MM-fountain outside cafeteria

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:04 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Flushed < 0.001 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 14:49 RPV

Sample Number: 6054197-07

Site: H.H Kitchen Island Sink

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:10 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing 0.002 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 14:45 RPV

Sample Number: 6054197-08

Site: H.H Kitchen Outside Kitchen

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:13 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing < 0.001 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 15:24 RPV

Sample Number: 6054197-09

Site: H.H Kitchen Outside Kitchen

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:15 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Flushed < 0.001 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 15:26 RPV

Sample Number: 6054197-10

Site: L.E Kitchen 3 Bay Sink

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:25 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing 0.002 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 15:32 RPV

Sample Number: 6054197-11

Site: L.E Cafeteria Fountain

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:27 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead, Standing < 0.001 mg/L EPA 200.8 0.001 1 06/07/16 RPV 06/11/16 15:34 RPV

Report Generated On: 06/13/2016 12:36 pm

6054197

STL_Results Revision #1.6

Effective: 07/09/2014

1037F MacArthur Road, Reading, PA 19605 Phone: 800-433-6595 Fax: 610-375-4090 suburbantestinglabs.com



PADEP 06-00208



SUBURBAN TESTING LABS

Sample Number: 6054197-12

Site: L.E Cafeteria Fountain

Sample ID:

Collector: JDH

Collect Date: 05/26/2016 6:34 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Metals									
Lead, Flushed	< 0.001	mg/L	EPA 200.8	0.001	1	06/07/16	RPV	06/11/16 15:36	RPV

Data Qualifiers:

All results meet the requirements of STL's TNI (NELAP) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
CSR

Report Generated On: 06/13/2016 12:36 pm

6054197

STL_Results Revision #1.6

Effective: 07/09/2014



**Suburban Water Testing Labs**

4600 Kutztown Road, Temple PA 19560
610-929-3666 - Fax: 610-929-8321 - h2otest.com



#054197
Rachel Luckhart

TAT (Circle One): Standard - 24hr - 48hr - 72hr - Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID:

Lampeter-Strasburg Sch Dist
School Complex - Building

Client Name:

Address: EHC Associates
2502 Horseshoe Road
Lancaster, PA 17601

Fax:

Contact Name:

Email:

Payment / P.O. Info:

008735-003

Comments:

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	HH-Kitchen Island Sink	5-26-16	6:10	JDH	Lead Standing	1		G	P	H	PH=2.0
	HH-Front-outside Kitchen		6:13	JPH	Lead Standing	1		G	P	H	PH=2.0
	HH-Front-Outside Kitchen		6:15	JPH	Lead Flush	1		G	P	H	PH=2.0
	LE-Kitchen 3 Bay Sink		6:25	JPH	Lead Standing	1		G	P	H	PH=2.0
	LE-CAF. Fountain		6:27	JPH	Lead Standing	1		G	P	H	PH=2.0
	LE-CAF Fountain		6:34	JDH	Lead Flush	1		G	P	H	PH=2.0

Requisitioned By: Received By: Requisitioned By: Received in Lab By:	Date: 5-26-16 Time: 9:45 AM Date: 5-26-16 Time: 08:45 Date: 5-26-16 Time: 11:00 Date: 5-26-16 Time: 11:00	On ice Y/N If no, Temp °C: On ice Y/N If no, Temp °C: On ice Y/N If no, Temp °C: On ice Y/N If no, Temp °C:	Sample Conditions Submitted with DOC? <input checked="" type="checkbox"/> Number of containers, multi number on DOC? <input checked="" type="checkbox"/> All containers in bag? <input checked="" type="checkbox"/> Tests within holding time? <input checked="" type="checkbox"/> VOC vials free of headspace? <input checked="" type="checkbox"/>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered Sludge, soil, etc. (as per label) PW = Potable Water SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Glass P = Plastic C = Composite S = 24 Hr 24HC = 24 Hr Composite	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HMT D = HCL S = H ₂ SO ₄ O = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
---	--	--	--	--	--	---

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.1 Effective March 15, 2009
Shaded areas are for SWTL use only.

PH=2.0 5-26-16

**Suburban Water Testing Labs**4600 Kutztown Road, Temple PA 19560
610-929-3666 - Fax: 610-929-8321 - h2otest.com6054197
Rachel LuckhartTAT (Circle One): Standard - 24hr - 48hr - 72hr - Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Client Name: _____

Address: _____
EHC Associates
2502 Horseshoe Road
Lancaster, PA 17601

Phone: _____

Fax: _____

Contact Name: _____

Email: _____

Order ID: _____

1st: Lampeter-Stranby SD
School Complex BuildingPayment / P.O. Info: 008735-003

Comments: _____

S/WL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Sampler Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	HS - Kitchen - Island Sink	5/26/16	5:40	JDH	lead (standing)	1		G	P	H	1st = lead
	HS - Fount. by Rm 245 (w)		5:45	JDH	lead (standing)	1		G	P	H	1st = lead
	HS - Fount by Rm 245 (w)		5:47	JDH	lead (flush)	1		G	P	H	1st = lead
	MM - Kitchen Sink		5:57	JDH	lead (standing)	1		G	P	H	1st = lead
	mm - Fount - outside CAF		6:04	JDH	lead (standing)	1		G	P	H	1st = lead
	mm Fount outside Caf		6:07	JDH	lead (flush)	1		G	P	H	1st = lead

Relinquished By: <u>[Signature]</u>	Date: <u>5-26-16</u> Time: <u>7:05 PM</u>	On ice Y / N <u>N</u> If no, Temp °C: _____	Sample Conditions Submitted with COC? <u>N</u> Number of containers match number on COC? <u>N</u> All containers in bag? <u>N</u> Tanks within holding times? <u>N</u> VOC Vials free of headspace? <u>N</u>	Matrix Key NFW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, etc. (reported as mg/kg) PW = Potable Water SDWA = Safe Drinking Water Act Possible Sample Sample Type Key G = Grab BIC = 8 hr Composite 24HC = 24 hr Composite D = Distribution E = Entry Point R = Raw C = Check S = Special N = Maximum Residence	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Received By: <u>[Signature]</u>	Date: <u>5-26-16</u> Time: <u>8:45</u>	On ice <u>Y</u> <u>15C</u> If no, Temp °C: <u>12.10</u>				
Relinquished By: <u>[Signature]</u>	Date: <u>5-25-16</u> Time: <u>11:00</u>	On ice <u>N</u> If no, Temp °C: <u>20.0</u>				
Received in Lab By: <u>[Signature]</u>	Date: <u>5/26/16</u> Time: <u>1100</u>	On ice <u>N</u> If no, Temp °C: <u>12.1</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.1 Effective March 15, 2009
Shaded areas are for SWTL use only.