



Element Materials Technology - Fort Wayne  
 328 Ley Rd.  
 Fort Wayne, IN 46825  
 TEL: (260) 424-1622 FAX: (260) 424-9124  
 Website: www.element.com

# Analytical Report

(wastewater)  
 WO#: 21090938  
 Date Reported 9/26/2021

**CLIENT:** Metropolitan School District of Wabash County    **Collection Date:** 9/10/2021 10:20:00 AM  
**Project:** Copper/Lead Metro North IN2850839  
**Lab ID:** 21090938-001    **Matrix:** DRINKING WATER  
**Client Sample ID** Kitchen  
**Sample Location:**

Analyses	Result	RL	Qual	Units	DF	PL	Date Analyzed
<b>COPPER &amp; LEAD IN DRINKING WATER LEAD IN WATER BY ICP-MS</b>					<b>E200.8</b>		Analyst: FJR
Lead	< 0.5	0.5		µg/L	1	15.0	9/20/2021
<b>COPPER &amp; LEAD IN DRINKING WATER METALS IN WATER BY ICP-MS, TOTALS</b>					<b>E200.8</b>		Analyst: FJR
Copper	0.0062	0.0050		mg/L	1	1.30	9/20/2021

**Qualifiers:** H Holding times for preparation or analysis exceeded    M Manual Integration used to determine area response  
 ND Not Detected at the Reporting Limit    PL Permit Limit  
 PQL Practical Quantitation Limit    RL Reporting Detection Limit



Element Materials Technology - Fort Wayne  
 328 Ley Rd.  
 Fort Wayne, IN 46825  
 TEL: (260) 424-1622 FAX: (260) 424-9124  
 Website: www.element.com

# Analytical Report

(wastewater)  
 WO#: 21090938  
 Date Reported 9/26/2021

**CLIENT:** Metropolitan School District of Wabash County    **Collection Date:** 9/10/2021 10:25:00 AM  
**Project:** Copper/Lead Metro North IN2850839  
**Lab ID:** 21090938-002    **Matrix:** DRINKING WATER  
**Client Sample ID** Health Room  
**Sample Location:**

Analyses	Result	RL	Qual	Units	DF	PL	Date Analyzed
<b>COPPER &amp; LEAD IN DRINKING WATER LEAD IN WATER BY ICP-MS</b>					<b>E200.8</b>		Analyst: FJR
Lead	< 0.5	0.5		µg/L	1	15.0	9/20/2021
<b>COPPER &amp; LEAD IN DRINKING WATER METALS IN WATER BY ICP-MS, TOTALS</b>					<b>E200.8</b>		Analyst: FJR
Copper	< 0.0050	0.0050		mg/L	1	1.30	9/20/2021

**Qualifiers:** H Holding times for preparation or analysis exceeded    M Manual Integration used to determine area response  
 ND Not Detected at the Reporting Limit    PL Permit Limit  
 PQL Practical Quantitation Limit    RL Reporting Detection Limit



Element Materials Technology - Fort Wayne  
 328 Ley Rd.  
 Fort Wayne, IN 46825  
 TEL: (260) 424-1622 FAX: (260) 424-9124  
 Website: www.element.com

# Analytical Report

(wastewater)

WO#: **21090938**

Date Reported **9/26/2021**

**CLIENT:** Metropolitan School District of Wabash County    **Collection Date:** 9/10/2021 10:28:00 AM  
**Project:** Copper/Lead Metro North IN2850839  
**Lab ID:** 21090938-003    **Matrix:** DRINKING WATER  
**Client Sample ID** Teacher Lounge  
**Sample Location:**

Analyses	Result	RL	Qual	Units	DF	PL	Date Analyzed
<b>COPPER &amp; LEAD IN DRINKING WATER LEAD IN WATER BY ICP-MS</b>					<b>E200.8</b>		Analyst: FJR
Lead	< 0.5	0.5		µg/L	1	15.0	9/20/2021
<b>COPPER &amp; LEAD IN DRINKING WATER METALS IN WATER BY ICP-MS, TOTALS</b>					<b>E200.8</b>		Analyst: FJR
Copper	0.0536	0.0050		mg/L	1	1.30	9/20/2021

**Qualifiers:** H Holding times for preparation or analysis exceeded    M Manual Integration used to determine area response  
 ND Not Detected at the Reporting Limit    PL Permit Limit  
 PQL Practical Quantitation Limit    RL Reporting Detection Limit



Element Materials Technology - Fort Wayne  
 328 Ley Rd.  
 Fort Wayne, IN 46825  
 TEL: (260) 424-1622 FAX: (260) 424-9124  
 Website: www.element.com

# Analytical Report

(wastewater)  
 WO#: 21090938  
 Date Reported 9/26/2021

**CLIENT:** Metropolitan School District of Wabash County      **Collection Date:** 9/10/2021 10:34:00 AM  
**Project:** Copper/Lead Metro North IN2850839  
**Lab ID:** 21090938-004      **Matrix:** DRINKING WATER  
**Client Sample ID** Wing 1  
**Sample Location:**

Analyses	Result	RL	Qual	Units	DF	PL	Date Analyzed
<b>COPPER &amp; LEAD IN DRINKING WATER LEAD IN WATER BY ICP-MS</b>					<b>E200.8</b>		Analyst: FJR
Lead	< 0.5	0.5		µg/L	1	15.0	9/20/2021
<b>COPPER &amp; LEAD IN DRINKING WATER METALS IN WATER BY ICP-MS, TOTALS</b>					<b>E200.8</b>		Analyst: FJR
Copper	0.0811	0.0050		mg/L	1	1.30	9/20/2021

**Qualifiers:** H Holding times for preparation or analysis exceeded      M Manual Integration used to determine area response  
 ND Not Detected at the Reporting Limit      PL Permit Limit  
 PQL Practical Quantitation Limit      RL Reporting Detection Limit



Element Materials Technology - Fort Wayne  
 328 Ley Rd.  
 Fort Wayne, IN 46825  
 TEL: (260) 424-1622 FAX: (260) 424-9124  
 Website: www.element.com

# Analytical Report

(wastewater)  
 WO#: 21090938  
 Date Reported 9/26/2021

**CLIENT:** Metropolitan School District of Wabash County    **Collection Date:** 9/10/2021 10:34:00 AM  
**Project:** Copper/Lead Metro North IN2850839  
**Lab ID:** 21090938-005    **Matrix:** DRINKING WATER  
**Client Sample ID** Wing 3  
**Sample Location:**

Analyses	Result	RL	Qual	Units	DF	PL	Date Analyzed
<b>COPPER &amp; LEAD IN DRINKING WATER LEAD IN WATER BY ICP-MS</b>					<b>E200.8</b>		Analyst: FJR
Lead	< 0.5	0.5		µg/L	1	15.0	9/20/2021
<b>COPPER &amp; LEAD IN DRINKING WATER METALS IN WATER BY ICP-MS, TOTALS</b>					<b>E200.8</b>		Analyst: FJR
Copper	0.0634	0.0050		mg/L	1	1.30	9/20/2021

**Qualifiers:** H Holding times for preparation or analysis exceeded    M Manual Integration used to determine area response  
 ND Not Detected at the Reporting Limit    PL Permit Limit  
 PQL Practical Quantitation Limit    RL Reporting Detection Limit