

Piney Ridge ES

Lab Identification	Sample Identification	Date Sampled	Time Sampled	pH (Range 6.5-8.5)	Copper mg/L (< 1.3 mg/L)	Lead ppb (< 20ppb)	Pass/Fail Copper/Lead
E047184-01	Dishroom Triple Sink Left	12/01/2016	07:17	7.0	0.327	1450	FAIL
E047184-02	Dishroom Triple Sink Right	12/01/2016	07:17	7.2	1.16	89.0	FAIL
E047184-03	Dishroom Hand Sink	12/01/2016	07:18	7.0	0.162	68.6	FAIL
E047184-04	Kitchen Hand Sink	12/01/2016	07:19	7.2	0.088	1.9	PASS
E047184-05	Kitchen Hand Sink by Serving Line	12/01/2016	07:20	7.0	0.210	93.9	FAIL
E047184-06	Kitchen Pot Filler	12/01/2016	07:20	7.4	0.078	1.1	PASS
E047184-07	Staff Room	12/01/2016	07:22	7.4	0.078	<1.0	PASS
E047184-08	Fountain 1st Floor by Room 101	12/01/2016	07:23	7.6	0.066	<1.0	PASS
E047184-09	Fountain in Cafeteria	12/01/2016	07:24	7.6	0.122	<1.0	PASS
E047184-10	Fountain by Room 116	12/01/2016	07:25	7.7	0.051	<1.0	PASS
E047184-11	Fountain by 2nd Floor Elevator	12/01/2016	07:26	7.7	0.119	<1.0	PASS
E047184-12	Sink Nurses Office	12/01/2016	07:27	7.7	0.139	3.6	PASS
E047184-13	Fountain by Room 314	12/01/2016	07:29	7.8	0.066	<1.0	PASS
E047184-14	Fountain by Room 301	12/01/2016	07:30	7.9	0.079	<1.0	PASS