



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@

Attn:

**TimPopp**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800

Fax: (856) 840-8815

8/31/2021

Middle School

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 8/12/2021. The results are tabulated on the attached data pages for the following client designated project:

**21-206 Bridgewater Raritan - BRMS**

The reference number for these samples is EMSL Order #012109290. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com>      [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012109290
CustomerID:	TTIE54
CustomerPO:	033125
ProjectID:	

Attn: <b>TimPopp</b> <b>TTI Environmental Inc.</b> <b>1253 North Church Street</b> <b>Moorestown, NJ 08057</b>	Phone: (856) 840-8800 Fax: (856) 840-8815 Received: 8/12/2021 01:10 PM
Project: 21-206 Bridgewater Raritan - BRMS	

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW1-AW Awing		8/5/2021 5:43:00 AM	012109290-0001		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	6.70	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:21
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW3-AW AWing		8/5/2021 5:19:00 AM	012109290-0002		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	1.66	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:23
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW5-AW Awing		8/5/2021 4:40:00 AM	012109290-0003		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	20.6	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:25
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW1-GH Gym Hall		8/5/2021 4:48:00 AM	012109290-0004		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	6.14	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:27
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW2-GH Gym Hall		8/5/2021 4:52:00 AM	012109290-0005		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	47.0	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012109290  
 CustomerID: TTIE54  
 CustomerPO: 033125  
 ProjectID:

Attn: **TimPopp** Phone: (856) 840-8800  
**TTI Environmental Inc.** Fax: (856) 840-8815  
**1253 North Church Street** Received: 8/12/2021 01:10 PM  
**Moorestown, NJ 08057**

Project: 21-206 Bridgewater Raritan - BRMS

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW1-GTR Girls Team Room		8/5/2021 5:12:00 AM	012109290-0006		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	65.1	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:33
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW2-GTR Girls Team Room		8/5/2021 5:11:00 AM	012109290-0007		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	10.0	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:35
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW1-BTR Boys Team Room		8/5/2021 4:43:00 AM	012109290-0008		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	4660 D	100 µg/L	8/27/2021 JW	8/28/2021 JW 12:41
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW2-BTR Boys Team Room		8/5/2021 4:41:00 AM	012109290-0009		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	132 D	5.00 µg/L	8/25/2021 KG	8/26/2021 JW 21:34
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW-EW Ewing		8/5/2021 5:21:00 AM	012109290-0010		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	4.05	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012109290

CustomerID: TTIE54

CustomerPO: 033125

ProjectID:

Attn: **TimPopp**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 8/12/2021 01:10 PM

Project: 21-206 Bridgewater Raritan - BRMS

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-DW-GLR Girls Locker Room		8/5/2021 4:50:00 AM		012109290-0011	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	7.72	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:44
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-DW-BW Bwing		8/5/2021 4:39:00 AM		012109290-0012	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	3.43	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:46
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
,S-DW1-BWU Bwing UP		8/5/2021 4:29:00 AM		012109290-0013	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	12.4	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:48
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-DW2-BWU Bwing UP		8/5/2021 4:27:00 AM		012109290-0014	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	5.80	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:51
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-DW1-CW Cwing		8/5/2021 4:35:00 AM		012109290-0015	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	15.9	1.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012109290
CustomerID:	TTIE54
CustomerPO:	033125
ProjectID:	

Attn: <b>TimPopp</b> <b>TTI Environmental Inc.</b> <b>1253 North Church Street</b> <b>Moorestown, NJ 08057</b>	Phone: (856) 840-8800 Fax: (856) 840-8815 Received: 8/12/2021 01:10 PM
Project: 21-206 Bridgewater Raritan - BRMS	

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW2-CW Cwing		8/5/2021 4:36:00 AM	012109290-0016		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	89.7 D	2.00 µg/L	8/27/2021 JW	8/28/2021 JW 12:54
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW1-CWU Cwing UP		8/5/2021 4:23:00 AM	012109290-0017		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	14.5	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:05
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW2-CWU Cwing UP		8/5/2021 4:25:00 AM	012109290-0018		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:11
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW1-DW Dwing		8/5/2021 4:43:00 AM	012109290-0019		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	13.8	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:13
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
MS-DW2-DW Dwing		8/5/2021 4:45:00 AM	012109290-0020		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	1.40	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012109290

CustomerID: TTIE54

CustomerPO: 033125

ProjectID:

Attn: **TimPopp**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 8/12/2021 01:10 PM

Project: 21-206 Bridgewater Raritan - BRMS

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-DW1-DWU Dwing UP		8/5/2021 4:34:00 AM		012109290-0021	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	8.93	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:17
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-DW2-DWU Dwing UP		8/5/2021 4:33:00 AM		012109290-0022	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:23
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-WC1-GH Gym Hall		8/5/2021 5:00:00 AM		012109290-0023	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:25
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-WC2-GH Gym Hall		8/5/2021 5:01:00 AM		012109290-0024	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:27
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-WC1-CFA Café A		8/5/2021 5:31:00 AM		012109290-0025	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012109290

CustomerID: TTIE54

CustomerPO: 033125

ProjectID:

Attn: **TimPopp**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 8/12/2021 01:10 PM

Project: 21-206 Bridgewater Raritan - BRMS

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-WC2-CFA Café A		8/5/2021 5:29:00 AM		012109290-0026	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:30
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-WC1-CFB Café B		8/5/2021 5:26:00 AM		012109290-0027	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:32
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-WC2-CFB Café B		8/5/2021 5:24:00 AM		012109290-0028	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:38
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-KC1-KIT Kitchen		8/5/2021 5:33:00 AM		012109290-0029	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	3.63	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:40
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-KC2-KIT Kitchen		8/5/2021 5:32:00 AM		012109290-0030	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	16.3	1.00 µg/L	8/25/2021 KG	8/26/2021 JW 20:58

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012109290  
 CustomerID: TTIE54  
 CustomerPO: 033125  
 ProjectID:

Attn: **TimPopp**  
**TTI Environmental Inc.**  
**1253 North Church Street**  
**Moorestown, NJ 08057**

Phone: (856) 840-8800  
 Fax: (856) 840-8815  
 Received: 8/12/2021 01:10 PM

Project: 21-206 Bridgewater Raritan - BRMS

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-KC3-KIT Kitchen		8/5/2021 5:37:00 AM		012109290-0031	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	15.9	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:46
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS-IM-KIT Kitchen Ice Machine		8/5/2021 5:35:00 AM		012109290-0032	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	24.0	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:48
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
Blank		8/5/2021 6:00:00 AM		012109290-0033	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	8/27/2021 JW	8/27/2021 JW 21:50

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results





# Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

012109290

200 RL 130 N  
Chamberson, NJ 08077

PHONE: (800) 220-3675  
EMAIL: EnvChemistry2@EMSL.com

EMSL ANALYTICAL, INC.

**Customer Information**

Customer ID: \_\_\_\_\_

Company Name: TTI Environmental Inc

Contact Name: Tim Popp

Street Address: 1253 North Church Street

City, State, Zip: Moorestown NJ

Country: \_\_\_\_\_

Phone: 856-840-8800

Email(s) for Report: timp@ttienv.com

**Billing Information**

Billing ID: \_\_\_\_\_

Company Name: Same

Billing Contact: \_\_\_\_\_

Street Address: \_\_\_\_\_

City, State, Zip: \_\_\_\_\_

Country: \_\_\_\_\_

Phone: \_\_\_\_\_

Email(s) for Invoice: \_\_\_\_\_

Project Name/No: 21-206 Bridgewater Raritan - BRMS

EMSL LIMS Project ID: \_\_\_\_\_

US State where samples collected: NJ

State of Connecticut (CT) must select project location: \_\_\_\_\_

Commercial (Taxable)  Residential (Non-Taxable)

Purchase Order: 033125

State Reporting Required? Yes  No

Samples for Compliance? Yes  No

If Yes, for NPDES? Yes  No

Other (Specify) NJDOE

Samples Collected by (Check One): EMSL  CLIENT

Samples Received Chilled? Yes  No

Sample(s) Temperature Upon Receipt (LAB ONLY) \_\_\_\_\_

Sampled By Name: *W. West*

Standard Turn-Around-Time: 2 Weeks

Turn-Around-Time (TAT) 1 Week  4 Days  3 Days  2 Days  1 Day

The following TAT's are subject to Lab approval. Call lab to confirm TAT before submitting.

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix	Preservative	List Test(s) Needed (Write in test below, then check on sample line.)								Comments		
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:			
See attached				W=Water S=Soil A=Air SL=Sludge O=Other	1 HCL 2 HNO3 3 H2SO4 4 ICE 5 Other	Lead										

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.):

Reporting Requirements: Results Only  Results and QC  Reduced Deliverables  Hiresults EDD  Excel  Other (Describe Above)

Method of Shipment: \_\_\_\_\_

Order ID: 012109290

Relinquished by: *[Signature]* Date/Time: 8/12/21 6:00

Relinquished by: *[Signature]* Date/Time: 8/12/21 12:30 PM

Received by: *[Signature]* Date/Time: 8/12/21 12:30 PM

Received by: *[Signature]* Date/Time: 8/12/21 1:10 PM

Method of Shipment: \_\_\_\_\_

Agree to Electronic Signature (By checking, I consent to signing this Chain of Custody Report by electronic signature.)



1253 North Church Street, Moorestown, NJ 08057  
 856-840-8800 Fax 856-840-8815

**LEAD IN WATER SAMPLING DATA AND CHAIN OF CUSTODY**

PROJECT #: 21-206 CLIENT: Bridgewater-Raritan Board of Education

PO #: 033125 SAMPLE(S): *water / ALEXS* DATE: 8-5-21

FACILITY: *BRMS* ADDRESS: *128 Herriwood Drive*

Sample ID	Location/Description	Time	Sample Type: Initial Flush (30sec / 15min)	Outlet Type:	Volume	Notes: Discolored, Odor, Low Flow, Etc...
19	MS-Dwg2-eww Cwng	4:36	Initial		250mL	
20	MS-Dw1-eww Cwng UP	4:23	Initial		250mL	
21	MS-Dwg-eww Cwng UP	4:25	Initial		250mL	
22	MS-Dw1-Dw Dwng	4:43	Initial		250mL	
23	MS-Dw2-Dw Dwng	4:45	Initial		250mL	
24	MS-Dw1-Dw Dwng UP	4:34	Initial		250mL	
25	MS-Dw2-Dw Dwng UP	4:33	Initial		250mL	
26	MS-wc1-GH Gym Hall	5:00	Initial		250mL	
27	MS-wc2-GH Gym Hall	5:01	Initial		250mL	
28	MS-wc1-GH Cafe' A	5:31	Initial		250mL	
29	MS-wc2-GH Cafe' A	5:29	Initial		250mL	
30	MS-wc1-CFB Cafe' B	5:26	Initial		250mL	
31	MS-wc2-CFB Cafe' B	5:24	Initial		250mL	
44	MS-KC1-KIT Kitchen	5:33	Initial		250mL	
45	MS-KC2-KIT Kitchen	5:32	Initial		250mL	
46	MS-KC3-KIT Kitchen	5:37	Initial		250mL	
48	MS-EM-KIT Kitchen Ice Machine	5:35	Initial		250mL	
	Blank	6:00	Initial		250mL	

OrderID: 012109290