



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2 North German St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvtl.com



Report Date: 29 Mar 2016

Work Order #: 12-5242
Account #: 019442

LAVONNE DENZER
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Date Received: 17 Mar 2016
Date Sampled: 11 Mar 2016
Time Sampled: 10:30
Temperature at Receipt: 20.1C

PROJECT NAME: ROCKFORD ELEM.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
16-A8722	RES-1 CAFETERIA FOUNTAIN	0.51 ug/L	15.0	28 Mar 16	RMV
16-A8723	RES-2 KITCHEN KETTLE FILLER	4.08 ug/L	15.0	28 Mar 16	RMV
16-A8724	RES-3 FOUNTAIN OUTSIDE A-11	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8725	RES-4 RM 301 FOUNTAIN	0.62 ug/L	15.0	28 Mar 16	RMV
16-A8726	RES-5 RM 307 FOUNTAIN	2.79 ug/L	15.0	28 Mar 16	RMV
16-A8727	RES-6 RM 802 FOUNTAIN	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8728	RES-7 RM 804 FOUNTAIN	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8729	RES-8 RM 702 FOUNTAIN	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8730	RES-9 RM 705 FOUNTAIN	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8731	RES-10 FOUNTAIN OUTSIDE R63 BATHROOM	0.97 ug/L	15.0	28 Mar 16	RMV
16-A8732	RES-11 RM 603 FOUNTAIN	1.43 ug/L	15.0	28 Mar 16	RMV
16-A8733	RES-12 RM 605 FOUNTAIN	1.18 ug/L	15.0	28 Mar 16	RMV
16-A8734	RES-13 RM 505 FOUNTAIN	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8735	RES-14 RM 501 FOUNTAIN	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8736	RES-15 FOUNTAIN OUTSIDE R42 BATHROOM	1.13 ug/L	15.0	28 Mar 16	RMV
16-A8737	RES-16 RM 402 FOUNTAIN	1.03 ug/L	15.0	28 Mar 16	RMV

Approved by:

Dan O'Connell, Chemistry Laboratory Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 WI LAB # 999447680 ND MICRO # 1013-M ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2 North German St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvttl.com



Report Date: 29 Mar 2016

LAVONNE DENZER
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Work Order #: 12-5242
Account #: 019442

Date Received: 17 Mar 2016
Date Sampled: 11 Mar 2016
Time Sampled: 11:43
Temperature at Receipt: 20.1C

PROJECT NAME: ROCKFORD ELEM.

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
16-A8738	RES-17 RM 405 FOUNTAIN	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8739	RES-18 FOUNTAIN OUTSIDE RM 206	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8740	RES-19 RM 209 FOUNTAIN	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8741	RES-20 RM 213 FAUCET	0.55 ug/L	15.0	28 Mar 16	RMV

Approved by:

Dan O'Connell, Chemistry Laboratory Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health A2 accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix

= Due to concentration of other analytes

! = Due to sample quantity

+ = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 WI LAB # 999447680 ND MICRO # 1013-M ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2 North German St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvtl.com



Report Date: 29 Mar 2016

LAVONNE DENZER
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Work Order #: 12-5246
Account #: 019442

Date Received: 17 Mar 2016
Date Sampled: 11 Mar 2016
Time Sampled: 12:00
Temperature at Receipt: 20.1C

PROJECT NAME: ROCKFORD MIDDLE SCHOOL

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
16-A8742	RMS-1 ETN OUTSIDE CAFETERIA	0.82 ug/L	15.0	28 Mar 16	RMV
16-A8743	RMS-2 VULCAN KETTLE POT FILLER	7.15 ug/L	15.0	28 Mar 16	RMV
16-A8744	RMS-3 GYM FOUNTAIN	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8745	RMS-4 FAUCET RM 106	3.01 ug/L	15.0	28 Mar 16	RMV
16-A8746	RMS-6 FOUNTAIN RM 120	11.6 ug/L	15.0	28 Mar 16	RMV
16-A8747	RMS-5 FAUCET RM 114	116 ~ ug/L	15.0	28 Mar 16	RMV
~Sample diluted due to result above calibration or linear range.					
16-A8748	RMS-7 FAUCET RM 123	2.19 ug/L	15.0	28 Mar 16	RMV
16-A8749	RMS-8 FOUNTAIN OUTSIDE 311	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8750	RMS-9 FOUNTAIN OUTSIDE 309	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8751	RMS-10 FOUNTAIN OUTSIDE D.O	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8752	RMS-11 FOUNTAIN D.O BREAKROOM	1.90 ug/L	15.0	28 Mar 16	RMV

Approved by:

Dan O'Connell, Chemistry Laboratory Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 WI LAB # 999447680 ND MICRO # 1013-M ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2 North German St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvttl.com



LAVONNE DENZER
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Report Date: 3 May 2016

Lab Number: 16-A15450
Work Order #: 201612-6968
Account #: 019442

Date Received: 22 Apr 2016
Time Received: 9:35
Date Sampled: 20 Apr 2016
Time Sampled: 9:00

Project Name: ROCKFORD MIDDLE SCHOOL

Temperature at Receipt: AMBIENT

Sample Description: ROOM 114 RETAKE (R114R)

Analyte	Results	MCL	RAL	Method	Analyzed	Analyst
Lead	10.6 ug/L	15.0	NA	200.8	4/30/16 12:42	RMB

MCL is defined as the Maximum Contaminant Level allowed by the Safe Drinking Water Act. RAL is the Recommended Allowable Limit. For further information, contact your state or local health department or call the EPA Safe Drinking Water Hotline 1-800-426-4791.

Approved by:

Dan O'Connell, Chemistry Laboratory Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix

= Due to concentration of other analytes

! = Due to sample quantity

+ = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 WI LAB # 999447680 ND MICRO # 1013-M ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2 North German St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvttl.com



Report Date: 30 Mar 2016

LAVONNE DENZER
RESOURCE TRAINING & SOLUTIONS
137 23RD ST S
SARTELL MN 56377

Work Order #: 12-5248
Account #: 019442

Date Received: 17 Mar 2016
Date Sampled: 11 Mar 2016
Time Sampled: 9:00
Temperature at Receipt: 20.1C

PROJECT NAME: ROCKFORD H.S

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
16-A8753	RHS-1 REC ENTRY DF	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8754	RHS-2 REC FIELDHOUSE FTN	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8755	RHS-3 KITCHEN VULCAN FRYER POT FILLER	1.16 ug/L	15.0	28 Mar 16	RMV
16-A8756	RHS-4 GYM DF	0.76 ug/L	15.0	28 Mar 16	RMV
16-A8757	RHS-5 DF OUTSIDE RM R-8	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8758	RHS-6 DF OUTSIDE RM 104	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8759	RHS-7 DF OUTSIDE RM 705	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8760	RHS-8 DF COMMONS	< 0.5 ug/L	15.0	28 Mar 16	RMV
16-A8764	RHS-9 GROEN KETTLE POT FILLER	< 0.5 ug/L	15.0	28 Mar 16	RMV

Approved by:


Dan O'Connell, Chemistry Laboratory Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix

= Due to concentration of other analytes

! = Due to sample quantity

+ = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 WI LAB # 999447680 ND MICRO # 1013-M ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.