



**Charles County Public Schools**  
P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646  
**Attention:**

Saturday, January 15, 2022  
***Certificate of Analysis***  
**FINAL**

**Project Information:**

Report for Lab No: 60404.  
Samples flushed by Martel on October 15, 2021, sampled by Martel on October 16, 2021.  
Project Identification: MD HB 270  
School: 20 Mary H. Matula ES PSC #08.032

**References and Important Notes:**

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

\* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

**Notices:**

Chain of Custody Form(s) are attached and are an integral part of this report.  
This report will be retained for at least five years and will be disposed of without notice.  
Measurement uncertainty for each listed test is available upon request.  
The results presented herein relate only to the samples or items tested.  
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60404 1	MMES-1-FC [sink on left--kitchen 2 comp]	10/16/2021 07:46			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.60	ug/l	EPA .200.8	2	01/13/2022 13:19 BJ
60404 2	MMES-2-FC [sink on right--kitchen 2 comp]	10/16/2021 07:46			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.17	ug/l*	EPA .200.8	2	01/13/2022 13:31 BJ
60404 3	MMES-3-FC [island sink - next to restroom--kitchen sink]	10/16/2021 07:46			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.44	ug/l	EPA .200.8	2	01/13/2022 13:34 BJ
60404 4	MMES-4-FC [island sink--kitchen sink]	10/16/2021 07:47			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.45	ug/l	EPA .200.8	2	01/13/2022 13:36 BJ
60404 5	MMES-5-FC [sink--kitchen sink]	10/16/2021 07:47			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.00	ug/l	EPA .200.8	2	01/13/2022 13:39 BJ
60404 6	MMES-6-IM [Ice Machine --kitchen sink]	10/16/2021 07:47			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/14/2022 08:43 BJ
60404 7	MMES-7-DC [water fountain --kitchen ]	10/16/2021 07:47			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 13:41 BJ
60404 8	MMES-8-DC [water fountain --hallway]	10/16/2021 07:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 13:44 BJ



MARTEL NO. 60404 9 CLIENT SAMPLE IDENTIFICATION MMES-9-DC [water fountain --hallway] Sample Date/Time 10/16/2021 07:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 13:46 BJ

MARTEL NO. 60404 12 CLIENT SAMPLE IDENTIFICATION MMES-12-FC [sink--CR 132 (Sp-Ed) SOAR] Sample Date/Time 10/16/2021 07:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.47	ug/l*	EPA .200.8	2	01/13/2022 13:48 BJ

MARTEL NO. 60404 13 CLIENT SAMPLE IDENTIFICATION MMES-13-DB [bubbler--CR 132 (Sp-Ed) SOAR] Sample Date/Time 10/16/2021 07:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.37	ug/l	EPA .200.8	2	01/13/2022 13:59 BJ

MARTEL NO. 60404 22 CLIENT SAMPLE IDENTIFICATION MMES-22-FC [sink--CR 118A (Sp-Ed) Pull Out] Sample Date/Time 10/16/2021 07:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 14:04 BJ

MARTEL NO. 60404 23 CLIENT SAMPLE IDENTIFICATION MMES-23-DB [bubbler--CR 118A (Sp-Ed) Pull Out] Sample Date/Time 10/16/2021 07:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.87	ug/l*	EPA .200.8	2	01/13/2022 14:06 BJ

MARTEL NO. 60404 28 CLIENT SAMPLE IDENTIFICATION MMES-28-FC [sink--Classroom 129] Sample Date/Time 10/16/2021 07:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.93	ug/l	EPA .200.8	2	01/13/2022 14:09 BJ

MARTEL NO. 60404 29 CLIENT SAMPLE IDENTIFICATION MMES-29-DB [bubbler--Classroom 129] Sample Date/Time 10/16/2021 07:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.07	ug/l	EPA .200.8	2	01/13/2022 14:11 BJ

MARTEL NO. 60404 30 CLIENT SAMPLE IDENTIFICATION MMES-30-FC [sink--Classroom 128] Sample Date/Time 10/16/2021 07:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.06	ug/l	EPA .200.8	2	01/13/2022 14:14 BJ



**Certificate of Analysis**

MARTEL NO. 60404 31 CLIENT SAMPLE IDENTIFICATION MMES-31-DB [bubbler--Classroom 128] Sample Date/Time 10/16/2021 07:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.01	ug/l	EPA .200.8	2	01/13/2022 14:16 BJ

MARTEL NO. 60404 34 CLIENT SAMPLE IDENTIFICATION MMES-34-FC [sink--CR 121 (Sp-Ed) EA] Sample Date/Time 10/16/2021 07:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.40	ug/l	EPA .200.8	2	01/13/2022 14:18 BJ

MARTEL NO. 60404 35 CLIENT SAMPLE IDENTIFICATION MMES-35-DB [bubbler--CR 121 (Sp-Ed) EA] Sample Date/Time 10/16/2021 07:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.17	ug/l	EPA .200.8	2	01/13/2022 14:21 BJ

MARTEL NO. 60404 38 CLIENT SAMPLE IDENTIFICATION MMES-38-FC [sink--Classroom 126] Sample Date/Time 10/16/2021 08:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.04	ug/l*	EPA .200.8	2	01/13/2022 14:23 BJ

MARTEL NO. 60404 39 CLIENT SAMPLE IDENTIFICATION MMES-39-DB [bubbler--Classroom 126] Sample Date/Time 10/16/2021 08:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.50	ug/l	EPA .200.8	2	01/13/2022 14:31 BJ

MARTEL NO. 60404 40 CLIENT SAMPLE IDENTIFICATION MMES-40-FC [sink--CR 122 (Sp-Ed) EA] Sample Date/Time 10/16/2021 08:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.10	ug/l	EPA .200.8	2	01/13/2022 14:38 BJ

MARTEL NO. 60404 41 CLIENT SAMPLE IDENTIFICATION MMES-41-DB [bubbler--CR 122 (Sp-Ed) EA] Sample Date/Time 10/16/2021 08:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.83	ug/l	EPA .200.8	2	01/13/2022 14:41 BJ

MARTEL NO. 60404 48 CLIENT SAMPLE IDENTIFICATION MMES-48-DC [water fountain --hallway] Sample Date/Time 10/16/2021 07:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 14:43 BJ



**Certificate of Analysis**

MARTEL NO. 60404 51 CLIENT SAMPLE IDENTIFICATION MMES-51-DC [water fountain --hallway] Sample Date/Time 10/16/2021 08:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 14:46 BJ

MARTEL NO. 60404 54 CLIENT SAMPLE IDENTIFICATION MMES-54-FC [sink--Classroom 109] Sample Date/Time 10/16/2021 08:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.65	ug/l*	EPA .200.8	2	01/14/2022 08:46 BJ

MARTEL NO. 60404 55 CLIENT SAMPLE IDENTIFICATION MMES-55-DB [bubbler--Classroom 109] Sample Date/Time 10/16/2021 08:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.50	ug/l	EPA .200.8	2	01/13/2022 14:48 BJ

MARTEL NO. 60404 56 CLIENT SAMPLE IDENTIFICATION MMES-56-FC [sink--CR 103 (Sp-Ed) SOAR] Sample Date/Time 10/16/2021 08:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.19	ug/l	EPA .200.8	2	01/13/2022 14:51 BJ

MARTEL NO. 60404 57 CLIENT SAMPLE IDENTIFICATION MMES-57-DB [bubbler--CR 103 (Sp-Ed) SOAR] Sample Date/Time 10/16/2021 08:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.34	ug/l	EPA .200.8	2	01/14/2022 08:48 BJ

MARTEL NO. 60404 58 CLIENT SAMPLE IDENTIFICATION MMES-58-FC [sink--Classroom 104] Sample Date/Time 10/16/2021 08:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.91	ug/l*	EPA .200.8	2	01/13/2022 14:53 BJ

MARTEL NO. 60404 59 CLIENT SAMPLE IDENTIFICATION MMES-59-DB [bubbler--Classroom 104] Sample Date/Time 10/16/2021 08:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.50	ug/l	EPA .200.8	2	01/13/2022 15:03 BJ

MARTEL NO. 60404 60 CLIENT SAMPLE IDENTIFICATION MMES-60-FC [sink--Classroom 105] Sample Date/Time 10/16/2021 08:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.80	ug/l*	EPA .200.8	2	01/14/2022 08:51 BJ



MARTEL NO. 60404 61 CLIENT SAMPLE IDENTIFICATION MMES-61-DB [bubbler--Classroom 105] Sample Date/Time 10/16/2021 08:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.97	ug/l	EPA .200.8	2	01/13/2022 15:08 BJ

MARTEL NO. 60404 66 CLIENT SAMPLE IDENTIFICATION MMES-66-FC [sink--Classroom 106] Sample Date/Time 10/16/2021 08:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.53	ug/l*	EPA .200.8	2	01/13/2022 15:10 BJ

MARTEL NO. 60404 67 CLIENT SAMPLE IDENTIFICATION MMES-67-DB [bubbler--Classroom 106] Sample Date/Time 10/16/2021 08:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.41	ug/l	EPA .200.8	2	01/13/2022 15:13 BJ

MARTEL NO. 60404 68 CLIENT SAMPLE IDENTIFICATION MMES-68-FC [sink--203 activity Room] Sample Date/Time 10/16/2021 08:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:15 BJ

MARTEL NO. 60404 69 CLIENT SAMPLE IDENTIFICATION MMES-69-FC [sink--Classroom 210 - K] Sample Date/Time 10/16/2021 08:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:18 BJ

MARTEL NO. 60404 70 CLIENT SAMPLE IDENTIFICATION MMES-70-DB [bubbler--Classroom 210 - K] Sample Date/Time 10/16/2021 08:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.11	ug/l	EPA .200.8	2	01/14/2022 08:54 BJ

MARTEL NO. 60404 71 CLIENT SAMPLE IDENTIFICATION MMES-71-FC [sink--Classroom 209 - K] Sample Date/Time 10/16/2021 08:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:20 BJ

MARTEL NO. 60404 72 CLIENT SAMPLE IDENTIFICATION MMES-72-DB [bubbler--Classroom 209 - K] Sample Date/Time 10/16/2021 08:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:23 BJ



MARTEL NO. 60404 73 CLIENT SAMPLE IDENTIFICATION MMES-73-FC [sink--Classroom 204 - K] Sample Date/Time 10/16/2021 08:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:30 BJ

MARTEL NO. 60404 74 CLIENT SAMPLE IDENTIFICATION MMES-74-DB [bubbler--Classroom 204 - K] Sample Date/Time 10/16/2021 08:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:37 BJ

MARTEL NO. 60404 75 CLIENT SAMPLE IDENTIFICATION MMES-75-FC [sink--Classroom 206 - K] Sample Date/Time 10/16/2021 08:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:40 BJ

MARTEL NO. 60404 76 CLIENT SAMPLE IDENTIFICATION MMES-76-DB [bubbler--Classroom 206 - K] Sample Date/Time 10/16/2021 08:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:42 BJ

MARTEL NO. 60404 77 CLIENT SAMPLE IDENTIFICATION MMES-77-FC [sink--CR 207 (Sp-Ed) Transition] Sample Date/Time 10/16/2021 08:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:45 BJ

MARTEL NO. 60404 78 CLIENT SAMPLE IDENTIFICATION MMES-78-DB [bubbler--CR 207 (Sp-Ed) Transition] Sample Date/Time 10/16/2021 08:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:47 BJ

MARTEL NO. 60404 79 CLIENT SAMPLE IDENTIFICATION MMES-79-FC [sink--CR 103 (Sp-Ed) SOAR] Sample Date/Time 10/16/2021 08:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.87	ug/l*	EPA .200.8	2	01/13/2022 15:50 BJ

MARTEL NO. 60404 80 CLIENT SAMPLE IDENTIFICATION MMES-80-FC [sink--Classroom 102 - Pre-K] Sample Date/Time 10/16/2021 08:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:52 BJ



# Certificate of Analysis

MARTEL NO. 60404 81 CLIENT SAMPLE IDENTIFICATION MMES-81-DB [bubbler--Classroom 102 - Pre-K] Sample Date/Time 10/16/2021 08:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.95	ug/l	EPA .200.8	2	01/14/2022 08:56 BJ

MARTEL NO. 60404 84 CLIENT SAMPLE IDENTIFICATION MMES-84-FC [sink--Classroom 101] Sample Date/Time 10/16/2021 08:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 15:55 BJ

MARTEL NO. 60404 85 CLIENT SAMPLE IDENTIFICATION MMES-85-DB [bubbler--Classroom 101] Sample Date/Time 10/16/2021 08:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 16:04 BJ

MARTEL NO. 60404 86 CLIENT SAMPLE IDENTIFICATION MMES-86-FC [sink--Classroom 100 - Pre-K] Sample Date/Time 10/16/2021 08:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.87	ug/l*	EPA .200.8	2	01/13/2022 16:09 BJ

MARTEL NO. 60404 87 CLIENT SAMPLE IDENTIFICATION MMES-87-DB [bubbler--Classroom 100 - Pre-K] Sample Date/Time 10/16/2021 08:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.05	ug/l	EPA .200.8	2	01/13/2022 16:12 BJ

MARTEL NO. 60404 88 CLIENT SAMPLE IDENTIFICATION MMES-88-FC [sink--teacher lounge] Sample Date/Time 10/16/2021 07:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 16:14 BJ

MARTEL NO. 60404 89 CLIENT SAMPLE IDENTIFICATION MMES-89-FC [cold water dispenser--teacher lounge ] Sample Date/Time 10/16/2021 07:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 16:17 BJ

MARTEL NO. 60404 90 CLIENT SAMPLE IDENTIFICATION MMES-90-DH [hot water insta hot--teacher lounge] Sample Date/Time 10/16/2021 07:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 16:19 BJ





MARTEL NO. 60404 91 CLIENT SAMPLE IDENTIFICATION MMES-91-BU [Bottle Filler--Hallway] Sample Date/Time 10/16/2021 07:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 16:22 BJ

MARTEL NO. 60404 92 CLIENT SAMPLE IDENTIFICATION MMES-92-BU [Bottle Filler--Hallway] Sample Date/Time 10/16/2021 07:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 16:24 BJ

MARTEL NO. 60404 93 CLIENT SAMPLE IDENTIFICATION MMES-93-BU [Bottle Filler--Hallway] Sample Date/Time 10/16/2021 07:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 16:27 BJ

MARTEL NO. 60404 94 CLIENT SAMPLE IDENTIFICATION MMES-94-BU [Bottle Filler--Hallway] Sample Date/Time 10/16/2021 08:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/13/2022 16:29 BJ

## MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

### Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 10/16/21 743 End Date/Time: 10/16/21 818

Sampler/Relinquished By: [Signature] Received at Martel by: [Signature] Date/Time: 10/16/21 1030

20 Mary H. Matula Elementary School PSC #08.032  
6025 Radio Station Road LaPlata, MD 20646

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

Martel NO: **60404**

Martel #	Sample #	Location ID #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)</small>	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush	
							Flush Date	Sample Time
1	1	MMES-1-FC	sink on left	FC	kitchen 2 comp	C	/	746
2	2	MMES-2-FC	sink on right	FC	kitchen 2 comp	C	/	↓
3	3	MMES-3-FC	island sink - next to restroom	FC	kitchen sink	C	/	↓
4	4	MMES-4-FC	island sink	FC	kitchen sink	C	/	747
5	5	MMES-5-FC	sink	FC	kitchen sink	C	/	↓
6	6	MMES-6-IM	Ice Machine	IM	kitchen sink	C	/	↓
7	7	MMES-7-DC	water fountain	DC	kitchen	C	/	↓
8	8	MMES-8-DC	water fountain	DC	hallway	C	/	745
9	9	MMES-9-DC	water fountain	DC	hallway	C	/	750
10	12	MMES-12-FC	sink	FC	CR 132 (Sp-Ed) SOAR	C	/	751
11	13	MMES-13-DB	bubbler	DB	CR 132 (Sp-Ed) SOAR	C	/	↓
12	22	MMES-22-FC	sink	FC	CR 118A (Sp-Ed) Pull Out	C	/	752
13	23	MMES-23-DB	bubbler	DB	CR 118A (Sp-Ed) Pull Out	C	/	↓
14	28	MMES-28-FC	sink	FC	Classroom 129	C	/	754
15	29	MMES-29-DB	bubbler	DB	Classroom 129	C	/	↓
16	30	MMES-30-FC	sink	FC	Classroom 128	C	/	780
17	31	MMES-31-DB	bubbler	DB	Classroom 128	C	/	↓
18	34	MMES-34-FC	sink	FC	CR 121 (Sp-Ed) EA	C	/	758
19	35	MMES-35-DB	bubbler	DB	CR 121 (Sp-Ed) EA	C	/	↓
20	38	MMES-38-FC	sink	FC	Classroom 126	C	/	0800
21	39	MMES-39-DB	bubbler	DB	Classroom 126	C	/	↓
22	40	MMES-40-FC	sink	FC	CR 122 (Sp-Ed) EA	C	/	801
23	41	MMES-41-DB	bubbler	DB	CR 122 (Sp-Ed) EA	C	/	↓
24	48	MMES-48-DC	water fountain	DC	hallway	C	/	757
25	51	MMES-51-DC	water fountain	DC	hallway	C	/	803

20 Mary H. Matula Elementary School PSC #08.032

6025 Radio Station Road LaPlata, MD 20646

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush 60404

26	54	MMES-54-FC	sink	FC	Classroom 109	C	/	814	
27	55	MMES-55-DB	bubbler	DB	Classroom 109	C	/	↓	
28	56	MMES-56-FC	sink	FC	CR 103 (Sp-Ed) SOAR	C	/	815	
29	57	MMES-57-DB	bubbler	DB	CR 103 (Sp-Ed) SOAR	C	/	↓	
30	58	MMES-58-FC	sink	FC	Classroom 104	C	/	812	
31	59	MMES-59-DB	bubbler	DB	Classroom 104	C	/	↓	
32	60	MMES-60-FC	sink	FC	Classroom 105	C	/	811	
33	61	MMES-61-DB	bubbler	DB	Classroom 105	C	/	↓	
34	66	MMES-66-FC	sink	FC	Classroom 106	C	/	810	
35	67	MMES-67-DB	bubbler	DB	Classroom 106	C	/	↓	
36	68	MMES-68-FC	sink	FC	203 activity Room	C	/	809	
37	69	MMES-69-FC	sink	FC	Classroom 210 - K	C	/	805	
38	70	MMES-70-DB	bubbler	DB	Classroom 210 - K	C	/	↓	
39	71	MMES-71-FC	sink	FC	Classroom 209 - K	C	/	806	
40	72	MMES-72-DB	bubbler	DB	Classroom 209 - K	C	/	↓	
41	73	MMES-73-FC	sink	FC	Classroom 204 - K	C	/	809	
42	74	MMES-74-DB	bubbler	DB	Classroom 204 - K	C	/	↓	
43	75	MMES-75-FC	sink	FC	Classroom 206 - K	C	/	808	
44	76	MMES-76-DB	bubbler	DB	Classroom 206 - K	C	/	↓	
45	77	MMES-77-FC	sink	FC	CR 207 (Sp-Ed) Transition	C	/	807	
46	78	MMES-78-DB	bubbler	DB	CR 207 (Sp-Ed) Transition	C	/	↓	
47	79	MMES-79-FC	sink	FC	CR 103 (Sp-Ed) SOAR	C	/	815	
48	80	MMES-80-FC	sink	FC	Classroom 102 - Pre-K	C	/	816	
49	81	MMES-81-DB	bubbler	DB	Classroom 102 - Pre-K	C	/	↓	
50	84	MMES-84-FC	sink	FC	Classroom 101	C	/	817	
51	85	MMES-85-DB	bubbler	DB	Classroom 101	C	/	↓	
52	86	MMES-86-FC	sink	FC	Classroom 100 - Pre-K	C	/	818	
53	87	MMES-87-DB	bubbler	DB	Classroom 100 - Pre-K	C	/	↓	
54	88	MMES-88-FC	sink	FC	teacher lounge	C	/	743	
55	89	MMES-89-FC	cold water dispenser	FC	teacher lounge	C	/	↓	
56	90	MMES-90-DH	hot water insta hot	DH	teacher lounge	C	/	↓	
57	91	MMES-91-BU	Bottle Filler	BU	Hallway	C	/	745	
58	92	MMES-92-BU	Bottle Filler	BU	Hallway	C	/	750	

20 Mary H. Matula Elementary School PSC #08.032

6025 Radio Station Road LaPlata, MD 20646

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN  
SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush

60404

59	93	MMES-93-BU	Bottle Filler	BU	Hallway	C	<del>/</del>	757
60	94	MMES-94-BU	Bottle Filler	BU	Hallway	C	/	803

P 12