

ADDENDUM NO. 2
JANUARY 19, 2022

Site Accessibility Improvements at ISD

Opening Date: January 25, 2022


Opening Time: 10:00 a.m.

Bid Number: 2349-21

This Addendum No. 2 is being issued to clarify questions and inquiries asked at the mandatory walk through that took place on Tuesday, January 11, 2022:

1. Ramp is to be 6'-0" wide, town minimum standard.
2. No additional handrails will be required at this time.
3. Flatness of the ramp will be achieved at the intersections and curved areas.
4. Be aware of the underground utilities under the wall footings.

All project requirements, except for those that are specifically added or modified by this Addendum shall remain in full effect.



Eugene H. Watts

END OF ADDENDUM NO. 2