



Charles County Public Schools
P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646
Attention:

Monday, January 24, 2022
Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 60418.
Samples flushed by Martel on November 5, sampled by Martel on November 6, 2021.
Project Identification: MD HB 270
School: J.C. Parks Elementary School PSC #08.030

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 60418 1 CLIENT SAMPLE IDENTIFICATION JCPES-1-FC [sink--teachers lounge] Sample Date/Time 11/06/2021 07:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.50	ug/l	EPA .200.8	2	01/17/2022 13:38 BJ

MARTEL NO. 60418 2 CLIENT SAMPLE IDENTIFICATION JCPES-2-DC [water fountain--corridor] Sample Date/Time 11/06/2021 07:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 13:51 BJ

MARTEL NO. 60418 3 CLIENT SAMPLE IDENTIFICATION JCPES-3-FC [sink--nurse office] Sample Date/Time 11/06/2021 07:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.19	ug/l	EPA .200.8	2	01/17/2022 13:53 BJ

MARTEL NO. 60418 4 CLIENT SAMPLE IDENTIFICATION JCPES-4-FC [Sink - Left fixture--Kitchen - Left Fixture on] Sample Date/Time 11/06/2021 07:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.21	ug/l	EPA .200.8	2	01/17/2022 13:55 BJ

MARTEL NO. 60418 5 CLIENT SAMPLE IDENTIFICATION JCPES-5-FC [Sink - Right fixture--Kitchen - Right Fixture] Sample Date/Time 11/06/2021 07:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 13:58 BJ

MARTEL NO. 60418 6 CLIENT SAMPLE IDENTIFICATION JCPES-6-FC [island sink next to ice maker--kitchen] Sample Date/Time 11/06/2021 07:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.60	ug/l	EPA .200.8	2	01/17/2022 14:00 BJ

MARTEL NO. 60418 7 CLIENT SAMPLE IDENTIFICATION JCPES-7-IM [Ice Machine --kitchen] Sample Date/Time 11/06/2021 07:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:03 BJ

MARTEL NO. 60418 8 CLIENT SAMPLE IDENTIFICATION JCPES-8-FC [sink--kitchen 2 comp sink] Sample Date/Time 11/06/2021 07:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.57	ug/l	EPA .200.8	2	01/17/2022 14:05 BJ



MARTEL NO. 60418 9 CLIENT SAMPLE IDENTIFICATION JCPES-9-FC [Island sink near dry storage--Kitchen] Sample Date/Time 11/06/2021 07:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:08 BJ

MARTEL NO. 60418 12 CLIENT SAMPLE IDENTIFICATION JCPES-12-DC [water fountain - Left--corridor] Sample Date/Time 11/06/2021 07:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:10 BJ

MARTEL NO. 60418 13 CLIENT SAMPLE IDENTIFICATION JCPES-13-DC [water fountain - Right--corridor] Sample Date/Time 11/06/2021 07:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:20 BJ

MARTEL NO. 60418 14 CLIENT SAMPLE IDENTIFICATION JCPES-14-DC [water fountain--corridor] Sample Date/Time 11/06/2021 07:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:25 BJ

MARTEL NO. 60418 15 CLIENT SAMPLE IDENTIFICATION JCPES-15-FC [sink--Classroom 89] Sample Date/Time 11/06/2021 07:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.76	ug/l*	EPA .200.8	2	01/17/2022 14:28 BJ

MARTEL NO. 60418 16 CLIENT SAMPLE IDENTIFICATION JCPES-16-DB [bubbler--Classroom 89] Sample Date/Time 11/06/2021 07:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:30 BJ

MARTEL NO. 60418 17 CLIENT SAMPLE IDENTIFICATION JCPES-17-FC [sink--Classroom 88] Sample Date/Time 11/06/2021 07:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:33 BJ

MARTEL NO. 60418 18 CLIENT SAMPLE IDENTIFICATION JCPES-18-DB [bubbler--Classroom 88] Sample Date/Time 11/06/2021 07:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:35 BJ



MARTEL NO. 60418 19 CLIENT SAMPLE IDENTIFICATION JCPES-19-FC [sink--Classroom 97] Sample Date/Time 11/06/2021 07:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:38 BJ

MARTEL NO. 60418 20 CLIENT SAMPLE IDENTIFICATION JCPES-20-DB [bubbler--Classroom 97] Sample Date/Time 11/06/2021 07:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:40 BJ

MARTEL NO. 60418 21 CLIENT SAMPLE IDENTIFICATION JCPES-21-FC [sink--Classroom 90] Sample Date/Time 11/06/2021 07:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	24.8	ug/l*	EPA .200.8	2	01/17/2022 14:43 BJ

MARTEL NO. 60418 22 CLIENT SAMPLE IDENTIFICATION JCPES-22-DB [bubbler--Classroom 90] Sample Date/Time 11/06/2021 07:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 14:45 BJ

MARTEL NO. 60418 23 CLIENT SAMPLE IDENTIFICATION JCPES-23-FC [sink--CR 96 (Sp-Ed) Life Skills] Sample Date/Time 11/06/2021 07:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.50	ug/l	EPA .200.8	2	01/17/2022 14:53 BJ

MARTEL NO. 60418 24 CLIENT SAMPLE IDENTIFICATION JCPES-24-DB [bubbler--CR 96 (Sp-Ed) Life Skills] Sample Date/Time 11/06/2021 07:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:00 BJ

MARTEL NO. 60418 25 CLIENT SAMPLE IDENTIFICATION JCPES-25-FC [sink--Classroom 95] Sample Date/Time 11/06/2021 07:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	16.4	ug/l*	EPA .200.8	2	01/17/2022 15:03 BJ

MARTEL NO. 60418 26 CLIENT SAMPLE IDENTIFICATION JCPES-26-DB [bubbler--Classroom 95] Sample Date/Time 11/06/2021 07:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:05 BJ



MARTEL NO. 60418 29 CLIENT SAMPLE IDENTIFICATION JCPES-29-DC [water fountain--corridor] Sample Date/Time 11/06/2021 07:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:08 BJ

MARTEL NO. 60418 34 CLIENT SAMPLE IDENTIFICATION JCPES-34-DC [water fountain--corridor] Sample Date/Time 11/06/2021 07:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:10 BJ

MARTEL NO. 60418 37 CLIENT SAMPLE IDENTIFICATION JCPES-37-FC [sink--Classroom 56 - K] Sample Date/Time 11/06/2021 07:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.17	ug/l*	EPA .200.8	2	01/17/2022 15:13 BJ

MARTEL NO. 60418 38 CLIENT SAMPLE IDENTIFICATION JCPES-38-DB [bubbler--Classroom 56 - K] Sample Date/Time 11/06/2021 07:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:15 BJ

MARTEL NO. 60418 39 CLIENT SAMPLE IDENTIFICATION JCPES-39-FC [sink - Right--Classroom 55 - K] Sample Date/Time 11/06/2021 07:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.87	ug/l	EPA .200.8	2	01/17/2022 15:17 BJ

MARTEL NO. 60418 40 CLIENT SAMPLE IDENTIFICATION JCPES-40-DB [bubbler--Classroom 55 - K] Sample Date/Time 11/06/2021 07:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:20 BJ

MARTEL NO. 60418 41 CLIENT SAMPLE IDENTIFICATION JCPES-41-FC [sink - Left--Classroom 55 - K] Sample Date/Time 11/06/2021 07:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:30 BJ

MARTEL NO. 60418 42 CLIENT SAMPLE IDENTIFICATION JCPES-42-FC [sink--Classroom 53 - K] Sample Date/Time 11/06/2021 07:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:35 BJ



MARTEL NO. 60418 43 CLIENT SAMPLE IDENTIFICATION JCPES-43-DB [bubbler--Classroom 53 - K] Sample Date/Time 11/06/2021 07:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:37 BJ

MARTEL NO. 60418 44 CLIENT SAMPLE IDENTIFICATION JCPES-44-FC [sink - Left--Classroom 54 - K] Sample Date/Time 11/06/2021 07:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:40 BJ

MARTEL NO. 60418 45 CLIENT SAMPLE IDENTIFICATION JCPES-45-DB [bubbler--Classroom 54 - K] Sample Date/Time 11/06/2021 07:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:42 BJ

MARTEL NO. 60418 46 CLIENT SAMPLE IDENTIFICATION JCPES-46-FC [sink - Right--Classroom 54 - K] Sample Date/Time 11/06/2021 07:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.45	ug/l	EPA .200.8	2	01/17/2022 15:45 BJ

MARTEL NO. 60418 47 CLIENT SAMPLE IDENTIFICATION JCPES-47-DC [water fountain--corridor] Sample Date/Time 11/06/2021 07:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:47 BJ

MARTEL NO. 60418 50 CLIENT SAMPLE IDENTIFICATION JCPES-50-FC [sink--Classroom 48 - Pre-K] Sample Date/Time 11/06/2021 07:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:50 BJ

MARTEL NO. 60418 51 CLIENT SAMPLE IDENTIFICATION JCPES-51-DB [bubbler--Classroom 48 - Pre-K] Sample Date/Time 11/06/2021 07:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:52 BJ

MARTEL NO. 60418 52 CLIENT SAMPLE IDENTIFICATION JCPES-52-DC [water fountain--corridor] left Sample Date/Time 11/06/2021 07:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 15:54 BJ



Certificate of Analysis

MARTEL NO. 60418 53 CLIENT SAMPLE IDENTIFICATION JCPES-53-DC [water fountain--corridor] right Sample Date/Time 11/06/2021 07:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:02 BJ

MARTEL NO. 60418 58 CLIENT SAMPLE IDENTIFICATION JCPES-58-FC [sink--Classroom 47] Sample Date/Time 11/06/2021 07:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:09 BJ

MARTEL NO. 60418 59 CLIENT SAMPLE IDENTIFICATION JCPES-59-DB [Bubbler--Classroom 47] Sample Date/Time 11/06/2021 07:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:12 BJ

MARTEL NO. 60418 60 CLIENT SAMPLE IDENTIFICATION JCPES-60-FC [sink--Classroom 51] Sample Date/Time 11/06/2021 07:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.00	ug/l*	EPA .200.8	2	01/17/2022 16:14 BJ

MARTEL NO. 60418 61 CLIENT SAMPLE IDENTIFICATION JCPES-61-DB [Bubbler--Classroom 51] Sample Date/Time 11/06/2021 07:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:17 BJ

MARTEL NO. 60418 62 CLIENT SAMPLE IDENTIFICATION JCPES-62-FC [sink - Next to restroom--Classroom 32 - Pre-K] Sample Date/Time 11/06/2021 07:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:19 BJ

MARTEL NO. 60418 63 CLIENT SAMPLE IDENTIFICATION JCPES-63-DB [Bubbler--Classroom 32 - Pre-K] Sample Date/Time 11/06/2021 07:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:22 BJ

MARTEL NO. 60418 64 CLIENT SAMPLE IDENTIFICATION JCPES-64-FC [sink - Next to stove--Classroom 32 - Pre-K] Sample Date/Time 11/06/2021 07:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.22	ug/l*	EPA .200.8	2	01/17/2022 16:24 BJ



MARTEL NO. 60418 65 CLIENT SAMPLE IDENTIFICATION JCPES-65-FC [sink--Classroom 31] Sample Date/Time 11/06/2021 07:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	84.8	ug/l*	EPA .200.8	2	01/17/2022 16:27 BJ

MARTEL NO. 60418 66 CLIENT SAMPLE IDENTIFICATION JCPES-66-DB [Bubbler--Classroom 31] Sample Date/Time 11/06/2021 07:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:29 BJ

MARTEL NO. 60418 67 CLIENT SAMPLE IDENTIFICATION JCPES-67-FC [sink--Classroom 30] Sample Date/Time 11/06/2021 07:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.86	ug/l*	EPA .200.8	2	01/17/2022 16:39 BJ

MARTEL NO. 60418 68 CLIENT SAMPLE IDENTIFICATION JCPES-68-DB [Bubbler--Classroom 30] Sample Date/Time 11/06/2021 07:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:44 BJ

MARTEL NO. 60418 69 CLIENT SAMPLE IDENTIFICATION JCPES-69-FC [sink--Classroom 29] Sample Date/Time 11/06/2021 07:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	19.9	ug/l*	EPA .200.8	2	01/17/2022 16:46 BJ

MARTEL NO. 60418 70 CLIENT SAMPLE IDENTIFICATION JCPES-70-DB [Bubbler--Classroom 29] Sample Date/Time 11/06/2021 07:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:49 BJ

MARTEL NO. 60418 71 CLIENT SAMPLE IDENTIFICATION JCPES-71-FC [sink--Classroom 39] Sample Date/Time 11/06/2021 07:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.39	ug/l*	EPA .200.8	2	01/17/2022 16:51 BJ

MARTEL NO. 60418 72 CLIENT SAMPLE IDENTIFICATION JCPES-72-DB [Bubbler--Classroom 39] Sample Date/Time 11/06/2021 07:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:54 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
60418 75	JCPES-75-FC [sink--Classroom 27]					11/06/2021 07:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:56 BJ	
60418 76	JCPES-76-DB [Bubbler--Classroom 27]					11/06/2021 07:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 16:59 BJ	
60418 77	JCPES-77-FC [sink--Classroom 26]					11/06/2021 07:43
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	7.05	ug/l*	EPA .200.8	2	01/17/2022 17:01 BJ	
60418 78	JCPES-78-DB [Bubbler--Classroom 26]					11/06/2021 07:43
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/17/2022 17:04 BJ	
60418 81	JCPES-81-FC [sink--CR 24 (Sp-Ed) SOAR]					11/06/2021 07:44
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 14:30 BJ	
60418 82	JCPES-82-DB [Bubbler--CR 24 (Sp-Ed) SOAR]					11/06/2021 07:44
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 14:38 BJ	
60418 83	JCPES-83-DC [water fountain - Left--corridor]					11/06/2021 07:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 14:40 BJ	
60418 84	JCPES-84-DC [water fountain - Right--corridor]					11/06/2021 07:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 14:43 BJ	



MARTEL NO. 60418 88 CLIENT SAMPLE IDENTIFICATION JCPES-88-FC [Sink--CR 100 (Sp-Ed) Pull Out] Sample Date/Time 11/06/2021 07:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 14:45 BJ

MARTEL NO. 60418 89 CLIENT SAMPLE IDENTIFICATION JCPES-89-BU [Bottle Filler--Corridor] Sample Date/Time 11/06/2021 07:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 14:48 BJ

MARTEL NO. 60418 90 CLIENT SAMPLE IDENTIFICATION JCPES-90-BU [Bottle Filler--Corridor] Sample Date/Time 11/06/2021 07:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 14:50 BJ

MARTEL NO. 60418 91 CLIENT SAMPLE IDENTIFICATION JCPES-91-BU [Bottle Filler--Corridor] Sample Date/Time 11/06/2021 07:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 14:53 BJ

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 11/6/21 706 End Date/Time: 11/6/21 747

Sampler/Relinquished By: [Signature] Received at Martel by: [Signature] Date/Time: 11/6/21 [Signature]

13 J.C. Parks Elementary School PSC #08.030
3505 Livingston Road Indian Head, MD 20640

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Flush 11/5/21 Martel NO: **60418**

Martel #	Sample #	Location ID #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)</small>	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush Date	Sample Time
1	1	JCPES-1-FC	sink	FC	teachers lounge	C	✓	707
2	2	JCPES-2-DC	water fountain	DC	corridor	C	✓	708
3	3	JCPES-3-FC	sink	FC	nurse office	C	✓	705
4	4	JCPES-4-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	✓	711
5	5	JCPES-5-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	✓	↓
6	6	JCPES-6-FC	island sink next to ice maker	FC	kitchen	C	✓	712
7	7	JCPES-7-IM	Ice Machine	IM	kitchen	C	✓	↓
8	8	JCPES-8-FC	sink	FC	kitchen 2 comp sink	C	✓	↓
9	9	JCPES-9-FC	Island sink near dry storage	FC	Kitchen	C	✓	713
10	12	JCPES-12-DC	water fountain - Left	DC	corridor	C	✓	714
11	13	JCPES-13-DC	water fountain - Right	DC	corridor	C	✓	↓
12	14	JCPES-14-DC	water fountain	DC	corridor	C	✓	715
13	15	JCPES-15-FC	sink	FC	Classroom 89	C	✓	716
14	16	JCPES-16-DB	bubbler	DB	Classroom 89	C	✓	↓
15	17	JCPES-17-FC	sink	FC	Classroom 88	C	✓	723
16	18	JCPES-18-DB	bubbler	DB	Classroom 88	C	✓	↓
17	19	JCPES-19-FC	sink	FC	Classroom 97	C	✓	717
18	20	JCPES-20-DB	bubbler	DB	Classroom 97	C	✓	↓
19	21	JCPES-21-FC	sink	FC	Classroom 90	C	✓	719
20	22	JCPES-22-DB	bubbler	DB	Classroom 90	C	✓	↓
21	23	JCPES-23-FC	sink	FC	CR 96 (Sp-Ed) Life Skills	C	✓	720
22	24	JCPES-24-DB	bubbler	DB	CR 96 (Sp-Ed) Life Skills	C	✓	↓
23	25	JCPES-25-FC	sink	FC	Classroom 95	C	✓	721
24	26	JCPES-26-DB	bubbler	DB	Classroom 95	C	✓	↓
25	29	JCPES-29-DC	water fountain	DC	corridor	C	✓	722

P 11

13 J.C. Parks Elementary School PSC #08.030

3505 Livingston Road Indian Head, MD 20640

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush

60418

26	34	JCPES-34-DC	water fountain	DC	corridor	C	✓	724	
27	37	JCPES-37-FC	sink	FC	Classroom 56 - K	C	✓	726	
28	38	JCPES-38-DB	bubbler	DB	Classroom 56 - K	C	✓	↓	
29	39	JCPES-39-FC	sink - Right	FC	Classroom 55 - K	C	✓	727	
30	40	JCPES-40-DB	bubbler	DB	Classroom 55 - K	C	✓	↓	
31	41	JCPES-41-FC	sink - Left	FC	Classroom 55 - K	C	✓	↓	
32	42	JCPES-42-FC	sink	FC	Classroom 53 - K	C	✓	62 729	
33	43	JCPES-43-FC	sink Bubbler	FC	Classroom 53 - K	C	✓	↓	
34	44	JCPES-44-FC	sink - Left	FC	Classroom 54 - K	C	✓	730	
35	45	JCPES-45-DB	bubbler	DB	Classroom 54 - K	C	✓	↓	
36	46	JCPES-46-FC	sink - Right	FC	Classroom 54 - K	C	✓	↓	
37	47	JCPES-47-DC	water fountain	DC	corridor	C	✓	731	
38	50	JCPES-50-FC	sink	FC	Classroom 48 - Pre-K	C	✓	733	
39	51	JCPES-51-DB	bubbler	DB	Classroom 48 - Pre-K	C	✓	↓	
40	52	JCPES-52-DC	water fountain L	DC	corridor	C	✓	↓	
41	53	JCPES-53-DC	water fountain R	DC	corridor	C	✓	↓	
42	58	JCPES-58-FC	sink	FC	Classroom 47	C	✓	746	
43	59	JCPES-59-DB	Bubbler	DB	Classroom 47	C	✓	↓	
44	60	JCPES-60-FC	sink	FC	Classroom 51	C	✓	747	
45	61	JCPES-61-DB	Bubbler	DB	Classroom 51	C	✓	↓	
46	62	JCPES-62-FC	sink - Next to restroom	FC	Classroom 32 - Pre-K	C	✓	734	
47	63	JCPES-63-DB	Bubbler	DB	Classroom 32 - Pre-K	C	✓	↓	
48	64	JCPES-64-FC	sink - Next to stove	FC	Classroom 32 - Pre-K	C	✓	↓	
49	65	JCPES-65-FC	sink	FC	Classroom 31	C	✓	736	
50	66	JCPES-66-DB	Bubbler	DB	Classroom 31	C	✓	↓	
51	67	JCPES-67-FC	sink	FC	Classroom 30	C	✓	137	
52	68	JCPES-68-DB	Bubbler	DB	Classroom 30	C	✓	↓	
53	69	JCPES-69-FC	sink	FC	Classroom 29	C	✓	740	
54	70	JCPES-70-DB	Bubbler	DB	Classroom 29	C	✓	↓	
55	71	JCPES-71-FC	sink	FC	Classroom 39	C	✓	741	
56	72	JCPES-72-DB	Bubbler	DB	Classroom 39	C	✓	↓	
57	75	JCPES-75-FC	sink	FC	Classroom 27	C	✓	742	
58	76	JCPES-76-DB	Bubbler	DB	Classroom 27	C	✓	↓	

13 J.C. Parks Elementary School PSC #08.030
3505 Livingston Road Indian Head, MD 20640

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN
SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:
60418

							Flush	
59	77	JCPES-77-FC	sink	FC	Classroom 26	C	✓	743
60	78	JCPES-78-DB	Bubbler	DB	Classroom 26	C	✓	↓
61	81	JCPES-81-FC	sink	FC	CR 24 (Sp-Ed) SOAR	C	✓	744
62	82	JCPES-82-DB	Bubbler	DB	CR 24 (Sp-Ed) SOAR	C	✓	↓
63	83	JCPES-83-DC	water fountain - Left	DC	corridor	C	✓	745
64	84	JCPES-84-DC	water fountain - Right	DC	corridor	C	✓	↓
65	88	JCPES-88-FC	Sink	FC	CR 100 (Sp-Ed) Pull Out	C	✓	715
66	89	JCPES-89-BU	Bottle Filler	BU	Corridor	C	✓	708
67	90	JCPES-90-BU	Bottle Filler	BU	Corridor	C	✓	715
68	91	JCPES-91-BU	Bottle Filler	BU	Corridor	C	✓	724