



## **Environmental Safety Lead in Drinking Water**

- In June of 2018, Act 39 was passed and placed in to Pennsylvania School Code. It recommends that all public schools test for lead in drinking water. Schools were to follow the EPA recommended testing procedures and report and implement a plan if any levels exceeded the primary drinking water standard of 15 parts per billion (ppb). Any Schools choosing not to test are required to discuss lead in water issues at a public meeting.
- Central York was notified of Act 39 and consulted with ALS Environmental. Testing was completed in all Central York School District facilities in January 2019.
- Copper in water is required to be tested in well sourced drinking water. Central York receives all drinking water from York Water, who monitors levels of copper.
- Results are attached. All tests were within the acceptable range.
- No additional testing is recommended at this time.

School	Samples	No				
		Detection	0.002 - 0.0059	0.006- 0.010	0.011 - 0.012	0.013 - 0.015
ESC	4	4	0	0	0	0
High School	57	51	6	0	0	0
Middle School	41	25	11	2	2	1
North Hills	18	14	4	0	0	0
Sinking Springs	20	19	1	0	0	0
Hayshire	16	15	1	0	0	0
Stony Brook	18	16	1	1	0	0
Roundtown	18	16	1	0	1	0
Farm House	1	1	0	0	0	0
<b>Totals</b>	<b>193</b>	<b>161</b>	<b>25</b>	<b>3</b>	<b>3</b>	<b>1</b>

Measured in mg/L

Acceptable Range 0.001 - 0.015

0.016+ would need additional testing and remediation