



Charles County Public Schools
P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646
Attention:

Saturday, January 29, 2022
Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 60424.
Samples flushed by Martel on November 16, 2021, sampled by Martel on November 17, 2021.
Project Identification: MD HB 270
School: 16 Dr. Thomas L. Higdon ES PSC #08.027

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 60424 1 CLIENT SAMPLE IDENTIFICATION HES-1-DC [water fountain on left--main corridor] Sample Date/Time 11/17/2021 06:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 14:16 BJ

MARTEL NO. 60424 2 CLIENT SAMPLE IDENTIFICATION HES-2-DC [water fountain on right--main corridor] Sample Date/Time 11/17/2021 06:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 14:29 BJ

MARTEL NO. 60424 3 CLIENT SAMPLE IDENTIFICATION HES-3-FC [teacher lounge sink--teacher lounge CR 125] Sample Date/Time 11/17/2021 06:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 14:31 BJ

MARTEL NO. 60424 4 CLIENT SAMPLE IDENTIFICATION HES-4-DB [bubbler--teacher lounge CR 125] Sample Date/Time 11/17/2021 06:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.0	ug/l*	EPA .200.8	2	01/24/2022 14:34 BJ

MARTEL NO. 60424 5 CLIENT SAMPLE IDENTIFICATION HES-5-DC [water fountain--corridor next to cr 131] Sample Date/Time 11/17/2021 06:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 14:36 BJ

MARTEL NO. 60424 6 CLIENT SAMPLE IDENTIFICATION HES-6-FC [sink --cr 131] Sample Date/Time 11/17/2021 06:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.85	ug/l	EPA .200.8	2	01/24/2022 14:39 BJ

MARTEL NO. 60424 7 CLIENT SAMPLE IDENTIFICATION HES-7-DB [bubbler --cr 131] Sample Date/Time 11/17/2021 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	not	working	EPA .200.8	2	/ /

MARTEL NO. 60424 8 CLIENT SAMPLE IDENTIFICATION HES-8-FC [sink --cr 132] Sample Date/Time 11/17/2021 06:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.35	ug/l	EPA .200.8	2	01/24/2022 14:41 BJ



MARTEL NO. 60424 9 CLIENT SAMPLE IDENTIFICATION HES-9-DB [bubbler --cr 132] Sample Date/Time 11/17/2021 06:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 14:44 BJ

MARTEL NO. 60424 10 CLIENT SAMPLE IDENTIFICATION HES-10-FC [sink --cr 135] Sample Date/Time 11/17/2021 06:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.95	ug/l*	EPA .200.8	2	01/24/2022 14:46 BJ

MARTEL NO. 60424 11 CLIENT SAMPLE IDENTIFICATION HES-11-DB [bubbler --cr 135] Sample Date/Time 11/17/2021 06:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 14:56 BJ

MARTEL NO. 60424 12 CLIENT SAMPLE IDENTIFICATION HES-12-FC [sink --cr 136] Sample Date/Time 11/17/2021 06:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 15:01 BJ

MARTEL NO. 60424 13 CLIENT SAMPLE IDENTIFICATION HES-13-DB [bubbler --cr 136] Sample Date/Time 11/17/2021 06:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.61	ug/l	EPA .200.8	2	01/24/2022 15:04 BJ

MARTEL NO. 60424 14 CLIENT SAMPLE IDENTIFICATION HES-14-FC [sink --cr 133] Sample Date/Time 11/17/2021 06:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.99	ug/l*	EPA .200.8	2	01/24/2022 15:06 BJ

MARTEL NO. 60424 15 CLIENT SAMPLE IDENTIFICATION HES-15-DB [bubbler --cr 133] Sample Date/Time 11/17/2021 06:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.57	ug/l	EPA .200.8	2	01/24/2022 15:09 BJ

MARTEL NO. 60424 16 CLIENT SAMPLE IDENTIFICATION HES-16-FC [sink --cr 130] Sample Date/Time 11/17/2021 06:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.8	ug/l*	EPA .200.8	2	01/24/2022 15:11 BJ



MARTEL NO. 60424 17 CLIENT SAMPLE IDENTIFICATION HES-17-DB [bubbler --cr 130] Sample Date/Time 11/17/2021 06:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 15:14 BJ

MARTEL NO. 60424 18 CLIENT SAMPLE IDENTIFICATION HES-18-FC [sink --cr 118] left Sample Date/Time 11/17/2021 06:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 15:16 BJ

MARTEL NO. 60424 19 CLIENT SAMPLE IDENTIFICATION HES-19-FC [sink --cr 118] right Sample Date/Time 11/17/2021 06:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 15:19 BJ

MARTEL NO. 60424 20 CLIENT SAMPLE IDENTIFICATION HES-20-DC [water fountain--corridor] Sample Date/Time 11/17/2021 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 15:21 BJ

MARTEL NO. 60424 21 CLIENT SAMPLE IDENTIFICATION HES-21-FC [sink --cr 121] Sample Date/Time 11/17/2021 06:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.92	ug/l*	EPA .200.8	2	01/24/2022 15:29 BJ

MARTEL NO. 60424 22 CLIENT SAMPLE IDENTIFICATION HES-22-DB [bubbler --cr 121] Sample Date/Time 11/17/2021 06:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 15:36 BJ

MARTEL NO. 60424 23 CLIENT SAMPLE IDENTIFICATION HES-23-FC [sink --cr 123] Sample Date/Time 11/17/2021 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.64	ug/l	EPA .200.8	2	01/24/2022 15:39 BJ

MARTEL NO. 60424 24 CLIENT SAMPLE IDENTIFICATION HES-24-DB [bubbler --cr 123] Sample Date/Time 11/17/2021 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.84	ug/l	EPA .200.8	2	01/24/2022 15:41 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60424 27	HES-27-FC [sink --cr 119]	11/17/2021 06:28			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 15:44 BJ
60424 28	HES-28-DB [bubbler --cr 119]	11/17/2021 06:28			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.47	ug/l	EPA .200.8	2	01/24/2022 15:46 BJ
60424 29	HES-29-FC [sink --cr 117]	11/17/2021 06:27			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 15:49 BJ
60424 30	HES-30-DB [bubbler --cr 117]	11/17/2021 06:27			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 15:51 BJ
60424 31	HES-31-FC [sink --cr 115]	11/17/2021 06:26			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.37	ug/l*	EPA .200.8	2	01/24/2022 15:54 BJ
60424 32	HES-32-DB [bubbler --cr 115]	11/17/2021 06:26			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 15:56 BJ
60424 33	HES-33-FC [sink --cr 114]	11/17/2021 06:25			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 16:06 BJ
60424 34	HES-34-DB [bubbler --cr 114]	11/17/2021 06:25			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.61	ug/l	EPA .200.8	2	01/24/2022 16:11 BJ



Certificate of Analysis

MARTEL NO. 60424 35 CLIENT SAMPLE IDENTIFICATION HES-35-FC [sink --cr 113] Sample Date/Time 11/17/2021 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.13	ug/l	EPA .200.8	2	01/24/2022 16:13 BJ

MARTEL NO. 60424 36 CLIENT SAMPLE IDENTIFICATION HES-36-DB [bubbler --cr 113] Sample Date/Time 11/17/2021 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 16:16 BJ

MARTEL NO. 60424 37 CLIENT SAMPLE IDENTIFICATION HES-37-FC [sink --cr 112] Sample Date/Time 11/17/2021 06:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.46	ug/l*	EPA .200.8	2	01/24/2022 16:18 BJ

MARTEL NO. 60424 38 CLIENT SAMPLE IDENTIFICATION HES-38-DB [bubbler --cr 112] Sample Date/Time 11/17/2021 06:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.12	ug/l	EPA .200.8	2	01/24/2022 16:21 BJ

MARTEL NO. 60424 39 CLIENT SAMPLE IDENTIFICATION HES-39-FC [sink --cr 107] Sample Date/Time 11/17/2021 06:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 16:23 BJ

MARTEL NO. 60424 40 CLIENT SAMPLE IDENTIFICATION HES-40-DB [bubbler --cr 107] Sample Date/Time 11/17/2021 06:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.02	ug/l	EPA .200.8	2	01/24/2022 16:26 BJ

MARTEL NO. 60424 43 CLIENT SAMPLE IDENTIFICATION HES-43-FC [sink --cr 106] Sample Date/Time 11/17/2021 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	18.0	ug/l*	EPA .200.8	2	01/24/2022 16:28 BJ

MARTEL NO. 60424 44 CLIENT SAMPLE IDENTIFICATION HES-44-DB [bubbler --cr 106] Sample Date/Time 11/17/2021 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.04	ug/l	EPA .200.8	2	01/24/2022 16:31 BJ



MARTEL NO. 60424 45 CLIENT SAMPLE IDENTIFICATION HES-45-FC [sink --cr 105 (Sp-Ed) Life Skills] Sample Date/Time 11/17/2021 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 16:38 BJ

MARTEL NO. 60424 46 CLIENT SAMPLE IDENTIFICATION HES-46-DB [bubbler --cr 105 (Sp-Ed) Life Skills] Sample Date/Time 11/17/2021 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 16:46 BJ

MARTEL NO. 60424 47 CLIENT SAMPLE IDENTIFICATION HES-47-FC [Sink - Right--cr 103 - Pre-K] Sample Date/Time 11/17/2021 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.81	ug/l	EPA .200.8	2	01/24/2022 16:48 BJ

MARTEL NO. 60424 48 CLIENT SAMPLE IDENTIFICATION HES-48-DB [bubbler --cr 103 - Pre-K] Sample Date/Time 11/17/2021 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.66	ug/l	EPA .200.8	2	01/24/2022 16:51 BJ

MARTEL NO. 60424 49 CLIENT SAMPLE IDENTIFICATION HES-49-FC [sink - Left--cr 103 - Pre-K] Sample Date/Time 11/17/2021 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 16:53 BJ

MARTEL NO. 60424 50 CLIENT SAMPLE IDENTIFICATION HES-50-FC [sink - Left--cr 101 - K] Sample Date/Time 11/17/2021 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.17	ug/l*	EPA .200.8	2	01/24/2022 16:56 BJ

MARTEL NO. 60424 51 CLIENT SAMPLE IDENTIFICATION HES-51-DB [bubbler --cr 101 - K] Sample Date/Time 11/17/2021 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 16:58 BJ

MARTEL NO. 60424 52 CLIENT SAMPLE IDENTIFICATION HES-52-FC [sink - Right--cr 101 - K] Sample Date/Time 11/17/2021 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.1	ug/l*	EPA .200.8	2	01/24/2022 17:01 BJ



MARTEL NO. 60424 53 CLIENT SAMPLE IDENTIFICATION HES-53-FC [sink - Right--cr 102 - K] Sample Date/Time 11/17/2021 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.7	ug/l*	EPA .200.8	2	01/24/2022 17:03 BJ

MARTEL NO. 60424 54 CLIENT SAMPLE IDENTIFICATION HES-54-DB [bubbler --cr 102 - K] Sample Date/Time 11/17/2021 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.52	ug/l	EPA .200.8	2	01/24/2022 17:06 BJ

MARTEL NO. 60424 56 CLIENT SAMPLE IDENTIFICATION HES-56-DC [water fountain--hallway next to cr 102] Sample Date/Time 11/17/2021 06:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 17:15 BJ

MARTEL NO. 60424 57 CLIENT SAMPLE IDENTIFICATION HES-57-DC [water fountain--auditoruim/ lunch room] Sample Date/Time 11/17/2021 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 17:20 BJ

MARTEL NO. 60424 58 CLIENT SAMPLE IDENTIFICATION HES-58-FC [Sink - Left fixture--Kitchen - Left Fixtur] Sample Date/Time 11/17/2021 06:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 17:23 BJ

MARTEL NO. 60424 59 CLIENT SAMPLE IDENTIFICATION HES-59-FC [Sink - Right fixture--Kitchen - Right Fixt] Sample Date/Time 11/17/2021 06:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.04	ug/l	EPA .200.8	2	01/24/2022 17:25 BJ

MARTEL NO. 60424 60 CLIENT SAMPLE IDENTIFICATION HES-60-FC [island sink--kitchen] Sample Date/Time 11/17/2021 06:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.32	ug/l	EPA .200.8	2	01/24/2022 17:28 BJ

MARTEL NO. 60424 61 CLIENT SAMPLE IDENTIFICATION HES-61-FC [2 comp sink --kitchen] Sample Date/Time 11/17/2021 06:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.97	ug/l	EPA .200.8	2	01/24/2022 17:30 BJ



MARTEL NO. 60424 62 CLIENT SAMPLE IDENTIFICATION HES-62-FC [island sink next to water fountain--kitche] Sample Date/Time 11/17/2021 06:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 17:33 BJ

MARTEL NO. 60424 63 CLIENT SAMPLE IDENTIFICATION HES-63-DC [water fountain--kitchen] Sample Date/Time 11/17/2021 06:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 17:35 BJ

MARTEL NO. 60424 64 CLIENT SAMPLE IDENTIFICATION HES-64-IM [Ice Machine--Kitchen] Sample Date/Time 11/17/2021 06:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 17:38 BJ

MARTEL NO. 60424 66 CLIENT SAMPLE IDENTIFICATION HES-66-FC [sink --Nurse's Office] Sample Date/Time 11/17/2021 06:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.04	ug/l	EPA .200.8	2	01/24/2022 17:40 BJ

MARTEL NO. 60424 67 CLIENT SAMPLE IDENTIFICATION HES-67-BU [Bottle Filler--Café] Sample Date/Time 11/17/2021 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 17:48 BJ

MARTEL NO. 60424 68 CLIENT SAMPLE IDENTIFICATION HES-68-BU [Bottle Filler--Corridor] Sample Date/Time 11/17/2021 06:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2022 17:56 BJ

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: F: 11/16/21 18:44 End Date/Time: F: 11/16/21 19:38
S: 11/17/21 6:46 S: 11/17/21 6:49
 Sampler/Relinquished By: [Signature] Received at Martel By: [Signature] Date/Time: 11/17/21 1435

16- Dr. Thomas L. Higdon Elementary PSC #08.027
12872 Rock Point Road Newburg, MD 20664

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Flush
 18:44
 19:38
 Martel NO: **60424**

Martel #	Sample #	Location ID #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)</small>	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush Date	Sample Time
1	1	HES-1-DC	water fountain on left	DC	main corridor	C	✓	6:49
2	2	HES-2-DC	water fountain on right	DC	main corridor	C	✓	↓
3	3	HES-3-FC	teacher lounge sink	FC	teacher lounge CR 125	C	✓	6:47
4	4	HES-4-DB	bubbler	DB	teacher lounge CR 125	C	✓	↓
5	5	HES-5-DC	water fountain	DC	corridor next to cr 131	C	✓	6:36
6	6	HES-6-FC	sink	FC	cr 131	C	✓	6:37
7	7	HES-7-DB	bubbler	DB	cr 131	C	✓	OUT WORKING
8	8	HES-8-FC	sink	FC	cr 132	C	✓	6:38
9	9	HES-9-DB	bubbler	DB	cr 132	C	✓	↓
10	10	HES-10-FC	sink	FC	cr 135	C	✓	6:44
11	11	HES-11-DB	bubbler	DB	cr 135	C	✓	↓
12	12	HES-12-FC	sink	FC	cr 136	C	✓	6:43
13	13	HES-13-DB	bubbler	DB	cr 136	C	✓	↓
14	14	HES-14-FC	sink	FC	cr 133	C	✓	6:42
15	15	HES-15-DB	bubbler	DB	cr 133	C	✓	↓
16	16	HES-16-FC	sink	FC	cr 130	C	✓	6:39
17	17	HES-17-DB	bubbler	DB	cr 130	C	✓	↓
18	18	HES-18-FC	sink LEFT	FC	cr 118	C	✓	6:41
19	19	HES-19-DB	SINK bubbler RIGHT	DB	cr 118	C	✓	↓
20	20	HES-20-DC	water fountain	DC	corridor	C	✓	6:33
21	21	HES-21-FC	sink	FC	cr 121	C	✓	6:32
22	22	HES-22-DB	bubbler	DB	cr 121	C	✓	↓
23	23	HES-23-FC	sink	FC	cr 123	C	✓	6:30
24	24	HES-24-DB	bubbler	DB	cr 123	C	✓	↓
25	27	HES-27-FC	sink	FC	cr 119	C	✓	6:28

16- Dr. Thomas L. Higdon Elementary PSC #08.027

12872 Rock Point Road Newburg, MD 20664

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN
SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush 60424

26	28	HES-28-DB	bubbler	DB	cr 119	C	/	6:28	
27	29	HES-29-FC	sink	FC	cr 117	C	/	6:27	
28	30	HES-30-DB	bubbler	DB	cr 117	C	/	↓	
29	31	HES-31-FC	sink	FC	cr 115	C	/	6:26	
30	32	HES-32-DB	bubbler	DB	cr 115	C	/	↓	
31	33	HES-33-FC	sink	FC	cr 114	C	/	6:25	
32	34	HES-34-DB	bubbler	DB	cr 114	C	/	↓	
33	35	HES-35-FC	sink	FC	cr 113	C	/	6:24	
34	36	HES-36-DB	bubbler	DB	cr 113	C	/	↓	
35	37	HES-37-FC	sink	FC	cr 112	C	/	6:23	
36	38	HES-38-DB	bubbler	DB	cr 112	C	/	↓	
37	39	HES-39-FC	sink	FC	cr 107	C	/	6:22	
38	40	HES-40-DB	bubbler	DB	cr 107	C	/	↓	
39	43	HES-43-FC	sink	FC	cr 106	C	/	6:20	
40	44	HES-44-DB	bubbler	DB	cr 106	C	/	↓	
41	45	HES-45-FC	sink	FC	cr 105 (Sp-Ed) Life Skills	C	/	6:21	
42	46	HES-46-DB	bubbler	DB	cr 105 (Sp-Ed) Life Skills	C	/	↓	
43	47	HES-47-FC	Sink - Right	FC	cr 103 - Pre-K	C	/	6:18	
44	48	HES-48-DB	bubbler	DB	cr 103 - Pre-K	C	/	↓	
45	49	HES-49-FC	sink - Left	FC	cr 103 - Pre-K	C	/	↓	
46	50	HES-50-FC	sink - Left	FC	cr 101 - K	C	/	6:15	
47	51	HES-51-DB	bubbler	DB	cr 101 - K	C	/	↓	
48	52	HES-52-FC	sink - Right	FC	cr 101 - K	C	/	↓	
49	53	HES-53-FC	sink - Right	FC	cr 102 - K	C	/	6:16	
50	54	HES-54-DB	bubbler	DB	cr 102 - K	C	/	↓	
51	56	HES-56-DC	water fountain	DC	hallway next to cr 102	C	/	6:06	
52	57	HES-57-DC	water fountain	DC	auditoruim/ lunch room	C	/	6:11	
53	58	HES-58-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	/	6:08	
54	59	HES-59-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	/	↓	
55	60	HES-60-FC	island sink	FC	kitchen	C	/	↓	
56	61	HES-61-FC	2 comp sink	FC	kitchen	C	/	↓	
57	62	HES-62-FC	island sink next to water fountain	FC	kitchen	C	/	6:09	
58	63	HES-63-DC	water fountain	DC	kitchen	C	/	↓	

16- Dr. Thomas L. Higdon Elementary PSC #08.027

12872 Rock Point Road Newburg, MD 20664

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN
SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush

60424

59	64	HES-64-IM	Ice Machine	IM	Kitchen	C	/	6:09
60	66	HES-66-FC	sink	FC	Nurse's Office	C	/	6:46
61	67	HES-67-BU	Bottle Filler	BU	Café	C	/	6:11
62	68	HES-68-BU	Bottle Filler	BU	Corridor	C	/	6:36

P 12