



**Charles County Public Schools**  
P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646  
**Attention:**

Saturday, January 29, 2022  
***Certificate of Analysis***  
**FINAL**

**Project Information:**

Report for Lab No: 60420.  
Samples flushed by Martel on November 9, 2021, sampled by Martel on November 10, 2021.  
Project Identification: MD HB 270  
School: 11 Mt. Hope ES PSC #08.023

**References and Important Notes:**

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

\* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

**Notices:**

Chain of Custody Form(s) are attached and are an integral part of this report.  
This report will be retained for at least five years and will be disposed of without notice.  
Measurement uncertainty for each listed test is available upon request.  
The results presented herein relate only to the samples or items tested.  
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 60420 1 CLIENT SAMPLE IDENTIFICATION MHES-1-FC [sink--cr 57] Sample Date/Time 11/10/2021 04:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:04 BJ

MARTEL NO. 60420 2 CLIENT SAMPLE IDENTIFICATION MHES-2-DB [bubbler--cr 57] Sample Date/Time 11/10/2021 04:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:16 BJ

MARTEL NO. 60420 3 CLIENT SAMPLE IDENTIFICATION MHES-3-FC [sink--cr 56] Sample Date/Time 11/10/2021 04:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.60	ug/l*	EPA .200.8	2	01/27/2022 14:19 BJ

MARTEL NO. 60420 4 CLIENT SAMPLE IDENTIFICATION MHES-4-DB [bubbler--cr 56] Sample Date/Time 11/10/2021 04:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:21 BJ

MARTEL NO. 60420 5 CLIENT SAMPLE IDENTIFICATION MHES-5-FC [sink--cr 55 (Sp-Ed) Pull Out] Sample Date/Time 11/10/2021 04:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.00	ug/l	EPA .200.8	2	01/27/2022 14:24 BJ

MARTEL NO. 60420 6 CLIENT SAMPLE IDENTIFICATION MHES-6-DB [bubbler--cr 55 (Sp-Ed) Pull Out] Sample Date/Time 11/10/2021 04:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:26 BJ

MARTEL NO. 60420 7 CLIENT SAMPLE IDENTIFICATION MHES-7-FC [sink--cr 54 (Sp-Ed) Pull Out - Speech] Sample Date/Time 11/10/2021 04:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.06	ug/l	EPA .200.8	2	01/27/2022 14:29 BJ

MARTEL NO. 60420 8 CLIENT SAMPLE IDENTIFICATION MHES-8-DB [bubbler--cr 54 (Sp-Ed) Pull Out - Speech] Sample Date/Time 11/10/2021 04:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:31 BJ



MARTEL NO. 60420 9 CLIENT SAMPLE IDENTIFICATION MHES-9-FC [sink--cr 53 - K] Sample Date/Time 11/10/2021 04:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:34 BJ

MARTEL NO. 60420 10 CLIENT SAMPLE IDENTIFICATION MHES-10-DB [bubbler--cr 53 - K] Sample Date/Time 11/10/2021 04:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:36 BJ

MARTEL NO. 60420 11 CLIENT SAMPLE IDENTIFICATION MHES-11-FC [sink on left--activity room 52] Sample Date/Time 11/10/2021 04:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.14	ug/l	EPA .200.8	2	01/27/2022 14:46 BJ

MARTEL NO. 60420 12 CLIENT SAMPLE IDENTIFICATION MHES-12-FC [sink on right--activity room 52] Sample Date/Time 11/10/2021 04:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:52 BJ

MARTEL NO. 60420 13 CLIENT SAMPLE IDENTIFICATION MHES-13-FC [sink--cr 51 - K] Sample Date/Time 11/10/2021 04:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:54 BJ

MARTEL NO. 60420 14 CLIENT SAMPLE IDENTIFICATION MHES-14-DB [bubbler--cr 51 - K] Sample Date/Time 11/10/2021 04:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:57 BJ

MARTEL NO. 60420 15 CLIENT SAMPLE IDENTIFICATION MHES-15-FC [sink--cr 50 - Pre-K] Sample Date/Time 11/10/2021 04:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 14:59 BJ

MARTEL NO. 60420 16 CLIENT SAMPLE IDENTIFICATION MHES-16-DB [bubbler--cr 50 - Pre-K] Sample Date/Time 11/10/2021 04:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:02 BJ



MARTEL NO. 60420 17 CLIENT SAMPLE IDENTIFICATION MHES-17-FC [sink - Right--cr 49 - Pre-K] Sample Date/Time 11/10/2021 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:04 BJ

MARTEL NO. 60420 18 CLIENT SAMPLE IDENTIFICATION MHES-18-DB [bubbler--cr 49 - Pre-K] Sample Date/Time 11/10/2021 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:06 BJ

MARTEL NO. 60420 19 CLIENT SAMPLE IDENTIFICATION MHES-19-FC [sink - Left--cr 49 - Pre-K] Sample Date/Time 11/10/2021 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:09 BJ

MARTEL NO. 60420 20 CLIENT SAMPLE IDENTIFICATION MHES-20-FC [sink--cr 48] Sample Date/Time 11/10/2021 04:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:11 BJ

MARTEL NO. 60420 21 CLIENT SAMPLE IDENTIFICATION MHES-21-DB [bubbler--cr 48] Sample Date/Time 11/10/2021 04:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:19 BJ

MARTEL NO. 60420 22 CLIENT SAMPLE IDENTIFICATION MHES-22-FC [sink--cr 47] Sample Date/Time 11/10/2021 04:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:27 BJ

MARTEL NO. 60420 23 CLIENT SAMPLE IDENTIFICATION MHES-23-DB [bubbler--cr 47] Sample Date/Time 11/10/2021 04:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.28	ug/l	EPA .200.8	2	01/27/2022 15:29 BJ

MARTEL NO. 60420 24 CLIENT SAMPLE IDENTIFICATION MHES-24-FC [sink--cr 69 ] Sample Date/Time 11/10/2021 04:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:31 BJ



MARTEL NO. 60420 25 CLIENT SAMPLE IDENTIFICATION MHES-25-DB [bubbler--cr 69 ] Sample Date/Time 11/10/2021 04:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.24	ug/l*	EPA .200.8	2	01/27/2022 15:34 BJ

MARTEL NO. 60420 26 CLIENT SAMPLE IDENTIFICATION MHES-26-FC [sink--cr 70 (Sp-Ed) Pull Out] Sample Date/Time 11/10/2021 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:37 BJ

MARTEL NO. 60420 27 CLIENT SAMPLE IDENTIFICATION MHES-27-DB [bubbler--cr 70 (Sp-Ed) Pull Out] Sample Date/Time 11/10/2021 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.6	ug/l*	EPA .200.8	2	01/27/2022 15:39 BJ

MARTEL NO. 60420 28 CLIENT SAMPLE IDENTIFICATION MHES-28-FC [sink--cr 59] Sample Date/Time 11/10/2021 04:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:42 BJ

MARTEL NO. 60420 29 CLIENT SAMPLE IDENTIFICATION MHES-29-DB [bubbler--cr 59] Sample Date/Time 11/10/2021 04:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:44 BJ

MARTEL NO. 60420 30 CLIENT SAMPLE IDENTIFICATION MHES-30-FC [sink--cr 58] Sample Date/Time 11/10/2021 04:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 15:47 BJ

MARTEL NO. 60420 31 CLIENT SAMPLE IDENTIFICATION MHES-31-DB [bubbler--cr 58] Sample Date/Time 11/10/2021 04:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.29	ug/l	EPA .200.8	2	01/27/2022 15:56 BJ

MARTEL NO. 60420 32 CLIENT SAMPLE IDENTIFICATION MHES-32-DC [water fountain --1st grade hallway] Sample Date/Time 11/10/2021 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 16:01 BJ



MARTEL NO. 60420 35 CLIENT SAMPLE IDENTIFICATION MHES-35-FC [sink--cr 68] Sample Date/Time 11/10/2021 04:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.76	ug/l	EPA .200.8	2	01/27/2022 16:04 BJ

MARTEL NO. 60420 36 CLIENT SAMPLE IDENTIFICATION MHES-36-DB [bubbler--cr 68] Sample Date/Time 11/10/2021 04:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.42	ug/l*	EPA .200.8	2	01/27/2022 16:06 BJ

MARTEL NO. 60420 37 CLIENT SAMPLE IDENTIFICATION MHES-37-DC [water fountain --4th grade hallway ] Sample Date/Time 11/10/2021 04:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 16:09 BJ

MARTEL NO. 60420 40 CLIENT SAMPLE IDENTIFICATION MHES-40-FC [sink--cr 44] Sample Date/Time 11/10/2021 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 16:11 BJ

MARTEL NO. 60420 41 CLIENT SAMPLE IDENTIFICATION MHES-41-DB [bubbler--cr 44] Sample Date/Time 11/10/2021 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.27	ug/l	EPA .200.8	2	01/27/2022 16:14 BJ

MARTEL NO. 60420 42 CLIENT SAMPLE IDENTIFICATION MHES-42-FC [sink--media center] Sample Date/Time 11/10/2021 04:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 16:16 BJ

MARTEL NO. 60420 43 CLIENT SAMPLE IDENTIFICATION MHES-43-DB [bubbler--media center] Sample Date/Time 11/10/2021 04:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	54.7	ug/l*	EPA .200.8	2	01/27/2022 16:19 BJ

MARTEL NO. 60420 44 CLIENT SAMPLE IDENTIFICATION MHES-44-DC [water fountain --main corridor] Sample Date/Time 11/10/2021 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 16:21 BJ



MARTEL NO.	60420	45	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
			MHES-45-FC [sink--rt room ]	11/10/2021 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.70	ug/l	EPA .200.8	2	01/27/2022 16:29 BJ

MARTEL NO.	60420	46	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
			MHES-46-DB [bubbler--rt room ]	11/10/2021 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.2	ug/l*	EPA .200.8	2	01/27/2022 16:36 BJ

MARTEL NO.	60420	47	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
			MHES-47-FC [sink - Next to fridge--teacher lounge]	11/10/2021 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 16:39 BJ

MARTEL NO.	60420	48	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
			MHES-48-FC [sink --teacher lounge]	11/10/2021 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	/ /

MARTEL NO.	60420	49	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
			MHES-49-FC [sink--main office]	11/10/2021 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	removed		EPA .200.8	2	/ /

MARTEL NO.	60420	50	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
			MHES-50-FC [island sink--kitchen]	11/10/2021 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 16:41 BJ

MARTEL NO.	60420	51	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
			MHES-51-FC [Sink - Left fixture--Kitchen - Left Fixture on	11/10/2021 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 16:44 BJ

MARTEL NO.	60420	52	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
			MHES-52-FC [Sink - Right fixture--Kitchen - Right Fixture	11/10/2021 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 16:46 BJ



# Certificate of Analysis

MARTEL NO. 60420 53 CLIENT SAMPLE IDENTIFICATION MHES-53-FC [island sink - near ice machine--kitchen] Sample Date/Time 11/10/2021 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.07	ug/l*	EPA .200.8	2	01/27/2022 16:49 BJ

MARTEL NO. 60420 54 CLIENT SAMPLE IDENTIFICATION MHES-54-FC [2 comp sink--kitchen] Sample Date/Time 11/10/2021 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.15	ug/l	EPA .200.8	2	01/27/2022 16:51 BJ

MARTEL NO. 60420 58 CLIENT SAMPLE IDENTIFICATION MHES-58-FC [Sink--Reading Room] Sample Date/Time 11/10/2021 04:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.70	ug/l	EPA .200.8	2	01/27/2022 17:01 BJ

MARTEL NO. 60420 59 CLIENT SAMPLE IDENTIFICATION MHES-59-DB [Bubbler--Reading Room] Sample Date/Time 11/10/2021 04:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 17:06 BJ

MARTEL NO. 60420 63 CLIENT SAMPLE IDENTIFICATION MHES-63-IM [Ice Machine --Kitchen] Sample Date/Time 11/10/2021 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 17:08 BJ

MARTEL NO. 60420 64 CLIENT SAMPLE IDENTIFICATION MHES-64-DC [Water Fountain --Gym] Sample Date/Time 11/10/2021 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 17:11 BJ

MARTEL NO. 60420 65 CLIENT SAMPLE IDENTIFICATION MHES-65-BU [Bottle Filler--Corridor] Sample Date/Time 11/10/2021 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/27/2022 17:13 BJ

MARTEL NO. 60420 66 CLIENT SAMPLE IDENTIFICATION MHES-66-BU [Bottle Filler--Corridor] Sample Date/Time 11/10/2021 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.17	ug/l	EPA .200.8	2	01/27/2022 17:16 BJ



# MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

## Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: FLUSH: 11/19/21 19:35 End Date/Time: 11/19/21 20:53

Sampler/Relinquished By: S. C. Cpl Received at Martel by [Signature] Date/Time: 11/10/21 1325

**11- Mt. Hope ES PSC #08.023**  
**9275 Ironsides Road Nanjemoy, MD 20662**

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

19:35  
20:53  
Flush  
Martel NO: 60420

Martel #	Sample #	Location ID #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)</small>	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush Date	Sample Time
1	1	MHES-1-FC	sink	FC	cr 57	C	/	4:37
2	2	MHES-2-DB	bubbler	DB	cr 57	C	/	↓
3	3	MHES-3-FC	sink	FC	cr 56	C	/	4:38
4	4	MHES-4-DB	bubbler	DB	cr 56	C	/	↓
5	5	MHES-5-FC	sink	FC	cr 55 (Sp-Ed) Pull Out	C	/	4:41
6	6	MHES-6-DB	bubbler	DB	cr 55 (Sp-Ed) Pull Out	C	/	↓
7	7	MHES-7-FC	sink	FC	cr 54 (Sp-Ed) Pull Out - Speech	C	/	4:43
8	8	MHES-8-DB	bubbler	DB	cr 54 (Sp-Ed) Pull Out - Speech	C	/	↓
9	9	MHES-9-FC	sink	FC	cr 53 - K	C	/	4:45
10	10	MHES-10-DB	bubbler	DB	cr 53 - K	C	/	↓
11	11	MHES-11-FC	sink on left	FC	activity room 52	C	/	4:47
12	12	MHES-12-FC	sink on right	FC	activity room 52	C	/	↓
13	13	MHES-13-FC	sink	FC	cr 51 - K	C	/	4:48
14	14	MHES-14-DB	bubbler	DB	cr 51 - K	C	/	↓
15	15	MHES-15-FC	sink	FC	cr 50 - Pre-K	C	/	4:49
16	16	MHES-16-DB	bubbler	DB	cr 50 - Pre-K	C	/	↓
17	17	MHES-17-FC	sink - Right	FC	cr 49 - Pre-K	C	/	4:50
18	18	MHES-18-DB	bubbler	DB	cr 49 - Pre-K	C	/	↓
19	19	MHES-19-FC	sink - Left	FC	cr 49 - Pre-K	C	/	↓
20	20	MHES-20-FC	sink	FC	cr 48	C	/	4:51
21	21	MHES-21-DB	bubbler	DB	cr 48	C	/	↓
22	22	MHES-22-FC	sink	FC	cr 47	C	/	4:53
23	23	MHES-23-DB	bubbler	DB	cr 47	C	/	↓
24	24	MHES-24-FC	sink	FC	cr 69	C	/	4:56
25	25	MHES-25-DB	bubbler	DB	cr 69	C	/	↓

P 09

**11- Mt. Hope ES PSC #08.023**  
**9275 Ironsides Road Nanjemoy, MD 20662**

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN  
SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

Martel NO:  
**60420**

							Flush	
26	26	MHES-26-FC	sink	FC	cr 70 (Sp-Ed) Pull Out	C	/	5:08
27	27	MHES-27-DB	bubbler	DB	cr 70 (Sp-Ed) Pull Out	C	/	↓
28	28	MHES-28-FC	sink	FC	cr 59	C	/	4:40
29	29	MHES-29-DB	bubbler	DB	cr 59	C	/	↓
30	30	MHES-30-FC	sink	FC	cr 58	C	/	4:39
31	31	MHES-31-DB	bubbler	DB	cr 58	C	/	↓
32	32	MHES-32-DC	water fountain	DC	1st grade hallway	C	/	4:46
33	35	MHES-35-FC	sink	FC	cr 68	C	/	4:58
34	36	MHES-36-DB	bubbler	DB	cr 68	C	/	↓
35	37	MHES-37-DC	water fountain	DC	4th grade hallway	C	/	4:57
36	40	MHES-40-FC	sink	FC	cr 44	C	/	5:00
37	41	MHES-41-DB	bubbler	DB	cr 44	C	/	↓
38	42	MHES-42-FC	sink	FC	media center	C	/	4:35
39	43	MHES-43-DB	bubbler	DB	media center	C	/	↓
40	44	MHES-44-DC	water fountain	DC	main corridor	C	/	5:02
41	45	MHES-45-FC	sink	FC	Room 43 rt room	C	/	5:04
42	46	MHES-46-DB	bubbler	DB	↓ rt room	C	/	↓
43	47	MHES-47-FC	sink - Next to fridge	FC	teacher lounge	C	/	5:05
44	48	MHES-48-FC	sink	FC	teacher lounge	C	N/A	ONLY ONE SINK
45	49	MHES-49-FC	sink	FC	main office	C	REMOVED	
46	50	MHES-50-FC	island sink	FC	kitchen	C	/	5:10
47	51	MHES-51-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	/	↓
48	52	MHES-52-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	/	↓
49	53	MHES-53-FC	island sink - near ice machine	FC	kitchen	C	/	5:11
50	54	MHES-54-FC	2 comp sink	FC	kitchen	C	/	↓
51	58	MHES-58-FC	Sink	FC	Room 60 Reading Room	C	/	4:42
52	59	MHES-59-DB	Bubbler	DB	↓ Reading Room	C	/	↓
53	63	MHES-63-IM	Ice Machine	IM	Kitchen	C	LOCKED	5:11
54	64	MHES-64-DC	Water Fountain	DC	Gym	C	/	5:06
55	65	MHES-65-BU	Bottle Filler	BU	Corridor	C	/	5:02
56	66	MHES-66-BU	Bottle Filler	BU	Corridor	C	/	4:46