



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Attention:

Tuesday, February 8, 2022

Certificate of Analysis

AMENDED

Project Information:

Report for Lab No: 60428.
Samples flushed by Martel on November 22, 2021, sampled by Martel on November 23, 2021.
Project Identification: MD HB 270
School: 38 Benjamin Stoddert Middle School PSC #08.002.

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

This report amends either the original report or the last amended report sent on: January 31, 2022
It has been amended for the following reason(s): Two sample id's requested change by client.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.

DL2020


Prefect Manager



MARTEL NO. 60428 1 CLIENT SAMPLE IDENTIFICATION BSMS-1-FC [2 Comp Sink--Kitchen] Sample Date/Time 11/23/2021 04:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:11 BJ

MARTEL NO. 60428 2 CLIENT SAMPLE IDENTIFICATION BSMS-2-IM [Ice Machine--Kitchen] Sample Date/Time 11/23/2021 04:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:19 BJ

MARTEL NO. 60428 3 CLIENT SAMPLE IDENTIFICATION BSMS-3-KK [Kettle--Kitchen] Sample Date/Time 11/23/2021 04:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.28	ug/l	EPA .200.8	2	01/25/2022 17:22 BJ

MARTEL NO. 60428 4 CLIENT SAMPLE IDENTIFICATION BSMS-4-FC [3 comp sink right fixture--Kitchen] Sample Date/Time 11/23/2021 04:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:24 BJ

MARTEL NO. 60428 5 CLIENT SAMPLE IDENTIFICATION BSMS-5-FC [3 comp sink left fixture--Kitchen] Sample Date/Time 11/23/2021 04:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:27 BJ

MARTEL NO. 60428 6 CLIENT SAMPLE IDENTIFICATION BSMS-6-FC [Sink--A100 Nurse] Sample Date/Time 11/23/2021 04:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:29 BJ

MARTEL NO. 60428 7 CLIENT SAMPLE IDENTIFICATION BSMS-7-FC [Sink--A102 Privacy Room] Sample Date/Time 11/23/2021 04:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.08	ug/l	EPA .200.8	2	01/25/2022 17:32 BJ

MARTEL NO. 60428 8 CLIENT SAMPLE IDENTIFICATION BSMS-8-DC [Water Fountain (Low) --Corridor] Sample Date/Time 11/23/2021 04:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:34 BJ



MARTEL NO. 60428 9 CLIENT SAMPLE IDENTIFICATION BSMS-9-DC [Water Fountain (High) --Corridor] Sample Date/Time 11/23/2021 04:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:37 BJ

MARTEL NO. 60428 10 CLIENT SAMPLE IDENTIFICATION BSMS-10-BU [Bottle Filler--Corridor] Sample Date/Time 11/23/2021 04:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:39 BJ

MARTEL NO. 60428 11 CLIENT SAMPLE IDENTIFICATION BSMS-11-DC [Water Fountain (Low) --Corridor] Sample Date/Time 11/23/2021 04:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:49 BJ

MARTEL NO. 60428 12 CLIENT SAMPLE IDENTIFICATION BSMS-12-DC [Water Fountain (High) --Corridor] Sample Date/Time 11/23/2021 04:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:54 BJ

MARTEL NO. 60428 13 CLIENT SAMPLE IDENTIFICATION BSMS-13-BU [Bottle Filler--Corridor] Sample Date/Time 11/23/2021 04:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:57 BJ

MARTEL NO. 60428 14 CLIENT SAMPLE IDENTIFICATION BSMS-14-DC [Water Fountain (Low) Left of serving line--Caf] Sample Date/Time 11/23/2021 04:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 17:59 BJ

MARTEL NO. 60428 15 CLIENT SAMPLE IDENTIFICATION BSMS-15-DC [Water Fountain (High) Left of serving line--Ca] Sample Date/Time 11/23/2021 04:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:02 BJ

MARTEL NO. 60428 16 CLIENT SAMPLE IDENTIFICATION BSMS-16-BU [Bottle Filler - Left of serving line--Café] Sample Date/Time 11/23/2021 04:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:04 BJ



MARTEL NO. 60428 17 CLIENT SAMPLE IDENTIFICATION BSMS-17-DC [Bottle Filler - Right of serving line--Café] Sample Date/Time 11/23/2021 04:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:07 BJ

MARTEL NO. 60428 18 CLIENT SAMPLE IDENTIFICATION BSMS-18-DC [Water Fountain (High) Right of serving line--C] Sample Date/Time 11/23/2021 04:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:09 BJ

MARTEL NO. 60428 19 CLIENT SAMPLE IDENTIFICATION BSMS-19-BU [Water Fountain (Low) Right of serving line--Ca] Sample Date/Time 11/23/2021 04:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:12 BJ

MARTEL NO. 60428 20 CLIENT SAMPLE IDENTIFICATION BSMS-20-FC [2 Comp Sink--Kitchen - Prep Room] Sample Date/Time 11/23/2021 04:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.12	ug/l	EPA .200.8	2	01/25/2022 18:14 BJ

MARTEL NO. 60428 21 CLIENT SAMPLE IDENTIFICATION BSMS-21-FC [Sink--B124 Work Room - Main Office] Sample Date/Time 11/23/2021 04:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.91	ug/l*	EPA .200.8	2	01/25/2022 18:22 BJ

MARTEL NO. 60428 22 CLIENT SAMPLE IDENTIFICATION BSMS-22-FC [Sink--A100 Teacher Lounge (2nd Floor)] Sample Date/Time 11/23/2021 04:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.06	ug/l	EPA .200.8	2	01/25/2022 18:30 BJ

MARTEL NO. 60428 23 CLIENT SAMPLE IDENTIFICATION BSMS-23-FC [Sink--A102 Privacy Room (2nd Floor)] Sample Date/Time 11/23/2021 04:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.86	ug/l	EPA .200.8	2	01/25/2022 18:32 BJ

MARTEL NO. 60428 24 CLIENT SAMPLE IDENTIFICATION BSMS-24-DC [Water Fountain (Low) --Corridor (2nd Floor)] Sample Date/Time 11/23/2021 04:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:35 BJ



MARTEL NO. 60428 25 CLIENT SAMPLE IDENTIFICATION BSMS-25-DC [Water Fountain (High) --Corridor (2nd Floor)] Sample Date/Time 11/23/2021 04:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:37 BJ

MARTEL NO. 60428 26 CLIENT SAMPLE IDENTIFICATION BSMS-26-BU [Bottle Filler--Corridor (2nd Floor)] Sample Date/Time 11/23/2021 04:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:40 BJ

MARTEL NO. 60428 27 CLIENT SAMPLE IDENTIFICATION BSMS-27-DC [Water Fountain (Low) --Corridor (2nd Floor)] Sample Date/Time 11/23/2021 04:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:42 BJ

MARTEL NO. 60428 28 CLIENT SAMPLE IDENTIFICATION BSMS-28-DC [Water Fountain (High) --Corridor (2nd Floor)] Sample Date/Time 11/23/2021 04:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:45 BJ

MARTEL NO. 60428 29 CLIENT SAMPLE IDENTIFICATION BSMS-29-BU [Bottle Filler--Corridor (2nd Floor)] Sample Date/Time 11/23/2021 04:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:47 BJ

MARTEL NO. 60428 30 CLIENT SAMPLE IDENTIFICATION BSMS-30-DC [Water Fountain (Low) Left of serving line--Caf] Sample Date/Time 11/23/2021 04:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 18:50 BJ

MARTEL NO. 60428 31 CLIENT SAMPLE IDENTIFICATION BSMS-31-DC [Water Fountain (High) Left of serving line--Ca] Sample Date/Time 11/23/2021 04:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:00 BJ

MARTEL NO. 60428 32 CLIENT SAMPLE IDENTIFICATION BSMS-32-BU [Bottle Filler - Left of serving line--Café (2n] Sample Date/Time 11/23/2021 04:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:05 BJ



MARTEL NO. 60428 33 CLIENT SAMPLE IDENTIFICATION BSMS-33-DC [Bottle Filler - Right of serving line--Café (2)] Sample Date/Time 11/23/2021 04:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:08 BJ

MARTEL NO. 60428 34 CLIENT SAMPLE IDENTIFICATION BSMS-34-DC [Water Fountain (High) Right of serving line--C] Sample Date/Time 11/23/2021 04:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:10 BJ

MARTEL NO. 60428 35 CLIENT SAMPLE IDENTIFICATION BSMS-35-BU [Water Fountain (Low) Right of serving line--Ca] Sample Date/Time 11/23/2021 04:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:13 BJ

MARTEL NO. 60428 36 CLIENT SAMPLE IDENTIFICATION BSMS-36-FC [2 Comp Sink--Kitchen - Prep Room (2nd Floor)] Sample Date/Time 11/23/2021 04:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:15 BJ

MARTEL NO. 60428 37 CLIENT SAMPLE IDENTIFICATION BSMS-37-FC [Sink--300 Teacher Lounge (3rd Floor)] Sample Date/Time 11/23/2021 04:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:18 BJ

MARTEL NO. 60428 38 CLIENT SAMPLE IDENTIFICATION BSMS-38-FC [Sink--302 Privacy Room (3rd Floor)] Sample Date/Time 11/23/2021 04:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.00	ug/l*	EPA .200.8	2	01/25/2022 19:20 BJ

MARTEL NO. 60428 39 CLIENT SAMPLE IDENTIFICATION BSMS-39-DC [Water Fountain (Low) --Corridor (3rd Floor)] Sample Date/Time 11/23/2021 04:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:23 BJ

MARTEL NO. 60428 40 CLIENT SAMPLE IDENTIFICATION BSMS-40-DC [Water Fountain (High) --Corridor (2nd Floor)] Sample Date/Time 11/23/2021 04:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:25 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60428 41	BSMS-41-BU [Bottle Filler--Corridor (3rd Floor)]	11/23/2021 04:03			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:33 BJ
60428 42	BSMS-42-DC [Water Fountain (Low) --Corridor (3rd Floor)]	11/23/2021 04:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:41 BJ
60428 43	BSMS-43-DC [Water Fountain (High) --Corridor (3rd Floor)]	11/23/2021 04:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:43 BJ
60428 44	BSMS-44-BU [Bottle Filler--Corridor (3rd Floor)]	11/23/2021 04:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:46 BJ
60428 45	BSMS-45-DC [Water Fountain (Low) Left of serving line--Caf	11/23/2021 04:05			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:48 BJ
60428 46	BSMS-46-DC [Water Fountain (High) Left of serving line--Ca	11/23/2021 04:05			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:51 BJ
60428 47	BSMS-47-BU [Bottle Filler - Left of serving line--Café (3r	11/23/2021 04:05			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:53 BJ
60428 48	BSMS-48-DC [Bottle Filler - Right of serving line--Café (3	11/23/2021 04:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:56 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60428 49	BSMS-49-DC [Water Fountain (High) Right of serving line--C]	11/23/2021 04:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 19:59 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60428 50	BSMS-50-BU [Water Fountain (Low) Right of serving line--Ca]	11/23/2021 04:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/25/2022 20:01 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60428 51	BSMS-51-FC [2 Comp Sink--Kitchen - Prep Room (3rd Floor)]	11/23/2021 04:07			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.37	ug/l	EPA .200.8	2	01/25/2022 20:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60428 52	BSMS-52-DC [Water Fountain--Corridor]	11/23/2021 04:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	turned	off	EPA .200.8	2	//

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60428 53	BSMS-53-BU [Bottle Filler--Corridor]	11/23/2021 04:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	turned	off	EPA .200.8	2	//

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60428 54	BSMS-54-DC [Water Fountain--Corridor]	11/23/2021 04:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	turned	off	EPA .200.8	2	//

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 11/23/21 0400 End Date/Time: 11/23/21 433

Sampler/Relinquished By: [Signature] Received at Martel by [Signature] Date/Time: 11/23/21 1000

38 Benjamin Stoddert Middle School PSC #08.002
2040 St. Thomas Drive Waldorf, MD 20602

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

11/22 Martel NO: **60428**
Flush

Martel #	Sample #	Location ID #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush Date	Sample Time
1	1	BSMS-1-FC	2 Comp Sink	FC	Kitchen	C	✓	432
2	2	BSMS-2-IM	Ice Machine	IM	Kitchen	C	✓	↓
3	3	BSMS-3-KK	Kettle	KK	Kitchen	C	✓	↓
4	4	BSMS-4-FC	3 comp sink right fixture	FC	Kitchen	C	✓	4433
5	5	BSMS-5-FC	3 comp sink left fixture	FC	Kitchen	C	✓	↓
6	6	BSMS-6-FC	Sink	FC	A100 Nurse	C	✓	423
7	7	BSMS-7-FC	Sink	FC	A102 Privacy Room	C	✓	↓
8	8	BSMS-8-DC	Water Fountain (Low)	DC	Corridor	C	✓	425
9	9	BSMS-9-DC	Water Fountain (High)	DC	Corridor	C	✓	↓
10	10	BSMS-10-BU	Bottle Filler	BU	Corridor	C	✓	↓
11	11	BSMS-11-DC	Water Fountain (Low)	DC	Corridor	C	✓	426
12	12	BSMS-12-DC	Water Fountain (High)	DC	Corridor	C	✓	↓
13	13	BSMS-13-BU	Bottle Filler	BU	Corridor	C	✓	↓
14	14	BSMS-14-DC	Water Fountain (Low) Left of serving line	DC	Café	C	✓	428
15	15	BSMS-15-DC	Water Fountain (High) Left of serving line	DC	Café	C	✓	↓
16	16	BSMS-16-BU	Bottle Filler - Left of serving line	BU	Café	C	✓	↓
17	17	BSMS-17-DC	Bottle Filler - Right of serving line	DC	Café	C	✓	427
18	18	BSMS-18-DC	Water Fountain (High) Right of serving line	DC	Café	C	✓	↓
19	19	BSMS-19-BU	Water Fountain (Low) Right of serving line	BU	Café	C	✓	↓
20	20	BSMS-20-FC	2 Comp Sink	FC	Kitchen - Prep Room	C	✓	425
21	21	BSMS-21-FC	Sink	FC	B124 Work Room - Main Office	C	✓	0400
22	22	BSMS-22-FC	Sink	FC	²⁰⁰ A100 Teacher Lounge (2nd Floor)	C	✓	421
23	23	BSMS-23-FC	Sink	FC	²⁰² A102 Privacy Room (2nd Floor)	C	✓	↓
24	24	BSMS-24-DC	Water Fountain (Low)	DC	Corridor (2nd Floor)	C	✓	418
25	25	BSMS-25-DC	Water Fountain (High)	DC	Corridor (2nd Floor)	C	✓	↓

POB 129

38 Benjamin Stoddert Middle School PSC #08.002

2040 St. Thomas Drive Waldorf, MD 20602

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush 60428

							Flush	60428
26	26	BSMS-26-BU	Bottle Filler	BU	Corridor (2nd Floor)	C	✓	418
27	27	BSMS-27-DC	Water Fountain (Low)	DC	Corridor (2nd Floor)	C	✓	417
28	28	BSMS-28-DC	Water Fountain (High)	DC	Corridor (2nd Floor)	C	✓	↓
29	29	BSMS-29-BU	Bottle Filler	BU	Corridor (2nd Floor)	C	✓	↓
30	30	BSMS-30-DC	Water Fountain (Low) Left of serving line	DC	Café (2nd Floor)	C	✓	416
31	31	BSMS-31-DC	Water Fountain (High) Left of serving line	DC	Café (2nd Floor)	C	✓	↓
32	32	BSMS-32-BU	Bottle Filler - Left of serving line	BU	Café (2nd Floor)	C	✓	↓
33	33	BSMS-33-DC	Bottle Filler - Right of serving line	DC	Café (2nd Floor)	C	✓	412
34	34	BSMS-34-DC	Water Fountain (High) Right of serving line	DC	Café (2nd Floor)	C	✓	↓
35	35	BSMS-35-BU	Water Fountain (Low) Right of serving line	BU	Café (2nd Floor)	C	✓	↓
36	36	BSMS-36-FC	2 Comp Sink	FC	Kitchen - Prep Room (2nd Floor)	C	✓	414
37	37	BSMS-37-FC	Sink	FC	300 A100 Teacher Lounge (3rd Floor)	C	✓	410
38	38	BSMS-38-FC	Sink	FC	302 A102 Privacy Room (3rd Floor)	C	✓	↓
39	39	BSMS-39-DC	Water Fountain (Low)	DC	Corridor (3rd Floor)	C	✓	403
40	40	BSMS-40-DC	Water Fountain (High)	DC	Corridor (2nd Floor)	C	✓	↓
41	41	BSMS-41-BU	Bottle Filler	BU	Corridor (3rd Floor)	C	✓	↓
42	42	BSMS-42-DC	Water Fountain (Low)	DC	Corridor (3rd Floor)	C	✓	404
43	43	BSMS-43-DC	Water Fountain (High)	DC	Corridor (3rd Floor)	C	✓	↓
44	44	BSMS-44-BU	Bottle Filler	BU	Corridor (3rd Floor)	C	✓	↓
45	45	BSMS-45-DC	Water Fountain (Low) Left of serving line	DC	Café (3rd Floor)	C	✓	405
46	46	BSMS-46-DC	Water Fountain (High) Left of serving line	DC	Café (3rd Floor)	C	✓	↓
47	47	BSMS-47-BU	Bottle Filler - Left of serving line	BU	Café (3rd Floor)	C	✓	↓
48	48	BSMS-48-DC	Bottle Filler - Right of serving line	DC	Café (3rd Floor)	C	✓	408
49	49	BSMS-49-DC	Water Fountain (High) Right of serving line	DC	Café (3rd Floor)	C	✓	↓
50	50	BSMS-50-BU	Water Fountain (Low) Right of serving line	BU	Café (3rd Floor)	C	✓	↓
51	51	BSMS-51-FC	2 Comp Sink	FC	Kitchen - Prep Room (3rd Floor)	C	✓	407
52	52	BSMS-52-DC	Water Fountain	DC	Corridor	C	---	turned
53	53	BSMS-53-BU	Bottle Filler	BU	Corridor	C	---	off
54	54	BSMS-54-DC	Water Fountain	DC	Corridor	C	---	↓