

## Water Sampling Results

### Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

**School Name** Mountain View ES

Sample ID	Sample Description	Lead Result in PPB	Action Taken
020117.136A.H4DF.01	Drinking fountain, hallway H4, east end, north wall, left DF	ND	-
020117.136A.H4DF.02	Drinking fountain, hallway H4, east end, north wall, right DF	ND	-
020117.136A.100SK.01	Sink, room 100	5	-
020117.136A.104SK.01	Sink, room 104	2.8	-
020117.136A.106SK.01	Sink, room 106	ND	-
020117.136A.107SK.01	Sink, room 107	5.1	-
020117.136A.107DF.01	Drinking fountain, room 107	1.8	-
020117.136A.109SK.01	Sink, room 109	ND	-
020117.136A.109SK.02	Sink, room 109	0.57	-
020117.136A.108SK.01	Sink, room 108, east wall, north sink	3.2	-
020117.136A.108SK.02	Sink, room 108, east wall, south sink	12	-
020117.136A.108SK.03	Sink, room 108, south sink	2	-
020117.136A.108SK.04	Sink, room 108, west wall	1.7	-
020117.136A.109DF.01	Drinking fountain, room 109	0.8	-
020117.136A.A15SK.01	Sink, room A15	1	-
020117.136A.A15DF.01	Drinking fountain, room A15	ND	-
020117.136A.A14SK.01	Sink, room A14	0.67	-
020117.136A.A14DF.01	Drinking fountain, room A14	ND	-
020117.136A.A13SK.01	Sink, room A13	ND	-
020117.136A.A13DF.01	Drinking fountain, room A13	ND	-
020117.136A.A21SK.01	Sink, room A21	ND	-
020117.136A.A21DF.01	Drinking fountain, room A21	ND	-
020117.136A.A20SK.01	Sink, room A20	ND	-
020117.136A.A20DF.01	Drinking fountain, room A20	ND	-
020117.136A.A19SK.01	Sink, room A19	1.3	-
020117.136A.A19DF.01	Drinking fountain, room A19	0.6	-
020117.136A.A12SK.01	Sink, room A12	ND	-
020117.136A.A12DF.01	Drinking fountain, room A12	ND	-
020117.136A.A11SK.01	Sink, room A11	0.5	-
020117.136A.A11DF.01	Drinking fountain, room A11	ND	-
020117.136A.A10SK.01	Sink, room A10	0.53	-
020117.136A.A10DF.01	Drinking fountain, room A10	0.59	-
020117.136A.A9SK.01	Sink, room A9	1	-
020117.136A.A9DF.01	Drinking fountain, room A9	0.65	-
020117.136A.A8SK.01	Sink, room A8	0.6	-
020117.136A.A8DF.01	Drinking fountain, room A8	0.62	-
020117.136A.A2SK.01	Sink, room A2	ND	-
020117.136A.A2DF.01	Drinking fountain, room A2	ND	-
020117.136A.ZSK.01	Sink, room Z	13	-
020117.136A.ZDF.01	Drinking fountain, room Z, currently 3rd grade class	16	Taken Offline
020117.136A.YSK.01	Sink, room Y	10	-
020117.136A.YDF.01	Drinking fountain, room Y	5.7	-

## Water Sampling Results

### Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above  
 ND: Non-detect (below detection limit) | PPB: Parts per Billion

**School Name** Mountain View ES

Sample ID	Sample Description	Lead Result	Action Taken
		in PPB	
020117.136A.XSK.01	Sink, room X	3.4	-
020117.136A.XDF.01	Drinking fountain, room X	2.6	-
020117.136A.WSK.01	Sink, room W	6.2	-
020117.136A.WDF.01	Drinking fountain, room W	4.8	-
020117.136A.VSK.01	Sink, room V	6.6	-
020117.136A.VDF.01	Drinking fountain, room V	3.3	-
020117.136A.USK.01	Sink, room U	1.6	-
020117.136A.UDF.01	Drinking fountain, room U	1.7	-
020117.136A.TSK.01	Sink, room T	4.7	-
020117.136A.TDF.01	Drinking fountain, room T	2.8	-
020117.136A.SSK.01	Sink, room S	4	-
020117.136A.SDF.01	Drinking fountain, room S	2.6	-
020117.136A.RSK.01	Sink, room R	7.5	-
020117.136A.RDF.01	Drinking fountain, room R	6.7	-
020117.136A.QSK.01	Sink, room Q	1.8	-
020117.136A.QDF.01	Drinking fountain, room Q	1.7	-
020117.136A.PSK.01	Sink, room P, book room	34	Taken Offline
020117.136A.PDF.01	Drinking fountain, room P, book room	18	Taken Offline
020117.136A.NSK.01	Sink, room N	11	-
020117.136A.NDF.01	Drinking fountain, room N, instructional coach office	16	Taken Offline
020117.136A.MSK.01	Sink, room M	2.2	-
020117.136A.MDF.01	Drinking fountain, room M	1.5	-
020117.136A.LSK.01	Sink, room L	7.8	-
020117.136A.LDF.01	Drinking fountain, room L	11	-
020117.136A.KSK.01	Sink, room K, currently K-lab	290	Taken Offline
020117.136A.KDF.01	Drinking fountain, room K, currently K-lab	24	Taken Offline
020117.136A.JSK.01	Sink, room J	7.7	-
020117.136A.JDF.01	Drinking fountain, room J	2.7	-
020117.136A.ISK.01	Sink, room I	5.6	-
020117.136A.IDF.01	Drinking fountain, room I	3.5	-
020117.136A.HSK.01	Sink, room H	0.84	-
020117.136A.GSK.01	Sink, room G	2.9	-
020117.136A.GDF.01	Drinking fountain, room G	3.5	-
020117.136A.FSK.01	Sink, room F	1.4	-
020117.136A.FDF.01	Drinking fountain, room F	1.6	-
020117.136A.ESK.01	Sink, room E	5.8	-
020117.136A.EDF.01	Drinking fountain, room E	0.71	-
020117.136A.DSK.01	Sink, room D	1.9	-
020117.136A.DDF.01	Drinking fountain, room D	1.2	-
020117.136A.CSK.01	Sink, room C	3.3	-
020117.136A.CDF.01	Drinking fountain, room C	2.8	-
020117.136A.BSK.01	Sink, room B	1.8	-

## Water Sampling Results

**Report Legend:**

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

**School Name** Mountain View ES

<u>Sample ID</u>	<u>Sample Description</u>	<u>Lead Result</u> <u>in</u> <u>PPB</u>	<u>Action Taken</u>
020117.136A.BDF.01	Drinking fountain, room B	6.7 -	
020117.136A.ASK.01	Sink, room A	1.6 -	
020117.136A.ADF.01	Drinking fountain, room A	1.5 -	
020117.136A.AASK.01	Sink, room AA	3.4 -	
020117.136A.AADF.01	Drinking fountain, room AA	0.75 -	
020117.136A.110DF.01	Drinking fountain, room 110, right side	ND	-
020117.136A.110DF.02	Drinking fountain, room 110, left side	ND	-
020117.136A.110BSK.01	Sink, room 110B	1.4 -	

# Resultados de las Muestras de Agua

## Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

### Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

### Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

### Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

### Action = Acción

Taken offline = Desconectado/a