

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **STEM Lab**

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
Initial Sample	030917.509A.A113SK.01	Sink, room A113	8.7	-	-	1
	030917.509A.A122SK.01	Sink, room A122	3.6	-	-	1
	030917.509A.A132SK.01	Sink, room A132	1.2	-	-	1
	030917.509A.B202SK.01	Sink, room B202, south wall, east side, currently the Lego lab	17	Taken offline	-	1
	030917.509A.B202SK.02	Sink, room B202, south wall, west side, currently the Lego lab	130	Taken offline	-	1
	030917.509A.B204SK.01	Sink, room B204	1.7	-	-	1
	030917.509A.B215SK.01	Sink, room B215, north wall, east side	3.7	-	-	1
	030917.509A.B215SK.02	Sink, room B215, north wall, west side	2.4	-	-	1
	030917.509A.C100DF.01	Drinking fountain, corridor C100, south wall, west end, bottom	ND	-	-	1
	030917.509A.C100DF.02	Drinking fountain, corridor C100, south wall, west end, upper	ND	-	-	1
	030917.509A.C100DF.03	Drinking fountain, corridor C100, south wall, west end, lower	ND	-	-	1
	030917.509A.C100DF.04	Drinking fountain, corridor C100, south wall, east end, left side	1.4	-	-	1
	030917.509A.C100DF.05	Drinking fountain, corridor C100, south wall, east end, right side	1.9	-	-	1
	030917.509A.C103SK.01	Sink, room C103	5.5	-	-	1
	030917.509A.C107DF.01	Drinking fountain, room C107	8.3	-	-	1
	030917.509A.C116SK.01	Sink, room C116, currently an intermediate tech lab	190	Taken offline	-	1
	030917.509A.C200DF.01	Drinking fountain, corridor C200, south wall, east end, main	24	Taken offline	-	1
	030917.509A.C200DF.02	Drinking fountain, corridor C200, south wall, middle	1.6	-	-	1
	030917.509A.C200DF.03	Drinking fountain, corridor C200, south wall, west end, main	19	Taken offline	-	1
	030917.509A.C207SK.01	Sink, room C207, south wall, right side sink	3.1	-	-	1
	030917.509A.C207SK.02	Sink, room C207, south wall, middle sink	2.8	-	-	1
	030917.509A.C207SK.03	Sink, room C207, south wall, left side sink	1.4	-	-	1
	030917.509A.C213SK.01	Sink, room C213	10	-	-	1
	030917.509A.D100DF.01	Drinking fountain, corridor D100, north wall, west end, left side	0.92	-	-	1
	030917.509A.D100DF.02	Drinking fountain, corridor D100, north wall, west end, right side	1.1	-	-	1
	030917.509A.D100DF.03	Drinking fountain, corridor D100, north wall, east end, left side	0.61	-	-	1
	030917.509A.D100DF.04	Drinking fountain, corridor D100, north wall, east end, right side	0.65	-	-	1
	030917.509A.D200DF.01	Drinking fountain, corridor D200, north wall, west end	13	-	-	1
	030917.509A.D200DF.02	Drinking fountain, corridor D200, north wall, middle	5.1	-	-	1
	030917.509A.D200DF.03	Drinking fountain, corridor D200, north wall, east end	13	-	-	1
	030917.509A.E205SK.01	Sink, room E205	3.3	-	-	1
	030917.509A.E211SK.01	Sink, room E211	7.9	-	-	1
	030917.509A.F105SK.01	Sink, room F105	0.79	-	-	1
	030917.509A.F120DF.01	Drinking fountain, room F120	2.8	-	-	1
	030917.509A.F137SK.01	Sink, room F137, south wall, left side sink	4.3	-	-	1
	030917.509A.F137SK.02	Sink, room F137, south wall, right side sink	9.6	-	-	1
	030917.509A.F137SK.03	Sink, room F137, west wall	7.3	-	-	1
	030917.509A.F137SK.04	Sink, room F137, north end, south side of wall	2.7	-	-	1
	030917.509A.F137SK.05	Sink, room F137, NE sink	7.8	-	-	1
	030917.509A.F151DF.01	Drinking fountain, room F151	3.8	-	-	1
	030917.509A.F160DF.01	Drinking fountain, corridor F160, bottle fill station	ND	-	-	1
	030917.509A.F160DF.02	Drinking fountain, corridor F160, bubbler	ND	-	-	1
	030917.509A.F166SK.01	Sink, room F166	ND	-	-	1
	030917.509A.G104DF.01	Drinking fountain, room G105	5.4	-	-	1
	030917.509A.G109SK.01	Drinking fountain, room G109	3.7	-	-	1
	030917.509A.G113SK.01	Sink, room G113	5.1	-	-	1
	030917.509A.G120DF.01	Drinking fountain, room G120	3.4	-	-	1
	030917.509A.H100DF.01	Drinking fountain, corridor H100, south wall, west end	2.1	-	-	1
	030917.509A.H112SK.01	Sink, room H112	ND	-	-	1
	030917.509A.H114SK.01	Sink, room H114, north wall, right side	1.2	-	-	1
	030917.509A.H114SK.02	Sink, room H114, north wall, left side	0.9	-	-	1
	030917.509A.H114SK.03	Sink, room H114, east wall	5.8	-	-	1
	030917.509A.H120DF.01	(blank)	1.4	-	-	1
	030917.509A.H122SK.01	Sink, room H122	1.1	-	-	1

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name STEM Lab

<u>Sample Type</u>	<u>Sample ID</u>	<u>Sample Description</u>	<u>Lead Result in PPB</u>	<u>Action Taken</u>	<u>Back in Service Date</u>	<u>Sample Count</u>
	030917.509A.H127SK.01	Sink, room H127	ND	-	-	1
	030917.509A.H129SK.01	Sink, room H129	ND	-	-	1
Initial Sample Total						56

Resultados de las Muestras de Agua

Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

Action = Acción

Taken offline = Desconectado/a