

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Horizon HS**

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
Initial Sample	042517.312A.A0101DF.01	Drinking fountain, room A0101	5.2	-	-	1
	042517.312A.A0101SK.01	Sink, room A0101	1	-	-	1
	042517.312A.A100DF.01	Drinking fountain, corridor A100, bottom of stairway	ND	-	-	1
	042517.312A.A100DF.02	Drinking fountain, corridor A100, bottom of stairway, bottl	ND	-	-	1
	042517.312A.B0203SK.01	Sink, room B0203	4.7	-	-	1
	042517.312A.B0209SK.01	Sink, room B0209	6	-	-	1
	042517.312A.B0224SK.01	Sink, room B0224, teacher work room	16	Taken offline	-	1
	042517.312A.B0231SK.01	Sink, room B0231	12	-	-	1
	042517.312A.B0245SK.01	Sink, room B0245	6.7	-	-	1
	042517.312A.C101DF.01	Drinking fountain, hallway C101	ND	-	-	1
	042517.312A.C2203SK.01	Sink, room M230	4.1	-	-	1
	042517.312A.D101DF.01	Drinking fountain, hallway D101, east wall	ND	-	-	1
	042517.312A.D101DF.02	Drinking fountain, hallway D101, east wall, bottle fill statio	ND	-	-	1
	042517.312A.E0507SK.01	Sink, room E0507	13	-	-	1
	042517.312A.F0603SK.01	Sink, room F0603	1	-	-	1
	042517.312A.F0605ASK.01	Sink, room F0605A	10	-	-	1
	042517.312A.F0605SK.01	Sink, room F0605	4.8	-	-	1
	042517.312A.F0607SK.01	Sink, room F0607, west wall, left side SK	4.4	-	-	1
	042517.312A.F0607SK.02	Sink, room F0607, west wall, middle SK	2.8	-	-	1
	042517.312A.F0607SK.03	Sink, room F0607, west wall, right side SK	3.8	-	-	1
	042517.312A.F0607SK.04	Sink, room F0607, east wall, left side SK	4.7	-	-	1
	042517.312A.F0607SK.05	Sink, room F0607, east wall, middle SK	3.5	-	-	1
	042517.312A.F0607SK.06	Sink, room F0607, east wall, right side SK	2.5	-	-	1
	042517.312A.F0607SK.07	Sink, room F0607, south wall	12	-	-	1
	042517.312A.F0610SK.01	Sink, room F0610, pre-school classroom	39	Taken offline	-	1
	042517.312A.F0611ASK.01	Sink, room F0611A, east wall	5.7	-	-	1
	042517.312A.F0611ASK.02	Sink, room F0611A, south wall	5.6	-	-	1
	042517.312A.F0611SK.01	Sink, room F0611, west wall, left side SK	7.1	-	-	1
	042517.312A.F0611SK.02	Sink, room F0611, west wall, right side SK, pre-school class	22	Taken offline	-	1
	042517.312A.G0701SK.01	Sink, room G0701	8.5	-	-	1
	042517.312A.G0704SK.01	Sink, room G0704, west wall, left side SK	4.4	-	-	1
	042517.312A.G0704SK.02	Sink, room G0704, west wall, right side SK	3.9	-	-	1
	042517.312A.G0704SK.03	Sink, room G0704, north wall, left side SK	4.1	-	-	1
	042517.312A.G0704SK.04	Sink, room G0704, north wall, right side SK	1.7	-	-	1
	042517.312A.G0709SK.01	Sink, room G0709, east side of room, right SK	0.92	-	-	1
	042517.312A.G0709SK.02	Sink, room G0709, east side of room, left SK	1	-	-	1
	042517.312A.G0713SK.01	Sink, room G0713, west side of room, left side SK	2.7	-	-	1
	042517.312A.G0713SK.02	Sink, room G0713, west side of room, right side SK	1.2	-	-	1
	042517.312A.G102DF.01	Drinking fountain, room G102	ND	-	-	1
	042517.312A.G152DF.01	Drinking fountain, corridor G152, west end, left side DF	ND	-	-	1
	042517.312A.G152DF.02	Drinking fountain, corridor G152, west end, bottle fill static	ND	-	-	1
	042517.312A.G152DF.03	Drinking fountain, corridor G152, east end	ND	-	-	1
	042517.312A.G164DF.01	Drinking fountain, room G164, north wall, left side DF	ND	-	-	1
	042517.312A.G164DF.02	Drinking fountain, room G164, north wall, right side DF	4.3	-	-	1
	042517.312A.G165SK.01	Sink, room G165	4.2	-	-	1
	042517.312A.G168SK.01	Sink, room G168	2	-	-	1
	042517.312A.G169SK.01	Sink, room G169	2	-	-	1
	042517.312A.G62DF.01	Drinking fountain, room G62, south wall, left side DF	1.7	-	-	1
	042517.312A.G62DF.02	Drinking fountain, room G62, south wall, right side DF	1.5	-	-	1
	042517.312A.G62DF.03	Drinking fountain, room G62, gymnasium loft	1.1	-	-	1
	042517.312A.H0800SK.01	Sink, room H0800	2.2	-	-	1
	042517.312A.H0802DF.01	Drinking fountain, room H0802	0.53	-	-	1
	042517.312A.H0810SK.01	Sink, room H0810, attached DF does not work	ND	-	-	1
	042517.312A.I101DF.01	Drinking fountain, room I101, NE corner, right side DF	1.4	-	-	1
	042517.312A.I101DF.02	Drinking fountain, room I101, NE corner, left side DF	1.3	-	-	1
	042517.312A.I101DF.03	Drinking fountain, room I101, NW corner, right side DF	1.1	-	-	1
	042517.312A.I101DF.04	Drinking fountain, room I101, NW corner, left side DF	1.1	-	-	1
	042517.312A.J1001SK.01	Sink, room J1001, east wall	2.8	-	-	1
	042517.312A.J1001SK.02	Sink, room J1001, east end of middle island	5.3	-	-	1
	042517.312A.J1001SK.03	Sink, room J1001, south side of east partition wall	3.7	-	-	1

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name **Horizon HS**

Sample Type	Sample ID	Sample Description	Lead Result	Action Taken	Back in	Sample Count
			in PPB		Service Date	
	042517.312A.J1001SK.04	Sink, room J1001, inside south storage area	1.5	-	-	1
	042517.312A.J1001SK.05	Sink, room J1001, outside J1005, right side SK	2.6	-	-	1
	042517.312A.J1001SK.06	Sink, room J1001, outside J1005, left side SK	3.9	-	-	1
	042517.312A.J1001SK.07	Sink, room J1001, outside J1006, right side SK	1	-	-	1
	042517.312A.J1001SK.08	Sink, room J1001, outside J1006, left side SK	ND	-	-	1
	042517.312A.J1001SK.09	Sink, room J1001, outside north wall of J1005	ND	-	-	1
	042517.312A.J1001SK.10	Sink, room J1001, north side of east partition, right side kit	17	Taken offline	-	1
	042517.312A.J1001SK.11	Sink, room J1001, north side of east partition, left side kit	230	Taken offline	-	1
	042517.312A.J1010SK.01	Sink, room J1010	32	Taken offline	-	1
	042517.312A.K1101SK.01	Sink, room K1101	7.7	-	-	1
	042517.312A.K1103DF.01	Drinking fountain, outside G59, north wall, left side DF	1.7	-	-	1
	042517.312A.K1103DF.02	Drinking fountain, outside G59, north wall, right side DF	2.9	-	-	1
	042517.312A.K1103DF.03	Drinking fountain, outside G59, east side of room	1.2	-	-	1
	042517.312A.K1113DF.01	Drinking fountain, room K1113, west side, south partition v	1.3	-	-	1
	042517.312A.K1113DF.02	Drinking fountain, room K1113, west side, south partition v	13	-	-	1
	042517.312A.K1113DF.03	Drinking fountain, room K1113, east side of room	13	-	-	1
	042517.312A.K201DF.01	Drinking fountain, hallway K201	ND	-	-	1
	042517.312A.M201DF.01	Drinking fountain, hallway M201	ND	-	-	1
	042517.312A.M2305ASK.01	Sink, room M230A	9.1	-	-	1
	042517.312A.M2305SK.01	Sink, room M230	13	-	-	1
	042517.312A.N2403SK.01	Sink, room N2403	5.2	-	-	1
	042517.312A.O201DF.01	Drinking fountain, hallway O0201, east wall, left side DF	ND	-	-	1
	042517.312A.O201DF.02	Drinking fountain, hallway O0201, east wall, bottle fill stati	ND	-	-	1
	042517.312A.P2602SK.01	Sink, room P2603	3.5	-	-	1
	042517.312A.P2603SK.01	Sink, room P2603	6.8	-	-	1
Initial Sample Total						85

Resultados de las Muestras de Agua

Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

Action = Acción

Taken offline = Desconectado/a