

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Northglenn HS

Sample Type	Sample ID	Sample Description	Lead Result	Action Taken	Back in	Sample Count
			in PPB		Service Date	
Initial Sample	041817.332A.101BSK.01	Sink, room 101B	5.1	-	-	1
	041817.332A.101CSK.01	Sink, room 101C, school clinic	20	Taken offline	-	1
	041817.332A.105SK.01	Sink, room 105, north wall, left side SK	1.3	-	-	1
	041817.332A.105SK.02	Sink, room 105, north wall, right side SK	0.52	-	-	1
	041817.332A.105SK.03	Sink, room 105, south wall, left side SK	2.2	-	-	1
	041817.332A.105SK.04	Sink, room 105, south wall, right side SK	0.79	-	-	1
	041817.332A.105SK.05	Sink, room 105, north wall, middle partition	1.2	-	-	1
	041817.332A.115CSK.01	Sink, room 115C	0.95	-	-	1
	041817.332A.116SK.01	Sink, room 116	5	-	-	1
	041817.332A.119SK.01	Sink, room 119	0.79	-	-	1
	041817.332A.121SK.01	Sink, room 121, west wall, left side SK	ND	-	-	1
	041817.332A.121SK.02	Sink, room 121, west wall, right side SK	2.1	-	-	1
	041817.332A.121SK.03	Sink, room 105, north wall, left side SK	ND	-	-	1
	041817.332A.121SK.04	Sink, room 105, north wall, middle left SK	5.2	-	-	1
	041817.332A.121SK.05	Sink, room 105, north wall, middle right SK	ND	-	-	1
	041817.332A.121SK.06	Sink, room 105, north wall, right side SK	ND	-	-	1
	041817.332A.121SK.07	Sink, room 105, middle of room	ND	-	-	1
	041817.332A.121SK.08	Sink, room 105, inside east storage room	ND	-	-	1
	041817.332A.132DF.01	Drinking fountain, hallway 132, south wall, west end	9	-	-	1
	041817.332A.132DF.02	Drinking fountain, hallway 132, north wall, east end	ND	-	-	1
	041817.332A.132DF.03	Drinking fountain, hallway 132, north wall, east end, bottle	ND	-	-	1
	041817.332A.134DF.01	Drinking fountain, hallway 134, south wall	2.3	-	-	1
	041817.332A.134DF.02	Drinking fountain, hallway 134, north wall	5.4	-	-	1
	041817.332A.148DF.01	Drinking fountain, hallway 148, east wall, left side DF	8	-	-	1
	041817.332A.148DF.02	Drinking fountain, hallway 148, east wall, right side DF	5.6	-	-	1
	041817.332A.150DF.01	Drinking fountain, hallway 150, west wall, left side DF	6.5	-	-	1
	041817.332A.150DF.02	Drinking fountain, hallway 150, west wall, left side DF	2.8	-	-	1
	041817.332A.200DF.01	Drinking fountain, hallway 200, east end of hall, left side DF	11	-	-	1
	041817.332A.200DF.02	Drinking fountain, hallway 200, east end of hall, right side DF	18	Taken offline	-	1
	041817.332A.211SK.01	Sink, room 211	7.8	-	-	1
	041817.332A.222SK.01	Sink, room 222	8.6	-	-	1
	041817.332A.224SK.01	Sink, room 224, east wall, north end	1.4	-	-	1
	041817.332A.224SK.02	Sink, room 224, east wall, south end, book storage room	44	Taken offline	-	1
	041817.332A.242DF.01	Drinking fountain, room 242	1.5	-	-	1
	041817.332A.250DF.01	Drinking fountain, hallway 250, west wall, middle of hall, left	5.2	-	-	1
	041817.332A.250DF.02	Drinking fountain, hallway 250, west wall, middle of hall, right	ND	-	-	1
	041817.332A.253DF.01	Drinking fountain, hallway 253	6.2	-	-	1
	041817.332A.280DF.01	Drinking fountain, corridor 280, north end, west wall, left side	ND	-	-	1
	041817.332A.280DF.02	Drinking fountain, corridor 280, north end, west wall, right side	1.3	-	-	1
	041817.332A.280DF.03	Drinking fountain, corridor 280, north end, west wall, bottle	6.2	-	-	1
	041817.332A.280DF.04	Drinking fountain, corridor 280, south end, west wall, left side	7.8	-	-	1
	041817.332A.280DF.05	Drinking fountain, corridor 280, south end, west wall, right side	7.4	-	-	1
	041817.332A.313ASK.01	Sink, room 313A, SE corner	3.8	-	-	1
	041817.332A.313ASK.02	Sink, room 313A, east wall	0.92	-	-	1
041817.332A.313ASK.03	Sink, room 313A, north wall	4.1	-	-	1	
041817.332A.313GSK.01	Sink, room 313G	4.5	-	-	1	
041817.332A.315JSK.01	Sink, room 315J	9.5	-	-	1	
041817.332A.318SK.01	Sink, room 318	3.4	-	-	1	
041817.332A.320BSK.01	Sink, room 320B	1.9	-	-	1	
041817.332A.322SK.01	Sink, room 322, south wall, left side SK, Mrs. Shockley's room	16	Taken offline	-	1	
041817.332A.322SK.02	Sink, room 322, south wall, right side SK	13	-	-	1	
041817.332A.322SK.03	Sink, room 322, north wall	ND	-	-	1	
041817.332A.324SK.01	Sink, room 324	1.1	-	-	1	
041817.332A.326SK.01	Sink, room 326, west wall	2.8	-	-	1	
041817.332A.326SK.02	Sink, room 326, north wall, left side sink	0.97	-	-	1	
041817.332A.326SK.03	Sink, room 326, north wall, right side sink	1.3	-	-	1	
041817.332A.328SK.01	Sink, room 328, north wall, left side sink	ND	-	-	1	
041817.332A.328SK.02	Sink, room 328, north wall, right side sink	ND	-	-	1	
041817.332A.358DF.01	Drinking fountain, hallway 358, east wall	2	-	-	1	
041817.332A.360DF.01	Drinking fountain, auditorium lobby 360, north wall, left side	ND	-	-	1	

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Northglenn HS

Sample Type	Sample ID	Sample Description	Lead Result	Action Taken	Back in	Sample
			in PPB		Service Date	
	041817.332A.360DF.02	Drinking fountain, auditorium lobby 360, north wall, right side	ND	-	-	1
	041817.332A.365DF.01	Drinking fountain, hallway 365, north wall	ND	-	-	1
	041817.332A.380DF.01	Drinking fountain, room 380	0.57	-	-	1
	041817.332A.404ASK.01	Sink, room 404A	0.88	-	-	1
	041817.332A.412SK.01	Sink, room 412	1.4	-	-	1
	041817.332A.440DF.01	Drinking fountain, hallway 440	0.85	-	-	1
	041817.332A.500DF.01	Drinking fountain, corridor 500, west wall, left side DF	ND	-	-	1
	041817.332A.500DF.02	Drinking fountain, corridor 500, west wall, right side DF	ND	-	-	1
	041817.332A.500DF.03	Drinking fountain, corridor 500, west wall, bottle fill station	ND	-	-	1
	041817.332A.502DF.01	Drinking fountain, room 502, Training room	16	Taken offline	-	1
	041817.332A.502SK.01	Sink, room 502	0.75	-	-	1
	041817.332A.520DF.01	Drinking fountain, north wall partition	2.9	-	-	1
	041817.332A.520DF.02	Drinking fountain, east wall, outside 512	14	-	-	1
	041817.332A.530DF.01	Drinking fountain, room 530, north wall, left side DF	ND	-	-	1
	041817.332A.530DF.02	Drinking fountain, room 530, north wall, right side DF	ND	-	-	1
	041817.332A.535DF.01	Drinking fountain, room 535	ND	-	-	1
	041817.332A.540DF.01	Drinking fountain, room 540	1.8	-	-	1
	041817.332A.541SK.01	Sink, room 541	0.5	-	-	1
	041817.332A.543SK.01	Sink, room 543, girl's locker room lounge	130	Taken offline	-	1
	041817.332A.606ASK.01	Sink, room 606A	5.7	-	-	1
	041817.332A.617DF.01	Drinking fountain, room 617	ND	-	-	1
	041817.332A.621DF.01	Drinking fountain, corridor 621, left side DF	0.83	-	-	1
	041817.332A.621DF.02	Drinking fountain, corridor 621, right side DF	ND	-	-	1
	041817.332A.625SK.01	Sink, room 625	ND	-	-	1
	041817.332A.650DF.01	Drinking fountain, corridor 650, south end, east wall	ND	-	-	1
	041817.332A.650DF.02	Drinking fountain, corridor 650, north end, east wall	ND	-	-	1
	041817.332A.705DF.01	Drinking fountain, room 705	ND	-	-	1
	041817.332A.900DF.01	Drinking fountain, room 900	1	-	-	1
	041817.332A.907SK.01	Sink, room 907	ND	-	-	1
	041817.332A.909SK.01	Sink, room 909	ND	-	-	1
	041817.332A.911SK.01	Sink, room 911	5.5	-	-	1
Initial Sample Total						91

Resultados de las Muestras de Agua

Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

Action = Acción

Taken offline = Desconectado/a