

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Thornton HS

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
Initial Sample	042017.352A.100DF.01	Drinking fountain, room 100	2.3	-	-	1
	042017.352A.100DSK.01	Sink, room 100D, south side of room	1.3	-	-	1
	042017.352A.100DSK.02	Sink, room 100D, north side of room	2.5	-	-	1
	042017.352A.100PSK.01	Sink, room 100P, NW corner	1.2	-	-	1
	042017.352A.100PSK.02	Sink, room 100P, north side of south island	2	-	-	1
	042017.352A.100PSK.03	Sink, room 100P, east wall, right side SK	1.6	-	-	1
	042017.352A.100PSK.04	Sink, room 100P, east wall, left side SK	1.7	-	-	1
	042017.352A.100PSK.05	Sink, room 100P, east side of middle island	3.7	-	-	1
	042017.352A.100PSK.06	Sink, room 100P, north island	7.5	-	-	1
	042017.352A.100PSK.07	Sink, room 100P, south wall	1.9	-	-	1
	042017.352A.100PSK.08	Sink, room 100P, SE corner	1.1	-	-	1
	042017.352A.101DF.01	Drinking fountain, room 101	1.1	-	-	1
	042017.352A.101HDF.01	Drinking fountain, room 101H	1.1	-	-	1
	042017.352A.103BSK.01	Sink, room 103B	1.5	-	-	1
	042017.352A.103DF.01	Drinking fountain, room 103	1.1	-	-	1
	042017.352A.104DF.01	Drinking fountain, room 104, east wall, north end	0.93	-	-	1
	042017.352A.104DF.02	Drinking fountain, room 104, east wall, south end	1.8	-	-	1
	042017.352A.105SK.01	Sink, room 105	0.52	-	-	1
	042017.352A.110DF.01	Drinking fountain, room 110	0.7	-	-	1
	042017.352A.112DF.01	Drinking fountain, room 112	10	-	-	1
	042017.352A.112FSK.01	Sink, room 112F	3.1	-	-	1
	042017.352A.112HDF.01	Drinking fountain, room 112H	2.2	-	-	1
	042017.352A.204SK.01	Sink, room 204, middle of room	1.2	-	-	1
	042017.352A.204SK.02	Sink, room 204, east wall	0.6	-	-	1
	042017.352A.208ASK.01	Sink, room 208A	7.8	-	-	1
	042017.352A.208SK.01	Sink, room 208, NE corner	0.62	-	-	1
	042017.352A.208SK.02	Sink, room 208, east wall, north end	0.91	-	-	1
	042017.352A.208SK.03	Sink, room 208, east wall, south end	ND	-	-	1
	042017.352A.208SK.04	Sink, room 208, SE corner	0.78	-	-	1
	042017.352A.208SK.05	Sink, room 208, west wall, south end	0.56	-	-	1
	042017.352A.208SK.06	Sink, room 208, west wall, middle	0.92	-	-	1
	042017.352A.208SK.07	Sink, room 208, west wall, north end	1	-	-	1
	042017.352A.210SK.01	Sink, room 210	ND	-	-	1
	042017.352A.213BSK.01	Sink, room 213B	1.2	-	-	1
	042017.352A.220SK.01	Sink, room 220, middle island	0.73	-	-	1
	042017.352A.220SK.02	Sink, room 220, middle island	0.76	-	-	1
	042017.352A.220SK.03	Sink, room 220, middle island	0.88	-	-	1
	042017.352A.220SK.04	Sink, room 220, middle island	0.8	-	-	1
	042017.352A.220SK.05	Sink, room 220, middle island	0.64	-	-	1
	042017.352A.220SK.06	Sink, room 220, middle island	0.52	-	-	1
	042017.352A.221SK.01	Sink, room 221, north wall, right side SK	1.6	-	-	1
	042017.352A.221SK.02	Sink, room 221, north wall, left side SK	0.58	-	-	1
	042017.352A.222SK.01	Sink, room 222, south wall, left side SK	1.9	-	-	1
	042017.352A.222SK.02	Sink, room 222, south wall, right side SK	0.84	-	-	1
	042017.352A.230SK.01	Sink, room 230	4.2	-	-	1
	042017.352A.234SK.01	Sink, room 234	2.5	-	-	1
042017.352A.237SK.01	Sink, room 237, ISS classroom	57	Taken offline	-	1	
042017.352A.240DF.01	Drinking fountain, room 240	6.1	-	-	1	
042017.352A.240SK.01	Sink, room 240	8.4	-	-	1	
042017.352A.300HSK.01	Sink, room 300H	1.7	-	-	1	
042017.352A.313SK.01	Sink, room 313	1.6	-	-	1	
042017.352A.318ASK.01	Sink, room 318A	0.82	-	-	1	
042017.352A.400SK.01	Sink, room 400	1.6	-	-	1	
042017.352A.401SK.01	Sink, room 401	2.2	-	-	1	
042017.352A.402ASK.01	Sink, room 402A, right side SK, snack bar	74	Taken offline	-	1	
042017.352A.402ASK.02	Sink, room 402A, left side SK, snack bar	60	Taken offline	-	1	
042017.352A.402SK.01	Sink, room 402	3.1	-	-	1	
042017.352A.403SK.01	Sink, room 403	3.4	-	-	1	
042017.352A.404SK.01	Sink, room 404	3.1	-	-	1	
042017.352A.416SK.01	Sink, room 416	4	-	-	1	

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Thornton HS

Sample Type	Sample ID	Sample Description	Lead Result in PPB	Action Taken	Back in Service Date	Sample Count
	042017.352A.419ASK.01	Sink, room 419A, book room	840	Taken offline	-	1
	042017.352A.420SK.01	Sink, room 420	0.87	-	-	1
	042017.352A.423SK.01	Sink, room 423, TV room	24	Taken offline	-	1
	042017.352A.429SK.01	Sink, room 429	6.2	-	-	1
	042017.352A.430SK.01	Sink, room 430, Language Arts classroom	48	Taken offline	-	1
	042017.352A.431ASK.01	Sink, room 431A, Language Arts office	69	Taken offline	-	1
	042017.352A.505DF.01	Drinking fountain, hallway 505, east hallway, left side DF	3	-	-	1
	042017.352A.505DF.02	Drinking fountain, hallway 505, east hallway, right side DF	2.9	-	-	1
	042017.352A.505DF.03	Drinking fountain, hallway 505, west hallway, left side DF	ND	-	-	1
	042017.352A.505DF.04	Drinking fountain, hallway 505, west hallway, right side DF	ND	-	-	1
	042017.352A.528ASK.01	Sink, hallway 528A	6.8	-	-	1
	042017.352A.530DF.01	Drinking fountain, hallway 530, east hallway, left side DF	2	-	-	1
	042017.352A.530DF.02	Drinking fountain, hallway 530, east hallway, right side DF	1.6	-	-	1
	042017.352A.530DF.03	Drinking fountain, hallway 530, west hallway, left side DF	1.3	-	-	1
	042017.352A.530DF.04	Drinking fountain, hallway 530, west hallway, right side DF	1	-	-	1
	042017.352A.A102DF.01	Drinking fountain, hallway A102, west wall, left side DF	2.8	-	-	1
	042017.352A.A102DF.02	Drinking fountain, hallway A102, west wall, right side DF	1.3	-	-	1
	042017.352A.B102DF.01	Drinking fountain, hallway D104, west wall, right side DF	0.57	-	-	1
		Drinking fountain, hallway B102, west wall, left side DF	0.76	-	-	1
	042017.352A.C109DF.01	Drinking fountain, hallway C109, west hallway, east wall, le	ND	-	-	1
	042017.352A.C109DF.02	Drinking fountain, hallway C109, west hallway, east wall, ri	ND	-	-	1
	042017.352A.C109DF.03	Drinking fountain, hallway C109, east hallway	3.6	-	-	1
	042017.352A.D104DF.01	Drinking fountain, hallway D104, west wall, left side DF	ND	-	-	1
	042017.352A.D104DF.02	Drinking fountain, hallway D104, west wall, right side DF	ND	-	-	1
	042017.352A.D104DF.03	Drinking fountain, hallway D104, west wall, bottle fill static	ND	-	-	1
	042017.352A.D120DF.01	Drinking fountain, hallway D120, west wall, left side DF	0.87	-	-	1
	042017.352A.D120DF.02	Drinking fountain, hallway D120, west wall, right side DF	0.67	-	-	1
	042017.352A.F128DF.01	Drinking fountain, room F128, south wall, left sideDF	ND	-	-	1
	042017.352A.F128DF.02	Drinking fountain, room F128, bottle fill station	ND	-	-	1
Initial Sample Total						89

Resultados de las Muestras de Agua

Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

Action = Acción

Taken offline = Desconectado/a