



Charles County Public Schools
P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646
Attention:

Monday, February 14, 2022
Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 60410.
Samples flushed by Martel on October 22, 2021, sampled by Martel on October 23, 2021.
Project Identification: MD HB 270
School: Westlake HS, PSC #08.031

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.


Project Manager



MARTEL NO. 60410 1 CLIENT SAMPLE IDENTIFICATION WHS-1-DC [water fountain--Kitchen] Sample Date/Time 10/23/2021 07:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2022 12:09 BJ

MARTEL NO. 60410 2 CLIENT SAMPLE IDENTIFICATION WHS-2-FC [Sink (near dishwasher) - Left fixture--Kitchen -] Sample Date/Time 10/23/2021 07:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 16:26 BJ

MARTEL NO. 60410 3 CLIENT SAMPLE IDENTIFICATION WHS-3-FC [Sink (near dishwasher) - Right fixture--Kitchen] Sample Date/Time 10/23/2021 07:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.01	ug/l	EPA .200.8	2	01/28/2022 12:11 BJ

MARTEL NO. 60410 4 CLIENT SAMPLE IDENTIFICATION WHS-4-IM [Ice Machine --Kitchen] Sample Date/Time 10/23/2021 07:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2022 12:14 BJ

MARTEL NO. 60410 5 CLIENT SAMPLE IDENTIFICATION WHS-5-FC [Sink - Left fixture--Kitchen - Left Fixture on 3] Sample Date/Time 10/23/2021 07:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 16:33 BJ

MARTEL NO. 60410 6 CLIENT SAMPLE IDENTIFICATION WHS-6-FC [Sink - Right fixture--Kitchen - Right Fixture on] Sample Date/Time 10/23/2021 07:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 16:36 BJ

MARTEL NO. 60410 7 CLIENT SAMPLE IDENTIFICATION WHS-7-FC [island sink - Left--Kitchen] Sample Date/Time 10/23/2021 07:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.32	ug/l	EPA .200.8	2	02/07/2022 16:38 BJ

MARTEL NO. 60410 8 CLIENT SAMPLE IDENTIFICATION WHS-8-FC [island sink (R)next to #5 & #6--Kitchen] Sample Date/Time 10/23/2021 07:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 16:41 BJ



MARTEL NO. 60410 9 CLIENT SAMPLE IDENTIFICATION WHS-9-KK [kettle L--Kitchen] Sample Date/Time 10/23/2021 07:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.07	ug/l	EPA .200.8	2	01/28/2022 12:16 BJ

MARTEL NO. 60410 10 CLIENT SAMPLE IDENTIFICATION WHS-10-KK [kettle R--Kitchen] Sample Date/Time 10/23/2021 07:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	not	working	EPA .200.8	2	/ /

MARTEL NO. 60410 11 CLIENT SAMPLE IDENTIFICATION WHS-11-FC [island sink next to kettle on right--Kitchen] Sample Date/Time 10/23/2021 07:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2022 12:19 BJ

MARTEL NO. 60410 12 CLIENT SAMPLE IDENTIFICATION WHS-12-FC [2 comp sink--Kitchen] Sample Date/Time 10/23/2021 07:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2022 12:21 BJ

MARTEL NO. 60410 13 CLIENT SAMPLE IDENTIFICATION WHS-13-DC [water fountain - Left--corridor] Sample Date/Time 10/23/2021 07:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 08:26 BJ

MARTEL NO. 60410 14 CLIENT SAMPLE IDENTIFICATION WHS-14-DC [water fountain - Right--corridor] Sample Date/Time 10/23/2021 07:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 08:38 BJ

MARTEL NO. 60410 15 CLIENT SAMPLE IDENTIFICATION WHS-15-FC [sink--nurse office] Sample Date/Time 10/23/2021 07:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.89	ug/l	EPA .200.8	2	02/07/2022 16:43 BJ

MARTEL NO. 60410 16 CLIENT SAMPLE IDENTIFICATION WHS-16-FC [sink--guidance office] Sample Date/Time 10/23/2021 07:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 16:46 BJ



MARTEL NO. 60410 17 CLIENT SAMPLE IDENTIFICATION WHS-17-DC [water fountain - Left--corridor] Sample Date/Time 10/23/2021 07:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 08:41 BJ

MARTEL NO. 60410 18 CLIENT SAMPLE IDENTIFICATION WHS-18-DC [water fountain - Right--corridor] Sample Date/Time 10/23/2021 07:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 08:43 BJ

MARTEL NO. 60410 19 CLIENT SAMPLE IDENTIFICATION WHS-19-DC [water fountain--chorus corridor] Sample Date/Time 10/23/2021 07:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 08:45 BJ

MARTEL NO. 60410 20 CLIENT SAMPLE IDENTIFICATION WHS-20-DC [water fountain - Left--corridor] Sample Date/Time 10/23/2021 07:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 16:48 BJ

MARTEL NO. 60410 21 CLIENT SAMPLE IDENTIFICATION WHS-21-DC [water fountain - Right--corridor] Sample Date/Time 10/23/2021 07:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 16:51 BJ

MARTEL NO. 60410 22 CLIENT SAMPLE IDENTIFICATION WHS-22-DC [water fountain--gym] Sample Date/Time 10/23/2021 07:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 16:53 BJ

MARTEL NO. 60410 23 CLIENT SAMPLE IDENTIFICATION WHS-23-DC [water fountain--gym] Sample Date/Time 10/23/2021 07:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 17:03 BJ

MARTEL NO. 60410 24 CLIENT SAMPLE IDENTIFICATION WHS-24-SG [cold tub hose--training room] Sample Date/Time 10/23/2021 07:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 08:48 BJ



MARTEL NO. 60410 25 CLIENT SAMPLE IDENTIFICATION WHS-25-IM [Ice Machine --training room] Sample Date/Time 10/23/2021 07:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 08:50 BJ

MARTEL NO. 60410 26 CLIENT SAMPLE IDENTIFICATION WHS-26-DC [water fountain--corridor] Sample Date/Time 10/23/2021 07:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 17:08 BJ

MARTEL NO. 60410 27 CLIENT SAMPLE IDENTIFICATION WHS-27-FC [sink--child development] Sample Date/Time 10/23/2021 07:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.88	ug/l*	EPA .200.8	2	02/09/2022 08:53 BJ

MARTEL NO. 60410 28 CLIENT SAMPLE IDENTIFICATION WHS-28-FC [sink - See map--food lab - home ec] Sample Date/Time 10/23/2021 07:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 08:55 BJ

MARTEL NO. 60410 29 CLIENT SAMPLE IDENTIFICATION WHS-29-FC [sink - See map--food lab - home ec] Sample Date/Time 10/23/2021 07:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 08:57 BJ

MARTEL NO. 60410 30 CLIENT SAMPLE IDENTIFICATION WHS-30-FC [sink - See map--food lab - home ec] Sample Date/Time 10/23/2021 07:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	292	ug/l*	EPA .200.8	2	02/09/2022 09:07 BJ

MARTEL NO. 60410 31 CLIENT SAMPLE IDENTIFICATION WHS-31-FC [sink - See map--food lab - home ec] Sample Date/Time 10/23/2021 07:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 09:12 BJ

MARTEL NO. 60410 32 CLIENT SAMPLE IDENTIFICATION WHS-32-FC [sink - See map--food lab - home ec] Sample Date/Time 10/23/2021 07:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 09:15 BJ



MARTEL NO. 60410 33 CLIENT SAMPLE IDENTIFICATION WHS-33-FC [sink - See map--food lab - home ec] Sample Date/Time 10/23/2021 07:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 17:11 BJ

MARTEL NO. 60410 34 CLIENT SAMPLE IDENTIFICATION WHS-34-FC [sink - See map--teachers lounge] Sample Date/Time 10/23/2021 07:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.47	ug/l	EPA .200.8	2	02/07/2022 17:13 BJ

MARTEL NO. 60410 35 CLIENT SAMPLE IDENTIFICATION WHS-35-DH [instant hot--teachers lounge] Sample Date/Time 10/23/2021 07:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 17:16 BJ

MARTEL NO. 60410 36 CLIENT SAMPLE IDENTIFICATION WHS-36-DC [water fountain--corridor - (2nd Floor)] Sample Date/Time 10/23/2021 07:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 17:18 BJ

MARTEL NO. 60410 37 CLIENT SAMPLE IDENTIFICATION WHS-37-DC [water fountain--media center - (2nd Floor)] Sample Date/Time 10/23/2021 07:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 09:17 BJ

MARTEL NO. 60410 38 CLIENT SAMPLE IDENTIFICATION WHS-38-DC [water fountain - Left--corridor - (2nd Floor)] Sample Date/Time 10/23/2021 07:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 09:19 BJ

MARTEL NO. 60410 39 CLIENT SAMPLE IDENTIFICATION WHS-39-DC [water fountain - Right--corridor - (2nd Floor)] Sample Date/Time 10/23/2021 07:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 09:22 BJ

MARTEL NO. 60410 40 CLIENT SAMPLE IDENTIFICATION WHS-40-FC [sink--teachers lounge - (2nd Floor)] Sample Date/Time 10/23/2021 07:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 09:24 BJ



MARTEL NO. 60410 41 CLIENT SAMPLE IDENTIFICATION WHS-41-DH [instant hot--teachers lounge - (2nd Floor)] Sample Date/Time 10/23/2021 07:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 09:27 BJ

MARTEL NO. 60410 42 CLIENT SAMPLE IDENTIFICATION WHS-42-DC [water fountain - Left--corridor - (2nd Floor)] Sample Date/Time 10/23/2021 07:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 09:29 BJ

MARTEL NO. 60410 43 CLIENT SAMPLE IDENTIFICATION WHS-43-DC [water fountain - Right--corridor - (2nd Floor)] Sample Date/Time 10/23/2021 07:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 17:21 BJ

MARTEL NO. 60410 44 CLIENT SAMPLE IDENTIFICATION WHS-44-DC [water fountain--corridor - (2nd Floor)] Sample Date/Time 10/23/2021 07:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/09/2022 09:31 BJ

MARTEL NO. 60410 45 CLIENT SAMPLE IDENTIFICATION WHS-45-FC [sink--CR 212 (Sp-ED) (2nd Floor) SOAR] Sample Date/Time 10/23/2021 07:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/11/2022 08:10 BJ

MARTEL NO. 60410 46 CLIENT SAMPLE IDENTIFICATION WHS-46-DH [instant hot--CR 212 (Sp-ED) (2nd Floor) SOAR] Sample Date/Time 10/23/2021 07:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 17:23 BJ

MARTEL NO. 60410 47 CLIENT SAMPLE IDENTIFICATION WHS-47-FC [sink--classroom 211 - (2nd Floor) - Sp.Ed.] Sample Date/Time 10/23/2021 07:59

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/11/2022 08:22 BJ

MARTEL NO. 60410 49 CLIENT SAMPLE IDENTIFICATION WHS-49-DC [water fountain--Girls Locker Room] Sample Date/Time 10/23/2021 07:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/11/2022 08:24 BJ



MARTEL NO. 60410 50 CLIENT SAMPLE IDENTIFICATION WHS-50-FC [sink--Classroom 104] Sample Date/Time 10/23/2021 07:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/11/2022 08:27 BJ

MARTEL NO. 60410 51 CLIENT SAMPLE IDENTIFICATION WHS-51-FC [sink--Classroom 106] Sample Date/Time 10/23/2021 07:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.45	ug/l*	EPA .200.8	2	02/11/2022 08:29 BJ

MARTEL NO. 60410 53 CLIENT SAMPLE IDENTIFICATION WHS-53-FC [sink--Inside Concession] Sample Date/Time 10/23/2021 07:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2022 17:26 BJ

MARTEL NO. 60410 54 CLIENT SAMPLE IDENTIFICATION WHS-54-DC [Water Fountain - outside--Outside concession st] Sample Date/Time 10/23/2021 07:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/11/2022 08:31 BJ

MARTEL NO. 60410 55 CLIENT SAMPLE IDENTIFICATION WHS-55-FC [Sink--Outside concession stand - see map] Sample Date/Time 10/23/2021 07:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.97	ug/l	EPA .200.8	2	02/11/2022 08:34 BJ

MARTEL NO. 60410 56 CLIENT SAMPLE IDENTIFICATION WHS-56-SG [Hose Bib--Outside concession stand - see map] Sample Date/Time 10/23/2021 07:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.22	ug/l	EPA .200.8	2	02/11/2022 08:36 BJ

MARTEL NO. 60410 57 CLIENT SAMPLE IDENTIFICATION WHS-57-FC [Sink--classroom 105 - Special Education] Sample Date/Time 10/23/2021 07:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/11/2022 08:38 BJ

MARTEL NO. 60410 58 CLIENT SAMPLE IDENTIFICATION WHS-58-FC [Sink--classroom 107 - Special Education] Sample Date/Time 10/23/2021 07:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.53	ug/l	EPA .200.8	2	02/11/2022 08:41 BJ



MARTEL NO. 60410	59	CLIENT SAMPLE IDENTIFICATION WHS-59-BU [Bottle Filler--Corridor]	Sample Date/Time 10/23/2021 07:59
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/11/2022 08:50 BJ

MARTEL NO. 60410	60	CLIENT SAMPLE IDENTIFICATION WHS-60-BU [Bottle Filler--Corridor]	Sample Date/Time 10/23/2021 07:40
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/11/2022 08:55 BJ

MARTEL NO. 60410	61	CLIENT SAMPLE IDENTIFICATION WHS-61-FC [Sink--Classroom 232 - Special Education]	Sample Date/Time 10/23/2021 08:00
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/11/2022 08:58 BJ

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 10/23/21 723 End Date/Time: 10/23/21 0800

Sampler/Relinquished By: [Signature] Received at Martel By: [Signature] Date/Time: 10/23/21 1000

58- Westlake HS PSC #08.031
3300 Middleton Road Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

10/22 Flush Martel NO: 60410

Martel #	Sample #	Location ID #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)</small>	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush Date	Sample Time
1	1	WHS-1-DC	water fountain	DC	Kitchen	C	✓	725
2	2	WHS-2-FC	Sink (near dishwasher) - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	✓	↓
3	3	WHS-3-FC	Sink (near dishwasher) - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	✓	726
4	4	WHS-4-IM	Ice Machine	IM	Kitchen	C	✓	↓
5	5	WHS-5-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	✓	727
6	6	WHS-6-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	✓	↓
7	7	WHS-7-FC	island sink - Left	FC	Kitchen	C	✓	↓
8	8	WHS-8-FC	island sink (R)next to #5 & #6	FC	Kitchen	C	✓	728
9	9	WHS-9-KK	kettle L	KK	Kitchen	C	✓	↓
10	10	WHS-10-KK	kettle R	KK	Kitchen	C		NW
11	11	WHS-11-FC	island sink next to kettle on right	FC	Kitchen	C	✓	729
12	12	WHS-12-FC	2 comp sink	FC	Kitchen	C	✓	↓
13	13	WHS-13-DC	water fountain - Left	DC	corridor	C	✓	730
14	14	WHS-14-DC	water fountain - Right	DC	corridor	C	✓	↓
15	15	WHS-15-FC	sink	FC	nurse office	C	✓	731
16	16	WHS-16-FC	sink	FC	guidance office	C	✓	732
17	17	WHS-17-DC	water fountain - Left	DC	corridor	C	✓	734
18	18	WHS-18-DC	water fountain - Right	DC	corridor	C	✓	↓
19	19	WHS-19-DC	water fountain	DC	chorus corridor	C	✓	733
20	20	WHS-20-DC	water fountain - Left	DC	corridor	C	✓	736
21	21	WHS-21-DC	water fountain - Right	DC	corridor	C	✓	↓
22	22	WHS-22-DC	water fountain	DC	gym	C	✓	737
23	23	WHS-23-DC	water fountain	DC	gym	C	✓	739
24	24	WHS-24-SG	cold tub hose	SG	training room	C	✓	740
25	25	WHS-25-IM	Ice Machine	IM	training room	C	✓	↓

58- Westlake HS PSC #08.031
3300 Middleton Road Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush

60410

26	26	WHS-26-DC	water fountain	DC	corridor	C	/	745
27	27	WHS-27-FC	sink	FC	child development	C	/	742
28	28	WHS-28-FC	sink - See map	FC	food lab - home ec	C	/	748
29	29	WHS-29-FC	sink - See map	FC	food lab - home ec	C	/	↓
30	30	WHS-30-FC	sink - See map	FC	food lab - home ec	C	/	
31	31	WHS-31-FC	sink - See map	FC	food lab - home ec	C	/	
32	32	WHS-32-FC	sink - See map	FC	food lab - home ec	C	/	
33	33	WHS-33-FC	sink - See map	FC	food lab - home ec	C	/	
34	34	WHS-34-FC	sink - See map	FC	teachers lounge	C	/	749
35	35	WHS-35-DH	instant hot	DH	teachers lounge	C	/	↓
36	36	WHS-36-DC	water fountain	DC	corridor - (2nd Floor)	C	/	750
37	37	WHS-37-DC	water fountain	DC	media center - (2nd Floor)	C	/	751
38	38	WHS-38-DC	water fountain - Left	DC	corridor - (2nd Floor)	C	/	752
39	39	WHS-39-DC	water fountain - Right	DC	corridor - (2nd Floor)	C	/	753
40	40	WHS-40-FC	sink	FC	teachers lounge - (2nd Floor)	C	/	754
41	41	WHS-41-DH	instant hot	DH	teachers lounge - (2nd Floor)	C	/	755
42	42	WHS-42-DC	water fountain - Left	DC	corridor - (2nd Floor)	C	/	756
43	43	WHS-43-DC	water fountain - Right	DC	corridor - (2nd Floor)	C	/	↓
44	44	WHS-44-DC	water fountain	DC	corridor - (2nd Floor)	C	/	757
45	45	WHS-45-FC	sink	FC	CR 212 (Sp-ED) (2nd Floor) SOAR	C	/	758
46	46	WHS-46-DH	instant hot	DH	CR 212 (Sp-ED) (2nd Floor) SOAR	C	/	↓
47	47	WHS-47-FC	sink	FC	classroom 211 - (2nd Floor) - Sp.Ed.	C	/	759
48	49	WHS-49-DC	water fountain	DC	Girls Locker Room	C	/	741
49	50	WHS-50-FC	sink	FC	Classroom 104	C	/	743
50	51	WHS-51-FC	sink	FC	Classroom 106	C	/	744
51	53	WHS-53-FC	sink	FC	Inside Concession	C	/	735
52	54	WHS-54-DC	Water Fountain - outside	DC	Outside concession stand - see map	C	/	725
53	55	WHS-55-FC	Sink	FC	Outside concession stand - see map	C	/	↓
54	56	WHS-56-SG	Hose Bib	SG	Outside concession stand - see map	C	/	↓
55	57	WHS-57-FC	Sink	FC	classroom 105 - Special Education	C	/	745
56	58	WHS-58-FC	Sink	FC	classroom 107 - Special Education	C	/	746
57	59	WHS-59-BU	Bottle Filler	BU	Corridor	C	/	739
58	60	WHS-60-BU	Bottle Filler	BU	Corridor	C	/	NW 740

58- Westlake HS PSC #08.031
3300 Middleton Road Waldorf, MD 20603

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN
SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

Martel NO:

Flush 60410

59	61	WHS-61-FC	Sink	FC	Classroom 232 - Special Education	C	//	800
----	----	-----------	------	----	-----------------------------------	---	----	-----