



**Charles County Public Schools**

P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646

**Attention:**

Tuesday, February 22, 2022

***Certificate of Analysis***  
**AMENDED**

**Project Information:**

Report for Lab No: 60411.  
Samples flushed by Martel on October 26 2021, sampled by Martel on October 27, 2021.  
Project Identification: MD HB 270  
School: North Point HS PSC #08.042

**References and Important Notes:**

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

\* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples. This report is amends the either the original report or the last amended report sent on: February 8, 2022 (dated Februaary 7, 2022)  
It has been amended for the following reason(s): Correct sample numbers to agree with correct sample id.

**Notices:**

Chain of Custody Form(s) are attached and are an integral part of this report.  
This report will be retained for at least five years and will be disposed of without notice.  
Measurement uncertainty for each listed test is available upon request.  
The results presented herein relate only to the samples or items tested.  
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 60411 1 CLIENT SAMPLE IDENTIFICATION NPHS-1-FC [2 comp sink--kitchen ] Sample Date/Time 10/27/2021 04:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 09:30 BJ

MARTEL NO. 60411 2 CLIENT SAMPLE IDENTIFICATION NPHS-2-IM [Ice Machine --kitchen ] Sample Date/Time 10/27/2021 04:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 09:33 BJ

MARTEL NO. 60411 3 CLIENT SAMPLE IDENTIFICATION NPHS-3-KK [kettle --kitchen ] Sample Date/Time 10/27/2021 04:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.03	ug/l	EPA .200.8	2	01/21/2022 09:36 BJ

MARTEL NO. 60411 4 CLIENT SAMPLE IDENTIFICATION NPHS-4-FC [island sink--kitchen ] Sample Date/Time 10/27/2021 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.30	ug/l	EPA .200.8	2	01/20/2022 10:51 BJ

MARTEL NO. 60411 5 CLIENT SAMPLE IDENTIFICATION NPHS-5-FC [Sink - Left fixture--Kitchen - Left Fixture on ] Sample Date/Time 10/27/2021 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:03 BJ

MARTEL NO. 60411 6 CLIENT SAMPLE IDENTIFICATION NPHS-6-FC [Sink - Right fixture--Kitchen - Right Fixture o ] Sample Date/Time 10/27/2021 04:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:06 BJ

MARTEL NO. 60411 7 CLIENT SAMPLE IDENTIFICATION NPHS-7-DC [water fountain - Left--cafeteria ] Sample Date/Time 10/27/2021 04:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:08 BJ

MARTEL NO. 60411 8 CLIENT SAMPLE IDENTIFICATION NPHS-8-DC [water fountain - Right--cafeteria ] Sample Date/Time 10/27/2021 04:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:11 BJ



MARTEL NO. 60411 9 CLIENT SAMPLE IDENTIFICATION NPHS-9-DC [water fountain - Left--corridor] Sample Date/Time 10/27/2021 04:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:13 BJ

MARTEL NO. 60411 10 CLIENT SAMPLE IDENTIFICATION NPHS-10-DC [water fountain - Right--corridor] Sample Date/Time 10/27/2021 04:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:16 BJ

MARTEL NO. 60411 11 CLIENT SAMPLE IDENTIFICATION NPHS-11-FC [sink - Left--nurse office] Sample Date/Time 10/27/2021 04:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:26 BJ

MARTEL NO. 60411 12 CLIENT SAMPLE IDENTIFICATION NPHS-12-FC [Sink - Right--nurse office] Sample Date/Time 10/27/2021 04:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:31 BJ

MARTEL NO. 60411 13 CLIENT SAMPLE IDENTIFICATION NPHS-13-FC [sink --work room ] Sample Date/Time 10/27/2021 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:34 BJ

MARTEL NO. 60411 14 CLIENT SAMPLE IDENTIFICATION NPHS-14-DH [coffee maker--work room ] Sample Date/Time 10/27/2021 04:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:36 BJ

MARTEL NO. 60411 15 CLIENT SAMPLE IDENTIFICATION NPHS-15-FC [sink--teachers lounge] Sample Date/Time 10/27/2021 04:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:38 BJ

MARTEL NO. 60411 16 CLIENT SAMPLE IDENTIFICATION NPHS-16-DC [water fountain - Left--corridor] Sample Date/Time 10/27/2021 04:59

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:41 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
60411 17	NPHS-17-DC [water fountain - Right--corridor]					10/27/2021 04:59
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:43 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
60411 18	NPHS-18-FC [sink--student services ]					10/27/2021 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:46 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
60411 19	NPHS-19-FC [Spout next to #114--Culinary Arts - 218 - See					10/27/2021 05:09
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 11:48 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
60411 20	NPHS-20-FC [2 comp sink--Culinary Arts - 218 - See Map]					10/27/2021 05:10
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	11.2	ug/l*	EPA .200.8	2	01/20/2022 11:51 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
60411 21	NPHS-21-FC [Spout--Culinary Arts - 218 - See Map]					10/27/2021 05:10
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	8.97	ug/l*	EPA .200.8	2	01/20/2022 11:59 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
60411 22	NPHS-22-OT [drink machine - Left (Juice)--Culinary Arts -					10/27/2021 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	n/a		EPA .200.8	2	/ /	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
60411 23	NPHS-23-OT [drink machine - Right (Ice Tea)--Culinary Arts					10/27/2021 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	n/a		EPA .200.8	2	/ /	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
60411 24	NPHS-24-FC [island sink - See map--Culinary Arts - 218 - S					10/27/2021 05:11
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.65	ug/l*	EPA .200.8	2	01/20/2022 12:06 BJ	



MARTEL NO. 60411 25 CLIENT SAMPLE IDENTIFICATION NPHS-25-FC [island sink - See map--Cullinary Arts - 218 - S] Sample Date/Time 10/27/2021 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.67	ug/l	EPA .200.8	2	01/20/2022 12:08 BJ

MARTEL NO. 60411 26 CLIENT SAMPLE IDENTIFICATION NPHS-26-FC [Sink left fixture--Cullinary Arts - 218 - Left] Sample Date/Time 10/27/2021 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.12	ug/l	EPA .200.8	2	01/20/2022 12:11 BJ

MARTEL NO. 60411 27 CLIENT SAMPLE IDENTIFICATION NPHS-27-FC [Sink right fixture--Cullinary Arts - 218 - Rig] Sample Date/Time 10/27/2021 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 12:14 BJ

MARTEL NO. 60411 28 CLIENT SAMPLE IDENTIFICATION NPHS-28-FC [island 2 comp sink - Left--Cullinary Arts - 218] Sample Date/Time 10/27/2021 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 12:16 BJ

MARTEL NO. 60411 29 CLIENT SAMPLE IDENTIFICATION NPHS-29-FC [island 2 comp sink - Right--Cullinary Arts - 21] Sample Date/Time 10/27/2021 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.28	ug/l	EPA .200.8	2	01/20/2022 12:18 BJ

MARTEL NO. 60411 30 CLIENT SAMPLE IDENTIFICATION NPHS-30-FC [island 2 comp sink - Left--Cullinary Arts - 218] Sample Date/Time 10/27/2021 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 12:21 BJ

MARTEL NO. 60411 31 CLIENT SAMPLE IDENTIFICATION NPHS-31-FC [island 2 comp sink - Right--Cullinary Arts - 21] Sample Date/Time 10/27/2021 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.38	ug/l	EPA .200.8	2	01/20/2022 12:31 BJ

MARTEL NO. 60411 32 CLIENT SAMPLE IDENTIFICATION NPHS-32-FC [island 2 comp sink - Left--Cullinary Arts - 218] Sample Date/Time 10/27/2021 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 09:38 BJ



MARTEL NO. 60411 33 CLIENT SAMPLE IDENTIFICATION NPHS-33-IM [Ice Machine --Culinary Arts - 218 - See Map] Sample Date/Time 10/27/2021 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 12:36 BJ

MARTEL NO. 60411 34 CLIENT SAMPLE IDENTIFICATION NPHS-34-HE [island 2 comp sink - Right--Culinary Arts - 21] Sample Date/Time 10/27/2021 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 12:38 BJ

MARTEL NO. 60411 35 CLIENT SAMPLE IDENTIFICATION NPHS-35-FC [island 2 comp sink - Left--Culinary Arts - 218] Sample Date/Time 10/27/2021 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 12:41 BJ

MARTEL NO. 60411 36 CLIENT SAMPLE IDENTIFICATION NPHS-36-FC [island 2 comp sink - Right--Culinary Arts - 21] Sample Date/Time 10/27/2021 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 12:43 BJ

MARTEL NO. 60411 37 CLIENT SAMPLE IDENTIFICATION NPHS-37-FC [island 2 comp sink - Left--Culinary Arts - 218] Sample Date/Time 10/27/2021 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 12:46 BJ

MARTEL NO. 60411 38 CLIENT SAMPLE IDENTIFICATION NPHS-38-FC [island 2 comp sink - Right--Culinary Arts - 21] Sample Date/Time 10/27/2021 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 09:41 BJ

MARTEL NO. 60411 39 CLIENT SAMPLE IDENTIFICATION NPHS-39-FC [island sink - Next to office--Culinary Arts - ] Sample Date/Time 10/27/2021 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.88	ug/l*	EPA .200.8	2	01/20/2022 12:48 BJ

MARTEL NO. 60411 40 CLIENT SAMPLE IDENTIFICATION NPHS-40-OT [ice cream machine--Culinary Arts - 218 - See M] Sample Date/Time 10/27/2021 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	/ /



MARTEL NO. 60411 41 CLIENT SAMPLE IDENTIFICATION NPHS-41-DC [water fountain - Left--corridor] Sample Date/Time 10/27/2021 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 12:56 BJ

MARTEL NO. 60411 42 CLIENT SAMPLE IDENTIFICATION NPHS-42-DC [water fountain - Right --corridor R] Sample Date/Time 10/27/2021 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:03 BJ

MARTEL NO. 60411 43 CLIENT SAMPLE IDENTIFICATION NPHS-43-DC [water fountain - Left--corridor L] Sample Date/Time 10/27/2021 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:06 BJ

MARTEL NO. 60411 44 CLIENT SAMPLE IDENTIFICATION NPHS-44-DC [water fountain - Right --corridor R] Sample Date/Time 10/27/2021 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:08 BJ

MARTEL NO. 60411 45 CLIENT SAMPLE IDENTIFICATION NPHS-45-DC [water fountain - Left--corridor L] Sample Date/Time 10/27/2021 05:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 09:44 BJ

MARTEL NO. 60411 46 CLIENT SAMPLE IDENTIFICATION NPHS-46-DC [water fountain - Right--corridor R] Sample Date/Time 10/27/2021 05:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 09:46 BJ

MARTEL NO. 60411 47 CLIENT SAMPLE IDENTIFICATION NPHS-47-DC [water fountain - Left--corridor L] Sample Date/Time 10/27/2021 05:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 09:49 BJ

MARTEL NO. 60411 48 CLIENT SAMPLE IDENTIFICATION NPHS-48-DC [water fountain - Right--corridor R] Sample Date/Time 10/27/2021 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:11 BJ



MARTEL NO. 60411 49 CLIENT SAMPLE IDENTIFICATION NPHS-49-DC [water fountain - Left--corridor L] Sample Date/Time 10/27/2021 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:13 BJ

MARTEL NO. 60411 50 CLIENT SAMPLE IDENTIFICATION NPHS-50-DC [water fountain - Center--corridor C] Sample Date/Time 10/27/2021 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:15 BJ

MARTEL NO. 60411 51 CLIENT SAMPLE IDENTIFICATION NPHS-51-DC [water fountain - Right --corridor R] Sample Date/Time 10/27/2021 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 09:52 BJ

MARTEL NO. 60411 52 CLIENT SAMPLE IDENTIFICATION NPHS-52-DC [water fountain - Left--corridor L] Sample Date/Time 10/27/2021 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:25 BJ

MARTEL NO. 60411 53 CLIENT SAMPLE IDENTIFICATION NPHS-53-DC [water fountain - Right--corridor R] Sample Date/Time 10/27/2021 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:30 BJ

MARTEL NO. 60411 54 CLIENT SAMPLE IDENTIFICATION NPHS-54-DC [water fountain - Center--corridor C] Sample Date/Time 10/27/2021 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:33 BJ

MARTEL NO. 60411 55 CLIENT SAMPLE IDENTIFICATION NPHS-55-DC [water fountain (#55 - #58 Left to right)--corr] Sample Date/Time 10/27/2021 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 10:02 BJ

MARTEL NO. 60411 56 CLIENT SAMPLE IDENTIFICATION NPHS-56-DC [water fountain (#55 - #58 Left to right)--corr] Sample Date/Time 10/27/2021 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 10:08 BJ





MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 57	NPHS-57-DC [water fountain (#55 - #58 Left to right)--corr	10/27/2021 05:38			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:35 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 58	NPHS-58-DC [water fountain (#55 - #58 Left to right)--corr	10/27/2021 05:38			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:38 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 59	NPHS-59-DC [water fountain (#59 - #62 Left to right)--corr	10/27/2021 05:35			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:40 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 60	NPHS-60-DC [water fountain (#59 - #62 Left to right)--corr	10/27/2021 05:35			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:43 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 61	NPHS-61-DC [water fountain (#59 - #62 Left to right)--corr	10/27/2021 05:35			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:50 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 62	NPHS-62-DC [water fountain (#59 - #62 Left to right)--coor	10/27/2021 05:35			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 13:58 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 63	NPHS-63-DC [water fountain - Left --corridor L]	10/27/2021 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:00 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 64	NPHS-64-DC [water fountain - Center--corridor C]	10/27/2021 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:03 BJ



MARTEL NO. 60411 65 CLIENT SAMPLE IDENTIFICATION NPHS-65-DC [water fountain - Right--corridor R] Sample Date/Time 10/27/2021 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:06 BJ

MARTEL NO. 60411 66 CLIENT SAMPLE IDENTIFICATION NPHS-66-FC [sink--training room] Sample Date/Time 10/27/2021 05:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:08 BJ

MARTEL NO. 60411 67 CLIENT SAMPLE IDENTIFICATION NPHS-67-IM [Ice Machine --training room] Sample Date/Time 10/27/2021 05:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 10:10 BJ

MARTEL NO. 60411 68 CLIENT SAMPLE IDENTIFICATION NPHS-68-SG [hose bib--training room] Sample Date/Time 10/27/2021 05:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.17	ug/l	EPA .200.8	2	01/20/2022 14:10 BJ

MARTEL NO. 60411 69 CLIENT SAMPLE IDENTIFICATION NPHS-69-DC [water fountain - Left--boys locker room] Sample Date/Time 10/27/2021 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:13 BJ

MARTEL NO. 60411 70 CLIENT SAMPLE IDENTIFICATION NPHS-70-DC [water fountain - Right--boys locker room] Sample Date/Time 10/27/2021 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:15 BJ

MARTEL NO. 60411 71 CLIENT SAMPLE IDENTIFICATION NPHS-71-DC [water fountain - Left--boys locker room ] Sample Date/Time 10/27/2021 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:25 BJ

MARTEL NO. 60411 72 CLIENT SAMPLE IDENTIFICATION NPHS-72-DC [water fountain - Right--boys locker room ] Sample Date/Time 10/27/2021 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:30 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 73	NPHS-73-DC [water fountain - Left--pool ]	10/27/2021 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:33 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 74	NPHS-74-DC [water fountain - Right--pool ]	10/27/2021 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:35 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 75	NPHS-75-DC [water fountain - (L) Next to door--gym - 2nd F	10/27/2021 05:33			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:38 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 76	NPHS-76-DC [water fountain - (R) Next to door--gym - 2nd F	10/27/2021 05:33			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:41 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 77	NPHS-77-DC [water fountain - Left--gym - 2nd Floor ]	10/27/2021 05:33			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:43 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 78	NPHS-78-DC [water fountain - Right--gym - 2nd Floor]	10/27/2021 05:33			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:46 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 79	NPHS-79-FC [sink--teachers lounge - 2nd Floor]	10/27/2021 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:48 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 80	NPHS-80-DC [water fountain - Left--corridor - 2nd Floor]	10/27/2021 05:03			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 10:13 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 81	NPHS-81-DC [water fountain - Center--corridor - 2nd Floor]	10/27/2021 05:03			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 14:56 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 82	NPHS-82-DC [water fountain - Right--corridor - 2nd Floor]	10/27/2021 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:03 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 83	NPHS-83-DC [water fountain - Left - By womens RR--concessi	10/27/2021 05:58			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 10:16 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 84	NPHS-84-FC [Sink - Left faucet of 3 comp sink--concessions	10/27/2021 05:55			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.60	ug/l	EPA .200.8	2	01/20/2022 15:06 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 85	NPHS-85-FC [Sink - Right faucet of 3 comp sink--concession	10/27/2021 05:55			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.76	ug/l	EPA .200.8	2	01/20/2022 15:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 86	NPHS-86-SG [hose bib--concessions - See Map]	10/27/2021 06:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	71.5	ug/l*	EPA .200.8	2	01/20/2022 15:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 87	NPHS-87-DC [water fountain - Right - By womens	10/27/2021 05:58			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 10:19 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
60411 88	NPHS-88-FC [Sink - Left--Child Care Classroom 115]	10/27/2021 04:52			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:13 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 89	NPHS-89-FC [Sink - Right--Child Care Classroom 115]				10/27/2021 04:52
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:16 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 90	NPHS-90-DC [Water Fountain--Child Care Classroom 116.3]				10/27/2021 04:52
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:18 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 91	NPHS-91-FC [Kitchen Sink - Left--Child Care Classroom 116.				10/27/2021 04:53
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:28 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 92	NPHS-92-FC [Kitchen Sink - Right--Child Care Classroom 116				10/27/2021 04:53
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:33 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 93	NPHS-93-FC [Sink - Left--Child Care Classroom 116]				10/27/2021 04:54
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:36 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 94	NPHS-94-FC [Sink - Right--Child Care Classroom 116]				10/27/2021 04:54
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:38 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 95	NPHS-95-DC [Water Fountain--Child Care Classroom 116]				10/27/2021 04:54
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:41 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 98	NPHS-98-FC [Sink--CR 322 (Sp-Ed)]				10/27/2021 04:25
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:43 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 100	NPHS-100-FC [Sink - 2 Comp - Right--Inside concessions]				10/27/2021 04:51
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.37	ug/l*	EPA .200.8	2	01/20/2022 15:46 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 101	NPHS-101-FC [Sink - 2 Comp - Left--Inside concessions ]				10/27/2021 04:51
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.72	ug/l	EPA .200.8	2	01/20/2022 15:48 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 103	NPHS-103-FC [Island Sink--Culinary Arts - 218 - See Map]				10/27/2021 04:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	/ /

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 104	NPHS-104-DC [Water Fountain - Left--Girls locker room - Le				10/27/2021 04:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:51 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 105	NPHS-105-DC [Water Fountain - Right--Girls locker room - L				10/27/2021 04:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 15:58 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 106	NPHS-106-DC [Water Fountain - Left--Girls locker room - Ri				10/27/2021 04:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 16:06 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 107	NPHS-107-DC [Water Fountain - Right--Girls locker room - R				10/27/2021 04:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 16:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 108	NPHS-108-DC [water fountian - Left - By Mens RR--concessio				10/27/2021 04:57
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 10:21 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 109	NPHS-109-DC [water fountain - Right - By Mens RR--concessi				10/27/2021 04:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	//

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 110	NPHS-110-SG [Hose Bib - Outside--concessions - See Map]				10/27/2021 04:58
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	23.4	ug/l*	EPA .200.8	2	01/20/2022 16:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 111	NPHS-111-BU [Bottle Filler--Corridor]				10/27/2021 04:30
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 16:13 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 112	NPHS-112-BU [Bottle Filler--Corridor]				10/27/2021 04:44
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 16:16 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 113	NPHS-113-BU [Bottle Filler--corridor - 2nd Floor]				10/27/2021 04:04
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 16:18 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 114	NPHS-114-FC [Sink left #19--Culinary Arts - 218 - See Map]				10/27/2021 04:09
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.31	ug/l	EPA .200.8	2	01/20/2022 16:21 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 115	NPHS-115-BU [Bottle Filler--Next to Teachers]				10/27/2021 04:59
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/20/2022 16:24 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60411 116	NPHS-116-BU [Bottle Filler--next to room 253]				10/27/2021 05:27
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/21/2022 10:24 BJ

## MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

### Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO<sub>3</sub> Analysis: Lead (EPA 200.8)

Flush #: 10/26/21 7:35

Flush #: 10/26/21 20:40

Sample Start Date/Time: 10/27/21 4:43

End Date/Time: 10/27/21 6:02

Sampler/Relinquished By: [Signature]

Received at Martel by: [Signature]

Date/Time: 10/27/21 1346

**59- North Point HS PSC #08.042**  
**2500 Davis Road Waldorf, MD 20603**

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

Martel #	Sample #	Location ID #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)</small>	Outlet Key Codes	Room/Location	Consumption Cor NCF?	Flush Date	Sample Time
1	1	NPHS-1-FC	2 comp sink	FC	kitchen	C	✓	4:45
2	2	NPHS-2-IM	Ice Machine	IM	kitchen	C	✓	↓
3	3	NPHS-3-KK	kettle	KK	kitchen	C	✓	↓
4	4	NPHS-4-FC	island sink	FC	kitchen	C	✓	4:46
5	5	NPHS-5-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	✓	↓
6	6	NPHS-6-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	✓	↓
7	7	NPHS-7-DC	water fountain - Left	DC	cafeteria	C	✓	4:43
8	8	NPHS-8-DC	water fountain - Right	DC	cafeteria	C	✓	↓
9	9	NPHS-9-DC	water fountain - Left	DC	corridor	C	✓	4:48
10	10	NPHS-10-DC	water fountain - Right	DC	corridor	C	✓	↓
11	11	NPHS-11-FC	sink - Left	FC	nurse office	C	✓	4:49
12	12	NPHS-12-FC	Sink - Right	FC	nurse office	C	✓	↓
13	13	NPHS-13-FC	sink	FC	work room	C	✓	4:50
14	14	NPHS-14-DH	coffee maker	DH	work room	C	✓	↓
15	15	NPHS-15-FC	sink	FC	teachers lounge	C	✓	4:58
16	16	NPHS-16-DC	water fountain - Left	DC	corridor	C	✓	4:59
17	17	NPHS-17-DC	water fountain - Right	DC	corridor	C	✓	↓
18	18	NPHS-18-FC	sink	FC	student services	C	✓	5:00
19	19	NPHS-19-FC	Spout next to #114	FC	Culinary Arts - 218 - See Map	C	✓	5:09
20	20	NPHS-20-FC	2 comp sink	FC	Culinary Arts - 218 - See Map	C	✓	5:10
21	21	NPHS-21-FC	Spout	FC	Culinary Arts - 218 - See Map	C	✓	↓
22	22	NPHS-22-OT	drink machine - Left (Juice)	OT	Culinary Arts - 218 - See Map	C	✓	↓
23	23	NPHS-23-OT	drink machine - Right (Ice Tea)	OT	Culinary Arts - 218 - See Map	C	✓	↓
24	24	NPHS-24-FC	island sink - See map	FC	Culinary Arts - 218 - See Map	C	✓	5:11
25	25	NPHS-25-FC	island sink - See map	FC	Culinary Arts - 218 - See Map	C	✓	↓

7:35  
20:40  
Flush

Martel NO:  
**60411**



**59- North Point HS PSC #08.042**  
**2500 Davis Road Waldorf, MD 20603**

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN  
SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

Martel NO:

Flush **60411**

							Flush	60411
26	26	NPHS-26-FC	Sink left fixture	FC	Culinary Arts - 218 - Left Fixture on 3 Comp Sink	C	/	S:13
27	27	NPHS-27-FC	Sink right fixture	FC	Culinary Arts - 218 - Right Fixture on 3 Comp Sink	C	/	S:14
28	28	NPHS-28-FC	island 2 comp sink - Left	FC	Culinary Arts - 218 - See Map	C	/	↓
29	29	NPHS-29-FC	island 2 comp sink - Right	FC	Culinary Arts - 218 - See Map	C	/	S:15
30	30	NPHS-30-FC	island 2 comp sink - Left	FC	Culinary Arts - 218 - See Map	C	/	↓
31	31	NPHS-31-FC	island 2 comp sink - Right	FC	Culinary Arts - 218 - See Map	C	/	S:16
32	32	NPHS-32-FC	island 2 comp sink - Left	FC	Culinary Arts - 218 - See Map	C	/	S:17
33	33	NPHS-33-IM	Ice Machine	IM	Culinary Arts - 218 - See Map	C	/	↓
34	34	NPHS-34-HE	island 2 comp sink - Right	HE	Culinary Arts - 218 - See Map	C	/	S:18
35	35	NPHS-35-FC	island 2 comp sink - Left	FC	Culinary Arts - 218 - See Map	C	/	↓
36	36	NPHS-36-FC	island 2 comp sink - Right	FC	Culinary Arts - 218 - See Map	C	/	↓
37	37	NPHS-37-FC	island 2 comp sink - Left	FC	Culinary Arts - 218 - See Map	C	/	S:19
38	38	NPHS-38-FC	island 2 comp sink - Right	FC	Culinary Arts - 218 - See Map	C	/	↓
39	39	NPHS-39-FC	island sink - Next to office	FC	Culinary Arts - 218 - See Map	C	/	S:16
40	40	NPHS-40-OT	ice cream machine	OT	Culinary Arts - 218 - See Map	C	/	N/A
41	41	NPHS-41-DC	water fountain - Left	DC	corridor	C	/	S:21
42	42	NPHS-42-DC	water fountain - Right	DC	corridor R	C	/	↓
43	43	NPHS-43-DC	water fountain - Left	DC	corridor L	C	/	↓
44	44	NPHS-44-DC	water fountain - Right	DC	corridor R	C	/	↓
45	45	NPHS-45-DC	water fountain - Left	DC	corridor L	C	/	S:27
46	46	NPHS-46-DC	water fountain - Right	DC	corridor R	C	/	↓
47	47	NPHS-47-DC	water fountain - Left	DC	corridor L	C	/	↓
48	48	NPHS-48-DC	water fountain - Right LEFT	DC	corridor R	C	/	S:24
49	49	NPHS-49-DC	water fountain - Left RIGHT	DC	corridor L	C	/	↓
50	50	NPHS-50-DC	water fountain - Center LEFT	DC	corridor C	C	/	↓
51	51	NPHS-51-DC	water fountain - Right	DC	corridor R	C	/	↓
52	52	NPHS-52-DC	water fountain - Left	DC	corridor L	C	/	S:30
53	53	NPHS-53-DC	water fountain - Right	DC	corridor R	C	/	↓
54	54	NPHS-54-DC	water fountain - Center	DC	corridor C	C	/	↓
55	55	NPHS-55-DC	water fountain (#55 - #58 Left to right)	DC	corridor	C	/	S:38
56	56	NPHS-56-DC	water fountain (#55 - #58 Left to right)	DC	corridor	C	/	↓
57	57	NPHS-57-DC	water fountain (#55 - #58 Left to right)	DC	corridor	C	/	↓
58	58	NPHS-58-DC	water fountain (#55 - #58 Left to right)	DC	corridor	C	/	↓

**59- North Point HS PSC #08.042**  
**2500 Davis Road Waldorf, MD 20603**

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN  
SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

Martel NO:

**Flush 60411**

59	59	NPHS-59-DC	water fountain (#59 - #62 Left to right)	DC	corridor	C	✓	5:35	6:27
60	60	NPHS-60-DC	water fountain (#59 - #62 Left to right)	DC	corridor	C	✓	↓	
61	61	NPHS-61-DC	water fountain (#59 - #62 Left to right)	DC	corridor	C	✓	↓	
62	62	NPHS-62-DC	water fountain (#59 - #62 Left to right)	DC	cooridor	C	✓	↓	
63	63	NPHS-63-DC	water fountain - Left	DC	corridor L	C	✓	5:44	
64	64	NPHS-64-DC	water fountain - Center	DC	corridor C	C	✓	↓	
65	65	NPHS-65-DC	water fountain - Right	DC	corridor R	C	✓	↓	
66	66	NPHS-66-FC	sink	FC	training room	C	✓	5:45	
67	67	NPHS-67-IM	Ice Machine	IM	training room	C	✓	↓	
68	68	NPHS-68-SG	hose bib	SG	training room	C	✓	↓	
69	69	NPHS-69-DC	water fountain - Left	DC	boys locker room	C	✓	5:48	
70	70	NPHS-70-DC	water fountain - Right	DC	boys locker room	C	✓	↓	
71	71	NPHS-71-DC	water fountain - Left	DC	boys locker room	C	✓	↓	
72	72	NPHS-72-DC	water fountain - Right	DC	boys locker room	C	✓	↓	
73	73	NPHS-73-DC	water fountain - Left	DC	pool	C	✓	5:40	
74	74	NPHS-74-DC	water fountain - Right	DC	pool	C	✓	↓	
75	75	NPHS-75-DC	water fountain - (L) Next to door	DC	gym - 2nd Floor	C	✓	5:33	
76	76	NPHS-76-DC	water fountain - (R) Next to door	DC	gym - 2nd Floor	C	✓	↓	
77	77	NPHS-77-DC	water fountain - Left	DC	gym - 2nd Floor	C	✓	↓	
78	78	NPHS-78-DC	water fountain - Right	DC	gym - 2nd Floor	C	✓	↓	
79	79	NPHS-79-FC	sink	FC	teachers lounge - 2nd Floor	C	✓	5:02	
80	80	NPHS-80-DC	water fountain - Left	DC	corridor - 2nd Floor	C	✓	5:03	
81	81	NPHS-81-DC	water fountain - Center	DC	corridor - 2nd Floor	C	✓	↓	
82	82	NPHS-82-DC	water fountain - Right	DC	corridor - 2nd Floor	C	✓	5:04	
83	83	NPHS-83-DC	water fountain - Left - By womens RR	DC	concessions - See Map	C	✓	5:58	
84	84	NPHS-84-FC	Sink - Left faucet of 3 comp sink	FC	concessions - See Map	C	✓	5:55	
85	85	NPHS-85-FC	Sink - Right faucet of 3 comp sink	FC	concessions - See Map	C	✓	↓	
86	86	NPHS-86-SG	hose bib	SG	concessions - See Map	C	✓	6:02	
87	87	NPHS-87-DC	water fountain - Right - By womens RR	DC	concessions - See Map	C	✓	5:58	
88	88	NPHS-88-FC	Sink - Left	FC	Child Care Classroom 115	C	✓	4:52	
89	89	NPHS-89-FC	Sink - Right	FC	Child Care Classroom 115	C	✓	↓	
90	90	NPHS-90-DC	Water Fountain	DC	Child Care Classroom 116.3	C	✓	↓	
91	91	NPHS-91-FC	Kitchen Sink - Left	FC	Child Care Classroom 116.3	C	✓	4:53	

**P 18**

**59- North Point HS PSC #08.042**  
**2500 Davis Road Waldorf, MD 20603**

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN  
 SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

Martel NO:

**Flush 60411**

92	92	NPHS-92-FC	Kitchen Sink - Right	FC	Child Care Classroom 116.3	C	✓	4:53
93	93	NPHS-93-FC	Sink - Left	FC	Child Care Classroom 116	C	✓	4:54
94	94	NPHS-94-FC	Sink - Right	FC	Child Care Classroom 116	C	✓	↓
95	95	NPHS-95-DC	Water Fountain	DC	Child Care Classroom 116	C	✓	↓
96	98	NPHS-98-FC	Sink	FC	CR 322 (Sp-Ed)	C	✓	5:25
97	100	NPHS-100-FC	Sink - 2 Comp - Right	FC	Inside concessions	C	✓	5:51
98	101	NPHS-101-FC	Sink - 2 Comp - Left	FC	Inside concessions	C	✓	↓
99	103	NPHS-103-FC	Island Sink	FC	Culinary Arts - 218 - See Map	C	✓	N/A (ALL COUNTED FOR)
100	104	NPHS-104-DC	Water Fountain - Left	DC	Girls locker room - Left of #106 & #107	C	✓	5:42
101	105	NPHS-105-DC	Water Fountain - Right	DC	Girls locker room - Left of #106 & #107	C	✓	↓
102	106	NPHS-106-DC	Water Fountain - Left	DC	Girls locker room - Right of #106 & #107	C	✓	↓
103	107	NPHS-107-DC	Water Fountain - Right	DC	Girls locker room - Right of #106 & #107	C	✓	↓
104	108	NPHS-108-DC	water fountain - Left - By Mens RR	DC	concessions - See Map	C	✓	5:57
105	109	NPHS-109-DC	water fountain - Right - By Mens RR	DC	concessions - See Map	C	✓	NOT WORKING
106	110	NPHS-110-SG	Hose Bib - Outside	SG	concessions - See Map	C	✓	5:58
107	111	NPHS-111-BU	Bottle Filler	BU	Corridor	C	✓	5:30
108	112	NPHS-112-BU	Bottle Filler	BU	Corridor	C	✓	5:44
109	113	NPHS-113-BU	Bottle Filler	BU	corridor - 2nd Floor	C	✓	5:04
110	114	NPHS-114-FC	Sink left #19	FC	Culinary Arts - 218 - See Map	C	✓	5:09

111	115		BOTTLE FILLER NEXT TO TEACHERS LOUNGE			C	✓	4:59
112	116		BOTTLE FILLER NEXT TO ROOM 253 (w/ SAMPLES) 45, 46, 47				✓	5:27