



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Attention:

Monday, February 28, 2022

Certificate of Analysis

FINAL

Project Information:

Report for Lab No: 60412.
Samples flushed by Martel on October 29, 2021, sampled by Martel on October 30, 2021.
Project Identification: MD HB 270
School: Maurice J. McDonough HS

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.


Project Manager



MARTEL NO. 60412 1 CLIENT SAMPLE IDENTIFICATION MHS-1-DC [water fountain - Left--corridor] Sample Date/Time 10/30/2021 06:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 17:18 BJ

MARTEL NO. 60412 2 CLIENT SAMPLE IDENTIFICATION MHS-2-DC [water fountain - Right--corridor] Sample Date/Time 10/30/2021 06:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.55	ug/l	EPA .200.8	2	02/14/2022 17:30 BJ

MARTEL NO. 60412 3 CLIENT SAMPLE IDENTIFICATION MHS-3-FC [island sink next to 3 comp sink--Kitchen] Sample Date/Time 10/30/2021 06:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.21	ug/l*	EPA .200.8	2	02/14/2022 17:32 BJ

MARTEL NO. 60412 4 CLIENT SAMPLE IDENTIFICATION MHS-4-KK [kettle--Kitchen] Sample Date/Time 10/30/2021 06:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 17:35 BJ

MARTEL NO. 60412 5 CLIENT SAMPLE IDENTIFICATION MHS-5-FC [Sink - Left fixture--Kitchen - Left Fixture on 3] Sample Date/Time 10/30/2021 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.98	ug/l	EPA .200.8	2	02/14/2022 17:37 BJ

MARTEL NO. 60412 6 CLIENT SAMPLE IDENTIFICATION MHS-6-FC [Sink - Right fixture--Kitchen - Right Fixture on] Sample Date/Time 10/30/2021 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.69	ug/l	EPA .200.8	2	02/14/2022 17:40 BJ

MARTEL NO. 60412 7 CLIENT SAMPLE IDENTIFICATION MHS-7-FC [island sink--Kitchen] Sample Date/Time 10/30/2021 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.50	ug/l	EPA .200.8	2	02/14/2022 17:42 BJ

MARTEL NO. 60412 8 CLIENT SAMPLE IDENTIFICATION MHS-8-FC [island sink near ice maker--Kitchen] Sample Date/Time 10/30/2021 06:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.48	ug/l	EPA .200.8	2	02/14/2022 17:45 BJ



MARTEL NO. 60412 9 CLIENT SAMPLE IDENTIFICATION MHS-9-IM [Ice Machine --Kitchen] Sample Date/Time 10/30/2021 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	11

MARTEL NO. 60412 10 CLIENT SAMPLE IDENTIFICATION MHS-10-FC [2 comp sink--Kitchen] Sample Date/Time 10/30/2021 06:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.01	ug/l*	EPA .200.8	2	02/14/2022 17:47 BJ

MARTEL NO. 60412 11 CLIENT SAMPLE IDENTIFICATION MHS-11-DC [water fountain--Kitchen] Sample Date/Time 10/30/2021 06:59

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.87	ug/l	EPA .200.8	2	02/14/2022 17:58 BJ

MARTEL NO. 60412 12 CLIENT SAMPLE IDENTIFICATION MHS-12-DC [water fountain - Left--cafeteria] Sample Date/Time 10/30/2021 07:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:03 BJ

MARTEL NO. 60412 13 CLIENT SAMPLE IDENTIFICATION MHS-13-DC [water fountain - Right--cafeteria] Sample Date/Time 10/30/2021 07:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.02	ug/l*	EPA .200.8	2	02/14/2022 18:05 BJ

MARTEL NO. 60412 14 CLIENT SAMPLE IDENTIFICATION MHS-14-FC [sink--lounge] Sample Date/Time 10/30/2021 07:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.75	ug/l	EPA .200.8	2	02/14/2022 18:08 BJ

MARTEL NO. 60412 15 CLIENT SAMPLE IDENTIFICATION MHS-15-DC [water fountain - Left--corridor] Sample Date/Time 10/30/2021 07:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:10 BJ

MARTEL NO. 60412 16 CLIENT SAMPLE IDENTIFICATION MHS-16-DC [water fountain - Right--corridor] Sample Date/Time 10/30/2021 07:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:13 BJ



MARTEL NO. 60412 17 CLIENT SAMPLE IDENTIFICATION MHS-17-DC [water fountain--main office] Sample Date/Time 10/30/2021 07:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:15 BJ

MARTEL NO. 60412 18 CLIENT SAMPLE IDENTIFICATION MHS-18-DC [water fountain - Left--corridor] Sample Date/Time 10/30/2021 07:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:18 BJ

MARTEL NO. 60412 19 CLIENT SAMPLE IDENTIFICATION MHS-19-DC [water fountain - Center--corridor] Sample Date/Time 10/30/2021 07:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:20 BJ

MARTEL NO. 60412 20 CLIENT SAMPLE IDENTIFICATION MHS-20-DC [water fountain - Right--corridor] Sample Date/Time 10/30/2021 07:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:23 BJ

MARTEL NO. 60412 21 CLIENT SAMPLE IDENTIFICATION MHS-21-DC [water fountain - Left--corridor] Sample Date/Time 10/30/2021 07:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:31 BJ

MARTEL NO. 60412 22 CLIENT SAMPLE IDENTIFICATION MHS-22-DC [water fountain - Right--corridor] Sample Date/Time 10/30/2021 07:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.11	ug/l	EPA .200.8	2	02/14/2022 18:38 BJ

MARTEL NO. 60412 23 CLIENT SAMPLE IDENTIFICATION MHS-23-IM [Ice Machine--training room - (Basement)] Sample Date/Time 10/30/2021 07:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	/ /

MARTEL NO. 60412 24 CLIENT SAMPLE IDENTIFICATION MHS-24-DC [water fountain - Left--corridor - (Basement)] Sample Date/Time 10/30/2021 07:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:41 BJ



MARTEL NO. 60412 25 CLIENT SAMPLE IDENTIFICATION MHS-25-DC [water fountain - Right--corridor - (Basement)] Sample Date/Time 10/30/2021 07:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:43 BJ

MARTEL NO. 60412 26 CLIENT SAMPLE IDENTIFICATION MHS-26-DC [water fountain - Left--corridor] Sample Date/Time 10/30/2021 07:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.81	ug/l	EPA .200.8	2	02/14/2022 18:46 BJ

MARTEL NO. 60412 27 CLIENT SAMPLE IDENTIFICATION MHS-27-DC [water fountain - Right--corridor] Sample Date/Time 10/30/2021 07:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.72	ug/l	EPA .200.8	2	02/14/2022 18:48 BJ

MARTEL NO. 60412 28 CLIENT SAMPLE IDENTIFICATION MHS-28-DC [water fountain - Left--corridor] Sample Date/Time 10/30/2021 07:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:51 BJ

MARTEL NO. 60412 29 CLIENT SAMPLE IDENTIFICATION MHS-29-DC [water fountain - Right--corridor] Sample Date/Time 10/30/2021 07:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:53 BJ

MARTEL NO. 60412 30 CLIENT SAMPLE IDENTIFICATION MHS-30-FC [sink--LH-1B/ child care] Sample Date/Time 10/30/2021 07:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 18:56 BJ

MARTEL NO. 60412 31 CLIENT SAMPLE IDENTIFICATION MHS-31-DB [bubbler--LH-1B/ child care] Sample Date/Time 10/30/2021 07:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 19:05 BJ

MARTEL NO. 60412 32 CLIENT SAMPLE IDENTIFICATION MHS-32-FC [sink - See map--FCS-1/ home ec] Sample Date/Time 10/30/2021 07:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.89	ug/l	EPA .200.8	2	02/14/2022 19:10 BJ



MARTEL NO. 60412 33 CLIENT SAMPLE IDENTIFICATION MHS-33-FC [sink - See map--FCS-1/ home ec] Sample Date/Time 10/30/2021 07:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.63	ug/l*	EPA .200.8	2	02/14/2022 19:13 BJ

MARTEL NO. 60412 34 CLIENT SAMPLE IDENTIFICATION MHS-34-FC [sink - See map--FCS-1/ home ec] Sample Date/Time 10/30/2021 07:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.59	ug/l*	EPA .200.8	2	02/14/2022 19:15 BJ

MARTEL NO. 60412 35 CLIENT SAMPLE IDENTIFICATION MHS-35-FC [sink - See map--FCS-1/ home ec] Sample Date/Time 10/30/2021 07:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.6	ug/l*	EPA .200.8	2	02/14/2022 19:18 BJ

MARTEL NO. 60412 36 CLIENT SAMPLE IDENTIFICATION MHS-36-FC [sink - See map--FCS-1/ home ec] Sample Date/Time 10/30/2021 07:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.85	ug/l	EPA .200.8	2	02/14/2022 19:20 BJ

MARTEL NO. 60412 37 CLIENT SAMPLE IDENTIFICATION MHS-37-FC [sink - See map--FCS-1/ home ec] Sample Date/Time 10/30/2021 07:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.1	ug/l*	EPA .200.8	2	02/14/2022 19:23 BJ

MARTEL NO. 60412 38 CLIENT SAMPLE IDENTIFICATION MHS-38-FC [sink - See map--FCS-1/ home ec] Sample Date/Time 10/30/2021 07:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.85	ug/l*	EPA .200.8	2	02/14/2022 19:25 BJ

MARTEL NO. 60412 39 CLIENT SAMPLE IDENTIFICATION MHS-39-DC [water fountain - Left--corridor] Sample Date/Time 10/30/2021 07:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 19:28 BJ

MARTEL NO. 60412 40 CLIENT SAMPLE IDENTIFICATION MHS-40-DC [water fountain - Right--corridor] Sample Date/Time 10/30/2021 07:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.01	ug/l	EPA .200.8	2	02/14/2022 19:30 BJ



MARTEL NO. 60412 41 CLIENT SAMPLE IDENTIFICATION MHS-41-DC [water fountain--FCS-1/ ROTC] Sample Date/Time 10/30/2021 07:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 19:38 BJ

MARTEL NO. 60412 42 CLIENT SAMPLE IDENTIFICATION MHS-42-DC [water fountain - Left--corridor - (2nd Floor)] Sample Date/Time 10/30/2021 07:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 19:45 BJ

MARTEL NO. 60412 43 CLIENT SAMPLE IDENTIFICATION MHS-43-DC [water fountain - Right--corridor - (2nd Floor)] Sample Date/Time 10/30/2021 07:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.97	ug/l	EPA .200.8	2	01/14/2022 09:07 BJ

MARTEL NO. 60412 44 CLIENT SAMPLE IDENTIFICATION MHS-44-DC [water fountain - Left--corridor - (2nd Floor)] Sample Date/Time 10/30/2021 07:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.04	ug/l	EPA .200.8	2	02/14/2022 19:48 BJ

MARTEL NO. 60412 45 CLIENT SAMPLE IDENTIFICATION MHS-45-DC [water fountain - Right--corridor - (2nd Floor)] Sample Date/Time 10/30/2021 07:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 19:50 BJ

MARTEL NO. 60412 47 CLIENT SAMPLE IDENTIFICATION MHS-47-DC [water fountain--media center - (2nd Floor)] Sample Date/Time 10/30/2021 07:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 19:53 BJ

MARTEL NO. 60412 48 CLIENT SAMPLE IDENTIFICATION MHS-48-SG [Hose bib--Outside concession stand - see map] Sample Date/Time 10/30/2021 08:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 19:55 BJ

MARTEL NO. 60412 49 CLIENT SAMPLE IDENTIFICATION MHS-49-FC [2 comp sink--Outside concession stand - see] Sample Date/Time 10/30/2021 08:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	19.5	ug/l*	EPA .200.8	2	02/14/2022 19:58 BJ



MARTEL NO. 60412 50 CLIENT SAMPLE IDENTIFICATION MHS-50-IM [Ice Machine --Outside concession stand - see ma] Sample Date/Time 10/30/2021 08:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	n/a		EPA .200.8	2	//

MARTEL NO. 60412 51 CLIENT SAMPLE IDENTIFICATION MHS-51-DC [Water Fountain - next to mech rm--Pool Fountain] Sample Date/Time 10/30/2021 07:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	53.7	ug/l*	EPA .200.8	2	01/14/2022 09:13 BJ

MARTEL NO. 60412 52 CLIENT SAMPLE IDENTIFICATION MHS-52-DC [Water Fountain--Pool Fountain - See map] Sample Date/Time 10/30/2021 07:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	16.1	ug/l*	EPA .200.8	2	02/14/2022 20:08 BJ

MARTEL NO. 60412 56 CLIENT SAMPLE IDENTIFICATION MHS-56-DC [water fountain - Left--Cooridor - (2nd Floor)] Sample Date/Time 10/30/2021 07:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 20:13 BJ

MARTEL NO. 60412 57 CLIENT SAMPLE IDENTIFICATION MHS-57-DC [water fountain - Right--Cooridor - (2nd Floor)] Sample Date/Time 10/30/2021 07:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 20:15 BJ

MARTEL NO. 60412 60 CLIENT SAMPLE IDENTIFICATION MHS-60-FC [Sink--Classroom (Sp-Ed) Life Skills] Sample Date/Time 10/30/2021 07:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 20:18 BJ

MARTEL NO. 60412 61 CLIENT SAMPLE IDENTIFICATION MHS-61-BU [Bottle Filler--Corridor - (Basement)] Sample Date/Time 10/30/2021 07:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 20:20 BJ

MARTEL NO. 60412 62 CLIENT SAMPLE IDENTIFICATION MHS-62-BU [Bottle Filler--Corridor - next to JROTC] Sample Date/Time 10/30/2021 07:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/14/2022 20:23 BJ



Certificate of Analysis

MARTEL NO.
60412 63

CLIENT SAMPLE IDENTIFICATION
MHS-63-BU [Bottle Filler--Corridor]

Sample Date/Time
10/30/2021 07:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.94	ug/l	EPA .200.8	2	02/14/2022 20:26 BJ

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 10/30/21 0653 End Date/Time: 10/30/21 0820

Sampler/Relinquished By: DS Received at Martel by: _____ Date/Time: 11/01/21 935

55- Maurice J. McDonough HS PSC #08.009
7165 Marshall Corner Road Pomfret, MD 20675

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO: **60412**

Martel #	Sample #	Location ID #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush		
							Flush Date	Sample Time	
✓ 1	1	MHS-1-DC	water fountain - Left	DC	corridor	C	10/29/21	0653	
✓ 2	2	MHS-2-DC	water fountain - Right	DC	corridor	C	↓	0653	
✓ 3	3	MHS-3-FC	island sink next to 3 comp sink	FC	Kitchen	C		0655	
✓ 4	4	MHS-4-KK	kettle	KK	Kitchen	C		0655	
✓ 5	5	MHS-5-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C		0657	
✓ 6	6	MHS-6-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C		0657	
✓ 7	7	MHS-7-FC	island sink	FC	Kitchen	C		0657	
✓ 8	8	MHS-8-FC	island sink near ice maker	FC	Kitchen	C		0658	
✗ 9	9	MHS-9-IM	Ice Machine	IM	Kitchen	C		0658 05	N/A
✓ 10	10	MHS-10-FC	2 comp sink	FC	Kitchen	C		10/29/21	0658
✓ 11	11	MHS-11-DC	water fountain	DC	Kitchen	C		0659	
✓ 12	12	MHS-12-DC	water fountain - Left	DC	cafeteria	C		0701	
✓ 13	13	MHS-13-DC	water fountain - Right	DC	cafeteria	C		0701	
✓ 14	14	MHS-14-FC	sink	FC	lounge	C		0702	
✓ 15	15	MHS-15-DC	water fountain - Left	DC	corridor	C		0704	
✓ 16	16	MHS-16-DC	water fountain - Right	DC	corridor	C		0704	
✓ 17	17	MHS-17-DC	water fountain	DC	main office	C		0705	
✓ 18	18	MHS-18-DC	water fountain - Left	DC	corridor	C		0706	
✓ 19	19	MHS-19-DC	water fountain - Center	DC	corridor	C		0706	
✓ 20	20	MHS-20-DC	water fountain - Right	DC	corridor	C		0707	
✓ 21	21	MHS-21-DC	water fountain - Left	DC	corridor	C		0709	
✓ 22	22	MHS-22-DC	water fountain - Right	DC	corridor	C	0709		
✗ 23	23	MHS-23-IM	Ice Machine	IM	training room - (Basement)	C	0711 05	N/A	
✓ 24	24	MHS-24-DC	water fountain - Left	DC	corridor - (Basement)	C	10/29/21	0712	
✓ 25	25	MHS-25-DC	water fountain - Right	DC	corridor - (Basement)	C	↓	0712	

55- Maurice J. McDonough HS PSC #08.009
7165 Marshall Corner Road Pomfret, MD 20675

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN
SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER**

Martel NO:

Flush 60412

✓	26	26	MHS-26-DC	water fountain - Left	DC	corridor	C	10/29/21	07124	BS
✓	27	27	MHS-27-DC	water fountain - Right	DC	corridor	C		0714	
✓	28	28	MHS-28-DC	water fountain - Left	DC	corridor	C		0716	
✓	29	29	MHS-29-DC	water fountain - Right	DC	corridor	C		0716	
✓	30	30	MHS-30-FC	sink	FC	LH-1B/ child care	C		0718	
✓	31	31	MHS-31-DB	bubbler	DB	LH-1B/ child care	C		0718	
✓	32	32	MHS-32-FC	sink - See map	FC	FCS-1/ home ec	C		0720	
✓	33	33	MHS-33-FC	sink - See map	FC	FCS-1/ home ec	C		0721	
✓	34	34	MHS-34-FC	sink - See map	FC	FCS-1/ home ec	C		0721	
✓	35	35	MHS-35-FC	sink - See map	FC	FCS-1/ home ec	C		0721	
✓	36	36	MHS-36-FC	sink - See map	FC	FCS-1/ home ec	C		0722	
✓	37	37	MHS-37-FC	sink - See map	FC	FCS-1/ home ec	C		0722	
✓	38	38	MHS-38-FC	sink - See map	FC	FCS-1/ home ec	C		0722	
✓	39	39	MHS-39-DC	water fountain - Left	DC	corridor	C		0724	
✓	40	40	MHS-40-DC	water fountain - Right	DC	corridor	C		0724	
✓	41	41	MHS-41-DC	water fountain	DC	FCS-1/ ROTC	C		0725	
✓	42	42	MHS-42-DC	water fountain - Left	DC	corridor - (2nd Floor)	C		0726	
✓	43	43	MHS-43-DC	water fountain - Right	DC	corridor - (2nd Floor)	C		0726	
✓	44	44	MHS-44-DC	water fountain - Left	DC	corridor - (2nd Floor)	C		0732	
✓	45	45	MHS-45-DC	water fountain - Right	DC	corridor - (2nd Floor)	C		0732	
✓	46	47	MHS-47-DC	water fountain	DC	media center - (2nd Floor)	C		0733	
✓	47	48	MHS-48-SG	Hose bib	SG	Outside concession stand - see map	C		0820	
✓	48	49	MHS-49-FC	2 comp sink	FC	Outside concession stand - see map	C	↓	0820	
X	49	50	MHS-50-IM	Ice Machine	IM	Outside concession stand - see map	C			
	50	51	MHS-51-DC	Water Fountain - next to mech rm	DC	Pool Fountain - See map	C		0752	
	51	52	MHS-52-DC	Water Fountain	DC	Pool Fountain - See map	C	↓	0751	
✓	52	56	MHS-56-DC	water fountain - Left	DC	Cooridor - (2nd Floor)	C	10/29/21	0730	
✓	53	57	MHS-57-DC	water fountain - Right	DC	Cooridor - (2nd Floor)	C		0730	
✓	54	60	MHS-60-FC	Sink	FC	Classroom (Sp-Ed) Life Skills	C		0744	
✓	55	61	MHS-61-BU	Bottle Filler	BU	Corridor - (Basement)	C		0712	
✓	56	62	MHS-62-BU	Bottle Filler	BU	Corridor - next to JROTC	C		0725	
✓	57	63	MHS-63-BU	Bottle Filler	BU	Corridor	C	↓	0701	