


District Energy Policy



Lighting levels will be maintained in accordance with the Illuminating Engineering Society (IES) of North America standards:

<u>Task Area</u>	<u>Foot-candles*</u>
Corridors/Stairways/Restrooms	10-20
Storage Rooms	10-20
Conference Rooms	20-50
General Offices	50
Classrooms	50
Cafeterias	50
Gymnasiums	30-70
Parking Areas (uncovered)	1-2

**A measure of light intensity on a surface being illuminated. Defined as one lumen of light per one square foot of surface area.*

IES lighting standards will be assessed and maintained through delamping and will be a consideration for remodeling and new construction projects.

Gym lights will be turned off if area will be unoccupied for a period in excess of 60 minutes. During spring and summer months, when phy-ed classes are outside, the gym lighting will be limited to walk-thru lighting and other minimal lighting requirements.

After school hours, all classroom and office windows will be closed and blinds/ shades will be drawn to $\frac{3}{4}$ the distance from the top of windowsill.

Night custodians should turn lights on only in the area they are currently working.

2. TEMPERATURE CONTROL

On regular school days, temperatures will be maintained for the entire building 60-90 minutes before the start of school until 60-90 minutes after dismissal. Special consideration will be given to certain preschool and special education classrooms when appropriate.

<u>Areas</u>	<u>Heating Season</u>	<u>Cooling Season</u>
Classrooms (grades K-12)	68-70 degrees F.	76-78 degrees F.
Gymnasiums & Locker Rooms	65-70 degrees F.	76-78 degrees F.
Offices	68-70 degrees F.	76-78 degrees F.
Shop Rooms	65-70 degrees F.	76-78 degrees F.
Halls	65-70 degrees F.	76-78 degrees F.
Kitchens & Cafeterias	65-70 degrees F.	76-78 degrees F.

(Temperatures are measured four feet above floor level in the center of the room.)