

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Monday, January 30, 2017 10:38 AM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Sampling Results - Administration Building
Attachments: Sample Location Map - Administration Building.pdf; W612115_Final Report_162017.pdf

Keith-

Fulcrum received drinking water analytical results for the Administration Building (ADM). Results report four samples with elevated copper concentrations. The sample numbers and locations are provided below:

OF-01: 1,590 µg/L, faucet in Mail/Copy room adjacent reception (Room 122)

OF-02: 1,290 µg/L, faucet in Workroom 141

WC-09: 1,230 µg/L, right water cooler fountain in hallway outside Conference Room 2

WC-10: 1,350 µg/L, left water cooler fountain in upstairs lobby

The blank included for this batch is labeled WC-13 and reports lead and copper concentrations below laboratory reporting limits. The spike we included in this batch (labeled WC-12 in the analytical results) is reporting at 1,100 µg/L for copper and 13 µg/L for lead, although we know these concentrations should be the action level for lead (15 µg/L) and copper (1,300 µg/L). As such, it is likely all lead and copper concentrations reported at or above the spiked sample concentration is at or above the action level.

Attached are the analytical results, and a sample location map. The link below will allow you to download pictures of the fixtures in question.

<https://efulcrum.sharefile.com/d-s1d8b241c57f4ead8>

Fulcrum recommends these fixtures be taken out of service until replacement or resampling.

Please feel free to contact me with any questions or concerns.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.