

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Tuesday, February 21, 2017 4:36 PM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Sampling - Amistad Elementary Results
Attachments: W612123_Final Report_162017.pdf; Sample Location Map - Amistad Elementary.pdf

Keith-

Fulcrum received initial drinking water analytical results for Amistad Elementary (AE). Results report four samples with an elevated lead concentration and one sample with an elevated copper concentration.

The blank included for this batch is labeled CF-41 and reports lead and copper concentrations below laboratory reporting limits. The spike we included in this batch is labeled CF-42 in the analytical results and reports at 1,200 µg/L for copper and 14 µg/L for lead. We know the spike contains a lead concentration of 15 µg/L, so it is likely all results reporting 14 µg/L or greater are at or above the action level for lead. A summary of samples and locations is listed below:

Lead-

CF-33: 15 µg/L, faucet in classroom opposite Classroom 6 (Room is unmarked. Please see attached map.)
CF-34: 15 µg/L, faucet in Special Programs classroom
OF-39: 28 µg/L, faucet in Library workroom
OF-40: 19 µg/L, faucet in office opposite Teacher's Lounge

Copper-

OF-40: 1,600 µg/L, faucet in office opposite Teacher's Lounge

Attached are the analytical results and a sample location map. The link below will allow you to download pictures of the fixtures in question.

<https://efulcrum.sharefile.com/d-s2e5c49ff14949579>

Fulcrum recommends these fixtures be taken out of service until replacement or resampling.

Please feel free to contact me with any questions or concerns.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.