

## Dustin Fisk

---

**From:** Amanda Enbysk <aenbysk@efulcrum.net>  
**Sent:** Thursday, March 23, 2017 10:06 AM  
**To:** Keith Colee  
**Cc:** Dustin Fisk; Ryan Mathews  
**Subject:** Drinking Water Sampling - Canyon View Elementary 3/18/17 Follow-Up Results  
**Attachments:** Rpt\_1703214\_Kennewick\_SD\_Drinking\_Water\_-\_Canyon\_View\_Final\_v1.pdf

Keith-

Fulcrum received results from follow-up sampling post aggressive flush conducted 3/18/2017 at Canyon View Elementary. A summary of results is below and analytical results from Fremont Analytical are attached.

Sample Identification and Location	Type of Faucet	Initial Copper Results (µg/L)	3/18/17 Copper Results (µg/L)
CVE31817-P-CDF-04: Music Room	Classroom Drinking Fountain	1,700	972
CVE31817-P-OF-47: Laboratory Blank	Distilled Blank	<10	<0.5
CVE31817-P-CF-48: Laboratory Spike	Lead and Copper Spike	1,200	1,380
<b>EPA Action Level</b>		<b>1,300</b>	<b>1,300</b>

Based on analytical results, the aggressive flush was successful at reducing copper concentrations at the remaining fixture initially identified above the action level. As such, this fixture can be put back into service.

No further testing or remediation is necessary at Canyon View Elementary at this time.

Please feel free to contact me with any questions.

Thank you,

Amanda Enbysk, Environmental Technician  
Fulcrum Environmental Consulting, Inc.  
406 North Second Street  
Yakima, WA 98901  
P: 509.574.0839 F: 505.575.8453

*Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.*