

## Dustin Fisk

**From:** Amanda Enbysk <aenbysk@efulcrum.net>  
**Sent:** Thursday, August 17, 2017 9:51 AM  
**To:** Keith Colee  
**Cc:** Dustin Fisk; Ryan Mathews  
**Subject:** Drinking Water Sampling - Chinook Middle School 8/15 Follow-Up  
**Attachments:** Rpt\_1708167\_KSD\_Drinking\_Water\_-\_Chinook\_MS\_Final\_v1.pdf

Keith-

We received results today from follow-up sampling conducted on Tuesday at Chinook Middle School and it's good news; All fixture locations initially sampled are now below both the action level and spike. Please see the table below for a summary. Analytical results are attached.

Sample Identification and Location	Type of Fixture	Initial Copper Results (µg/L)	5/20/17 Copper Results (µg/L)	8/15/17 Copper Results (µg/L)
CHK81517-P-CF-06: Choir/Orchestra Classroom	Classroom Faucet	1,414	3,380	173
CHK81517-P-KF-20: Room 104, east wall	Kitchen Faucet	3,266	1,320	86
CHK81517-P-CF-24: Room 103, south fixture	Classroom Faucet	2,017	1,550	409
CHK81517-P-WC-31: South entrance, left	Water Cooler Fountain	1,836	1,640	74.7
CHK81517-P-OF-34: Main office, conference room	Office Faucet	1,683	1,460	295
CHK81517-P-WC-35: Laboratory Blank	Distilled Water Blank	<1.00	4.70	<0.500
CHK81517-P-WC-36: Laboratory Spike	Lead and Copper Spike	1,339	1,300	1,400
<b>EPA Action Level</b>		<b>1,300</b>	<b>1,300</b>	<b>1,300</b>

Based on the analytical results, remediation was successful. No further sampling or remediation is necessary at Chinook Middle School at this time.

Please feel free to contact me with any questions.

Thanks again,

Amanda

**Amanda Enbysk, GIT**  
Environmental Geologist

experience balance commitment



*Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.*

*Electronic Attachments: The attached electronic documents have been provided for Fulcrum Environmental Consulting, Inc's client's express use for informational purposes. While every effort has been made to ensure the accuracy of the attached documents, only the final printed and signed document is considered valid. Use of the attached electronic document carries the potential for unintentional absence of pages, appendices, etc. that may be necessary to understand the breadth of the work product and Fulcrum Environmental Consulting, Inc. cannot be held responsible for decisions based on the electronic document.*