

## Dustin Fisk

---

**From:** Amanda Enbysk <aenbysk@efulcrum.net>  
**Sent:** Tuesday, January 10, 2017 4:58 PM  
**To:** Keith Colee  
**Cc:** Dustin Fisk; Ryan Mathews  
**Subject:** Drinking Water Sampling - Cottonwood Elementary Results Review  
**Attachments:** Cottonwood Elem\_W612098\_Final Report\_162017.pdf; Cottonwood Elementary\_Sampling Map.pdf; IMG\_7253.JPG

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

Keith-

Fulcrum received the first set of drinking water analytical results for Cottonwood Elementary from R.J. Lee today.

Upon review, one sample labeled OF-11 located in the staff lounge reports with a concentration of 25 µg/L (ppb), above the action level of 15 µg/L for lead. Attached are the results, a sample location map, and a picture of the fixture in question.

Fulcrum recommends this fixture be taken out of service until replaced or retested to confirm lead concentration.

No other samples from Cottonwood Elementary are reported with exceedances of lead or copper.

If you have any questions, please feel free to contact Ryan or me at 509-574-0839.

Thank you,

Amanda Enbysk, Environmental Technician  
Fulcrum Environmental Consulting, Inc.  
406 North Second Street  
Yakima, WA 98901  
P: 509.574.0839 F: 505.575.8453