

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Wednesday, March 22, 2017 9:58 AM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Sampling - Desert Hills Middle School 3/18/17 Follow-Up Results
Attachments: Rpt_1703208_Kennewick_SD_Drinking_Water_-_Desert_Hills_MS_Final_v1.pdf

Keith-

Fulcrum received results from follow-up sampling conducted 3/18/2017 of the remaining two fixtures above the copper action level at Desert Hills Middle School. A summary of results is below and analytical results from Fremont Analytical are attached.

DHM31817-P-CF-37: Room 109, E. middle fixture	Classroom Faucet	1,300	3,070
DHM31817-P-CF-38: Room 109, W. fixture	Classroom Faucet	1,500	1,400
DHM31817-P-CF-43: Laboratory Blank	Distilled Blank	<10	<0.5
DHM31817-P-CF-44: Laboratory Spike	Lead and Copper Spike	1,200	1,200
EPA Action Level		1,300	1,300

Based on analytical results, the aggressive flush was not successful at reducing copper concentrations at the two fixtures sampled.

These two fixtures should continue to remain out of service until further testing or remediation is completed.

Please feel free to contact me with any questions.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.