

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Friday, February 10, 2017 8:28 AM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Sampling Results - Hawthorne Elementary
Attachments: W612120_Final Report_162017.pdf; Sample Location Map - Hawthorne Elementary.pdf

Keith-

Fulcrum received drinking water analytical results for Hawthorne Elementary (HTE). Results report two samples with elevated copper concentrations. The blank included for this batch is labeled OF-43 and reports lead and copper concentrations below laboratory reporting limits. The spike included in this batch (labeled OF-44 in the analytical results) is reporting at 1,100 µg/L for copper, though we know this concentration should be 1,300 µg/L. As such, it is likely all results reporting at or above 1,100 µg/L are at or above the action level for copper.

Sample numbers and locations are provided below:

CF-06: 1,300 µg/L, faucet in Classroom 2

OF-32: 1,400 µg/L, drinking fountain at sink in Library Workroom

Attached are the analytical results and a sample location map. The link below will allow you to download a picture of the library fixture.

<https://efulcrum.sharefile.com/d-s5fdc4a79cfb4a9f8>

Fulcrum recommends fixtures reporting over the action level be taken out of service until remediation and resampling.

Please feel free to contact me with any questions or concerns.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.