

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Friday, February 3, 2017 10:05 AM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Sampling - Fruitland Building Results
Attachments: W612116_Final Report_162017.pdf; Sample Location Map - Fruitland Building.pdf

Keith-

Fulcrum received drinking water analytical results for the Fruitland Building (FLB). Results report one sample with an elevated lead concentration, listed below:

OF-12: 30 µg/L, faucet in Room 16

The blank included for this batch is labeled CF-16 and reports lead and copper concentrations below laboratory reporting limits. The spike we included in this batch (labeled CF-17 in the analytical results) is reporting at 1,290 µg/L for copper and 15 µg/L for lead.

Attached are the analytical results, and a sample location map. The link below will allow you to download a picture of the fixture in question.

<https://efulcrum.sharefile.com/d-s36ad5b3e557439c9>

Fulcrum recommends this fixture be taken out of service until replacement or resampling.

Please feel free to contact me with any questions or concerns.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.