

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Monday, March 13, 2017 9:54 AM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Sampling - Fruitland Building Follow-Up Results
Attachments: Rpt_1703026_Kennewick_SD_Drinking_Water_-_Fruitland_Building_Final_v1.pdf

Keith-

Fulcrum received results from follow-up sampling post fixture replacement conducted 3/2/2017 at the Fruitland Building. A summary of results is below and analytical results from Fremont Analytical are attached.

Sample Identification and Location	Type of Faucet	Initial Lead Results (µg/L)	Follow-Up Lead Results (µg/L)
FLB3217-P-OF-12: Room 16	Office Faucet	30	22
FLB3217-P-CF-16: Laboratory Blank	Distilled Water Blank	<1.0	<1.0
FLB3217-P-CF-17: Laboratory Spike	Lead and Copper Spike	15	17.5
EPA Action Level		15	15

Based on analytical results, the fixture replacement was not successful at reducing lead concentrations below the action level at the fixture tested. As such, this fixture should remain out of service until further testing or remediation is completed.

Please feel free to contact me with any questions.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.