

## Dustin Fisk

---

**From:** Amanda Enbysk <aenbysk@efulcrum.net>  
**Sent:** Thursday, January 12, 2017 10:56 AM  
**To:** Keith Colee; Dustin Fisk  
**Cc:** Ryan Mathews  
**Subject:** Drinking Water Sampling - Eastgate Elementary School (1 of 2)  
**Attachments:** W612100\_Final Report\_162017\_Eastgate\_reduced.pdf; Eastgate Elementary School - Sample Location Map\_reduced.pdf

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

Keith-

Fulcrum received more analytical results from R.J. Lee for Eastgate Elementary (EGE). Analytical results report nine samples with elevated copper. Sample locations are as follows:

KF-01: 1,300 µg/L, faucet on east side of island in kitchen  
CF-07: 1,400 µg/L, faucet in Classroom 15  
CF-11: 1,300 µg/L, faucet in Classroom 9  
NF-12: 2,000 µg/L, faucet in Health room/nurse's office  
NF-15: 1,300 µg/L, faucet in Staff work room adjacent to the Staff lounge  
CF-18: 1,400 µg/L, faucet in Classroom 6  
CF-19: 1,600 µg/L, faucet in Classroom 2  
CF-20: 1,600 µg/L, faucet in Classroom 3  
OF-24: 2,100 µg/L, faucet in Library workroom upstairs

Attached is a sample location map. Pictures will follow in a second email.

Fulcrum recommends each of these fixtures be taken out of service until either replacement or resampling.

Please don't hesitate to contact us with any questions.

Thank you,

Amanda Enbysk, Environmental Technician  
Fulcrum Environmental Consulting, Inc.  
406 North Second Street  
Yakima, WA 98901  
P: 509.574.0839 F: 505.575.8453