

## Dustin Fisk

---

**From:** Amanda Enbysk <aenbysk@efulcrum.net>  
**Sent:** Thursday, March 23, 2017 9:46 AM  
**To:** Keith Colee  
**Cc:** Dustin Fisk; Ryan Mathews  
**Subject:** Drinking Water Sampling - Eastgate Elementary 3/18/17 Follow-Up Results  
**Attachments:** Rpt\_1703212\_Kennewick\_SD\_Drinking\_Water\_-\_Eastgate\_Elem.\_Final\_v1.pdf

Keith-

Fulcrum received results from follow-up sampling post aggressive flush conducted 3/18/2017 at Eastgate Elementary. A summary of results is below and analytical results from Fremont Analytical are attached.

Sample Identification and Location	Type of Fixture	Initial Copper Results (µg/L)	1/21/17 Copper Results (µg/L)	3/4/17 Copper Results (µg/L)	3/18/17 Copper Results (µg/L)
EGE31817-P-NF-12: Nurse's Office	Nurse's Faucet	2,000	1,660	1,350	797
EGE31817-P-OF-15: Work Room	Office Faucet	1,300	1,590	1,270	694
EGE31817-P-CF-19: Room 02	Classroom Faucet	1,600	1,480	1,300	578
EGE31817-P-CF-20: Room 03	Classroom Faucet	1,600	1,730	1,280	674
EGE31817-P-OF-24: Library Storage	Office Faucet	2,100	2,090	1,650	821
EGE31817-P-CF-34: Laboratory Blank	Distilled Blank	<10	0.60	<0.5	0.760
EGE31817-P-CF-35: Laboratory Spike	Lead and Copper Spike	1,300	-	1,220	1,310
<b>EPA Action Level</b>		<b>1,300</b>	<b>1,300</b>	<b>1,300</b>	<b>1,300</b>

Based on analytical results, the aggressive flush was successful at reducing copper concentrations at all fixtures that remained above the action level from previous sampling events. As such, these fixtures can be put back into service.

No further testing or remediation is necessary at Eastgate Elementary at this time.

Please feel free to contact me with any questions.

Thank you,

Amanda Enbysk, Environmental Technician  
Fulcrum Environmental Consulting, Inc.  
406 North Second Street  
Yakima, WA 98901  
P: 509.574.0839 F: 505.575.8453

*Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.*