Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Tuesday, February 28, 2017 8:39 AM

To: Keith Colee

Cc: Dustin Fisk; Ryan Mathews

Subject: Drinking Water Sampling - Highlands Middle School Follow-Up Results

Attachments: Rpt_1702288_Kennewick_SD_Drinking_Water_-_Highlands_Middle_Sch_Final_v1.pdf

Keith-

Fulcrum received results from follow-up sampling following preconditioning of a fixture replaced for lead. A summary of analytical results is below and results from Fremont Analytical are attached.

Sample Identification and Location	Type of Fixture	Initial Lead Results (µg/L)	Follow- Up Lead Results (µg/L)
HMS22517-P-CF-14: Room 20	Classroom Faucet	19	1.94
HMS22517-P-CDF-35: Laboratory Spike	Lead and Copper Spike	16.5	13.5
HMS22517-P-OF-36: Laboratory Blank	Distilled Blank	<1.0	<1.0
EPA Action Level		15	15

Based on the analytical results, the fixture replacement was successful at reducing lead concentrations below the action level at this location.

Fulcrum collected follow-up samples on 1/28/2017 from four other replaced fixtures initially identified with elevated lead. Results demonstrated the fixture replacement was also successful at reducing lead concentrations at the four other replaced fixtures. As such, fixture replacement was successful at reducing lead concentrations below the action level at all locations initially above the action level for lead.

Evaluation at Highlands Middle School continues for fixture locations that still report concentrations above the action level for copper.

Please feel free to contact me with any questions.

Thank you,

Amanda Enbysk, Environmental Technician Fulcrum Environmental Consulting, Inc. 406 North Second Street Yakima, WA 98901

P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.