



RJ LeeGroup, Inc. | Columbia Basin Analytical Laboratories

2710 North 20th Avenue, Pasco WA 99301

Tel: (509) 545-4989 | Fax: (509) 544-6010

Fulcrum Environmental  
406 N. 2nd St.  
Yakima, WA 98901

### Subject: Chemical Analysis Report

Columbia Basin Analytical Laboratories received 38 sample(s) on 12/21/16 for analysis. These sample(s) have been assigned a login order number of W612103. Enclosed is the final report that consists of a summary report of the sample(s), and a copy of the chain of custody.

### General Lab Comments

The results provided in this report relate only to the items tested. Sample(s) were received in acceptable conditions unless otherwise noted in the comments above. Sample(s) have not been field blank corrected unless otherwise noted in the general set comments above. The sample(s) were prepared in accordance with EPA 200.8 and analyzed in compliance with EPA 200.8. This test report shall not be reproduced, except in full, without written approval of Columbia Basin Analytical Laboratories. Any questions, please contact our office.

*All samples were diluted 1:10.*

*X - Samples that exceeded the instrument calibration range were rerun at a 1:100 dilution, necessitating a 10-fold increase in the PQL.*

Release of the data contained in the hard copy report has been authorized by the Laboratory Director or a designee as verified by the following signature. This report has been administratively reviewed by the following individual:

01/12/17

Project Coordinator II, M. Fernanda Pincheira

Date

If you have any questions please feel free to contact Fernanda Pincheira at [MPincheira@rjleegroup.com](mailto:MPincheira@rjleegroup.com).



## Laboratory Report

Amanda Enbysk  
Fulcrum Environmental  
406 N. 2nd St.  
Yakima, WA 98901

RJ Lee Group No.: W612103  
COC No.: Kennewick  
Samples Received: 12/21/16  
Analysis/Prep Date: 01/11/17  
Report Date: 01/12/17

Client Project:

Fulcrum Kennewick

**Sample Name:** KMH122116-P-NF-01 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-01 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.3	0.1	X
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-OF-02 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-02 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.97	0.01	
Lead	EPA 200.8	0.001	0.001	

**Sample Name:** KMH122116-P-OF-03 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-03 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.1	0.1	X
Lead	EPA 200.8	0.001	0.001	

**Sample Name:** KMH122116-P-WC-04 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-04 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.58	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-WC-05 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-05 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.49	0.01	
Lead	EPA 200.8	< 0.001	0.001	

Columbia Basin Analytical Laboratories | 2710 North 20th Avenue, Pasco WA 93301 | 509.545.4989

WWW.RJLEEGROUP.COM

Report Template: GenMetalReportFull\_v12.rpt

Approved: 01/12/17 7:58  
Report Time Stamp: 01/12/17 16:01



**Sample Name:** KMH122116-P-WC-06 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-06 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.3	0.1	X
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-KF-07 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-07 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.1	0.1	X
Lead	EPA 200.8	0.002	0.001	

**Sample Name:** KMH122116-P-KF-08 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-08 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.78	0.01	
Lead	EPA 200.8	0.002	0.001	

**Sample Name:** KMH122116-P-KF-09 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-09 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.94	0.01	
Lead	EPA 200.8	0.003	0.001	

**Sample Name:** KMH122116-P-KF-10 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-10 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.74	0.01	
Lead	EPA 200.8	0.003	0.001	

**Sample Name:** KMH122116-P-KF-11 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-11 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.76	0.01	
Lead	EPA 200.8	0.003	0.001	



**Sample Name:** KMH122116-P-KF-12 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-12 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.79	0.01	
Lead	EPA 200.8	0.003	0.001	

**Sample Name:** KMH122116-P-KF-13 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-13 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.3	0.1	X
Lead	EPA 200.8	0.004	0.001	

**Sample Name:** KMH122116-P-DF-14 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-14 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.2	0.1	X
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-DF-15 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-15 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.2	0.1	X
Lead	EPA 200.8	0.003	0.001	

**Sample Name:** KMH122116-P-OF-16 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-16 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.85	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-OF-17 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-17 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.88	0.01	
Lead	EPA 200.8	0.001	0.001	



**Sample Name:** KMH122116-P-DF-18 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-18 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.1	0.1	X
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-WC-19 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-19 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.74	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-OF-20 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-20 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.83	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-CDF-21 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-21 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.4	0.1	X
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-KF-22 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-22 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.65	0.01	
Lead	EPA 200.8	0.004	0.001	

**Sample Name:** KMH122116-P-KF-23 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-23 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.61	0.01	
Lead	EPA 200.8	0.002	0.001	



**Sample Name:** KMH122116-P-KF-24 **Matrix:** Potable Water  
**RJ Lee Grp. ID:** W612103-24

**Date Received:** 12/21/16  
**Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.74	0.01	
Lead	EPA 200.8	0.001	0.001	

**Sample Name:** KMH122116-P-WC-25 **Matrix:** Potable Water  
**RJ Lee Grp. ID:** W612103-25

**Date Received:** 12/21/16  
**Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.36	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-KF-26 **Matrix:** Potable Water  
**RJ Lee Grp. ID:** W612103-26

**Date Received:** 12/21/16  
**Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.90	0.01	
Lead	EPA 200.8	0.006	0.001	

**Sample Name:** KMH122116-P-WC-27 **Matrix:** Potable Water  
**RJ Lee Grp. ID:** W612103-27

**Date Received:** 12/21/16  
**Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.85	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-DF-28 **Matrix:** Potable Water  
**RJ Lee Grp. ID:** W612103-28

**Date Received:** 12/21/16  
**Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.94	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-DF-30 **Matrix:** Potable Water  
**RJ Lee Grp. ID:** W612103-29

**Date Received:** 12/21/16  
**Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.3	0.1	X
Lead	EPA 200.8	< 0.001	0.001	



**Sample Name:** KMH122116-P-DF-31 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-30 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.5	0.1	X
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-DF-32 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-31 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.3	0.1	X
Lead	EPA 200.8	0.004	0.001	

**Sample Name:** KMH122116-P-DF-33 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-32 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.76	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-DF-34 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-33 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.91	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KHM122116-P-KF-35 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-34 **Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.3	0.1	X
Lead	EPA 200.8	0.002	0.001	

**Sample Name:** KHM122116-P-WC-36 **Matrix:** Potable Water **Date Received:** 12/21/16  
**RJ Lee Grp. ID:** W612103-35 **Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.78	0.01	
Lead	EPA 200.8	< 0.001	0.001	



**Sample Name:** KMH122116-P-WC-37 **Matrix:** Potable Water  
**RJ Lee Grp. ID:** W612103-36

**Date Received:** 12/21/16  
**Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.27	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Sample Name:** KMH122116-P-DF-38 **Matrix:** Potable Water  
**RJ Lee Grp. ID:** W612103-37

**Date Received:** 12/21/16  
**Date Analyzed:** 01/11/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.2	0.1	X
Lead	EPA 200.8	0.013	0.001	

**Sample Name:** KMH122116-P-CF-39 **Matrix:** Potable Water  
**RJ Lee Grp. ID:** W612103-38

**Date Received:** 12/21/16  
**Date Analyzed:** 01/10/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	< 0.010	0.01	
Lead	EPA 200.8	< 0.001	0.001	

**Report Qualifiers:**

*A = Target Analyte media breakthrough suspect, see analytical report*  
*D = Analyte analyzed in a dilution*  
*E = Report concentration was above the instrument calibration range*  
*J = Analyte detected below quantitation limits, concentration is estimated*  
*P = Library spectrum match, rsd >90% w RT match*  
*Q = Result out of method specific acceptance QC criteria*  
*S = Spike Recovery outside accepted recovery limits*  
*Z = Not ELAP accredited analyte*  
*ND = Not Detected*

*B = Analyte detected in the associated blank*  
*d = Data that exceeds the RSD criteria set by the SOP*  
*H = Holding times for preparation or analysis exceeded*  
*L = Sample condition at receipt out of compliance with method defined conditions*  
*R = RPD (relative percent difference) outside accepted recovery limits*  
*U = Analyte analyzed for but not detected*  
*N/A = Not Applicable*

QA Officer/Organic Analytical SME John Coddington

*These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, RJ Lee Group will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee will be assessed for the return of any samples. Unless otherwise noted, samples were received in an acceptable condition. This laboratory operates in accordance with ISO 17025 guidelines, and holds limited scopes of accreditation under ORELAP Lab Code 4061 AIHA-LAP, LLC Lab ID 178656 EPA ID WA01195 and WA DOE Lab ID C859. This report may not be used to claim product endorsement by any laboratory accrediting agency. The results contained in this report relate only to the items tested or to the sample(s) as received by the laboratory. Any reproduction of this document must be in full for the report to be valid. Quality control data is available upon request.*

Columbia Basin Analytical Laboratories | 2710 North 20th Avenue, Pasco WA 93301 | 509.545.4989

WWW.RJLEEGROUP.COM

Report Template: GenMetalReportFull\_v12.rpt

Approved: 01/12/17 7:58  
 Report Time Stamp: 01/12/17 16:01



# Request for Environmental and IH Laboratory Analytical Services

W612103

ATTENTION TO: **RYAN MATHEWS** Client Job No.: **162017**

Lab Use Only: Project No.: Client No.: Turnaround Request: Standard: **Yes** No If 'No,' No. of Business Days: **162017**

Report Results To: Name: Amanda Enbysk, Ryan Mathews Logged In By: Company: Fulcrum Environmental Consulting

Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901

Phone: (509) 574-0839 Fax: (509) 575-8453

Call with Verbal Results: Email Results To: aenbysk@fulcrum.net, CC: rmathews@fulcrum.net

Send Invoice To: Name: Lorrie Boutillier Company: Fulcrum Environmental Email: lboutillier@fulcrum.net

Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901

Phone: (509) 574-0839 Fax: (509) 575-8453

Client Sample ID	Sample Description	Sample Date	Sample Time		Wipe Area / Air	EPA 200.8: Pb, Cu	Analysis Requested	Pres. Upon Receipt (Y/N)	Preservation	Matrix	Container Type	pH	No. Containers
			Start	Stop									
KMTH12116-P-01	Nurse's office	12/21/16				X							19.1
KMTH12116-P-02	415, Conference Room office												19.1
KMTH12116-P-03	512A, Staff workroom												17.1
KMTH12116-P-04	Hallway opposite 512												15.6
KMTH12116-P-05	Hallway opposite 512												14.1
KMTH12116-P-06	Between 410 & 436												14.1
KMTH12116-P-07	Room 436, west wall south												16.2
KMTH12116-P-08	Room 436, west wall center												15.8
KMTH12116-P-09	Room 436, west wall north												14.8
KMTH12116-P-10	Room 436, west wall west												16.6
KMTH12116-P-11	Room 436, north wall center												16.6

Chain of Custody: Relinquished By (Signature): *[Signature]* Date: 12/21/2016 Time: 1430  
 Relinquished By (Print Name): Company Name: Method of Shipment:

Chain of Custody: Received By (Signature): *[Signature]* Date: DEC 21 2016 Time: 1430  
 Received By (Print Name): Company Name: Method of Shipment:

Pennsylvania - HQ  
 350 Hochberg Road  
 Monroeville, PA 15146

Washington  
 Columbia Basin Analytical Laboratories  
 2710 North 20th Avenue  
 Pasco, WA 99301

724.325.1776 Phone  
 724.733.1799 Fax

509.545.4989 Phone  
 509.544.6010 Fax



W612103

ATTENTION TO: RYAN MATHEWS

Purchase Order No.:

Client Job No.:

162017

Lab Use Only	Project No.:	Client No.:	Turnaround Request	Standard: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	If 'No,' No. of Business Days:	Pres. Upon Receipt (Y/N)	UNPR	DW	Container Type	pH	No. Containers
	Date Logged In:	Logged In By:	Drinking Water	System ID #:	Accreditation (please list below):						
Report Results To	Name: Amanda Embysk, Ryan Mathews Company: Fulcrum Environmental Consulting Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453 Call with Verbal Results: Email Results To: aembysk@fulcrum.net, CC: rmathews@fulcrum.net Fax Results To:		Sample Only	Multiple Sources #s:							
Send Invoice To	Company: Fulcrum Environmental Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453		Chemistry Analysis Key	Preservation: Unpres H <sub>2</sub> SO <sub>4</sub> 4°C HNO <sub>3</sub> NaOH Na <sub>2</sub> SO <sub>4</sub> Other	Matrix: WW=Wastewater GW=Groundwater S=Soil/Sludge E=Extract						
Special Instructions	Name: Lorrie Boutillier Company: Fulcrum Environmental Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453		Analysis Requested								

Client Sample ID	Sample Description	Sample Date	Sample Time		Wiper Area / Air Volume	Chain of Custody	Received By (Signature)	Received By (Print Name)	Date	Time
			Start	Stop						
KMHT03116-0-KF-12	Room 434, west					X				
KMHT03116-0-KF-13	Room 434, Center Island									
KMHT03116-0-KF-14	SW entry of 300 bldg, 5th fl									
KMHT03116-0-KF-15	SWE entry of 300 bldg, West									
KMHT03116-0-KF-16	Staff workroom 2, 339									
KMHT03116-0-KF-17	Staff workroom 1, 335									
KMHT03116-0-KF-18	Bldg 300, NW entrance									
KMHT03116-0-KF-19	Library Entrance									
KMHT03116-0-KF-20	Library workroom, 309									
KMHT03116-0-KF-21	Classroom 173, music									
KMHT03116-0-KF-22	Kitgarnat fill South									

Chain of Custody	Relinquished By (Signature):	Date: 01/16	Time: 1430
Chain of Custody	Relinquished By (Print Name):	Date: DEC 21 2016	Time: 1430
Chain of Custody	Relinquished By (Signature):	Date:	Time:
Chain of Custody	Relinquished By (Print Name):	Date:	Time:

Pennsylvania - HQ  
350 Hochberg Road  
Monroeville, PA 15146  
724.325.1776 Phone  
724.733.1799 Fax

Washington  
Columbia Basin Analytical Laboratories  
2710 North 20th Avenue  
Pasco, WA 99301  
509.545.4989 Phone  
509.544.6010 Fax





# Request for Environmental and IH Laboratory Analytical Services

W612103

ATTENTION TO: <b>RYAN MATHEWS</b>		Purchase Order No.: <b>162017</b>		Client Job No.: <b>162017</b>	
Lab Use Only		Project No.: Date Logged In:		Client No.: Logged In By:	
Report Results To		Name: Amanda Embysk, Ryan Mathews Company: Fulcrum Environmental Consulting Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453 Call with Verbal Results: Email Results To: aembysk@fulcrum.net, CC: rmathews@fulcrum.net Fax Results To:		Turnaround Request Standard: <b>Yes</b> No If 'No,' No. of Business Days: Sample Purpose: <b>Information X</b> Regulatory <input type="checkbox"/> Accreditation (please list below): System ID #: DOH Source #:	
Send Invoice To		Name: Lorie Boutillier Company: Fulcrum Environmental Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453		Drinking Water Sample Only Multiple Sources #: Preservation: <input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> Other <input type="checkbox"/> Matrix: WW=Wastewater GW=Groundwater S=Soil/Sludge E=Extract Container: P=Plastic G=Glass W=Wipe A=Air (filter or tube)	
Special Instructions		EPA 200.8: Pb, Cu		Chemistry Analysis Key Unpres H <sub>2</sub> SO <sub>4</sub> 4°C HCl HNO <sub>3</sub> NaOH Na <sub>2</sub> SO <sub>4</sub> Other SW=Surface Water DW=Drinking Water O=Oil X=Other	
Client Sample ID		Sample Description		Sample Date	
Sample Time		Start		Stop	
Wipe Area / Air Volume		Pres. Upon Receipt (Y/N)		UNPR. DW P	
EPA 200.8: Pb, Cu		Preservation		Matrix	
Chain of Custody		Chain of Custody		Container Type	
Relinquished By (Signature): Relinquished By (Print Name): Company Name:		Received By (Signature): Received By (Print Name): Company Name:		pH	
Date: 12/11/16 Time: 1430		Date: 12/11/16 Time: 1430		No. Containers	
Method of Shipment:		Method of Shipment:			

Pennsylvania - HQ  
350 Hochberg Road  
Monroeville, PA 15146  
724.325.1776 Phone  
724.733.1799 Fax

Washington  
Columbia Basin Analytical Laboratories  
2710 North 20th Avenue  
Pasco, WA 99301  
509.545.4989 Phone  
509.544.6010 Fax



# Request for Environmental and IH Laboratory Analytical Services

W612103

ATTENTION TO: <b>RYAN MATHEWS</b>		Client Job No.: <b>162017</b>	
Lab Use Only	Project No.: Date Logged In: Logged In By:	Turnaround Request	Standard: <b>Yes</b> No If No, No. of Business Days: Sample Purpose: <b>Information X</b> Regulatory <input type="checkbox"/> Accreditation (please list below): System ID #: DOH Source #: Multiple Sources #s:
Report Results To	Name: Amanda Embysk, Ryan Mathews Company: Fulcrum Environmental Consulting Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453 Call with Verbal Results: Email Results To: aembysk@fulcrum.net CC: rmathews@fulcrum.net Fax Results To:	Drinking Water Sample Only	Preservation: <input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> Other <input type="checkbox"/> Matrix: <input type="checkbox"/> WW=Wastewater <input type="checkbox"/> GW=Groundwater <input type="checkbox"/> S=Soil/Sludge <input type="checkbox"/> E=Extract Container: <input type="checkbox"/> P=Plastic <input type="checkbox"/> G=Glass <input type="checkbox"/> W=Wipe <input type="checkbox"/> A=Air (filter or tube)
Send Invoice To	Name: Lorrie Boutilier Company: Fulcrum Environmental Email: lboutilier@fulcrum.net Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453	Chemistry Analysis Key	Analysis Requested
Special Instructions		EPA 200.8: Pb, Cu	Pres. Upon Receipt (Y/N)
Client Sample ID	Sample Description	Sample Date	Start
			Stop
			Wipe Area / Air Volume
KNH120116-P-DF-34	Upper gym	12/21/16	
KNH120116-P-DF-35	Multi of iron containers	12/21/16	
KNH120116-P-DF-36	200 Slidy opposite 219	12/21/16	
KNH120116-P-DF-37	water room outside of kitchen	12/21/16	
KNH120116-P-DF-38	Auditorium Concessions	12/21/16	
KNH120116-P-DF-39	Custodian's storage	12/21/16	
KNH120116-P-DF-40	Computer labball, 990 213	12/21/16	
KNH120116-P-DF-41	Room 400	12/21/16	
KNH120116-P-DF-42	Room 525	12/21/16	
Chain of Custody	Relinquished By (Signature): <i>[Signature]</i> Relinquished By (Print Name): Company Name:	Received By (Signature): <i>[Signature]</i> Received By (Print Name): Company Name:	Date: <b>DEC 21 2016</b> Time: <b>1430</b>
Chain of Custody	Relinquished By (Signature): Relinquished By (Print Name): Company Name:	Received By (Signature): Received By (Print Name): Company Name:	Date: Time:

Pennsylvania - HQ  
350 Hochberg Road  
Monroeville, PA 15146  
724.325.1776 Phone  
724.733.1799 Fax

Washington  
Columbia Basin Analytical Laboratories  
2710 North 20th Avenue  
Pasco, WA 99301  
509.545.4989 Phone  
509.544.6010 Fax

