

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Wednesday, January 18, 2017 9:42 AM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Sampling Results - Kennewick High School
Attachments: W612102_Final Report_162017.pdf; Kennewick High School - Sample Location Map.pdf

Follow Up Flag: Follow up
Flag Status: Completed

Keith-

Fulcrum received drinking water analytical results for Kennewick High School (KHS). Three fixtures are reporting with copper concentrations above the action level. A summary of sample locations for each is below:

OF-13: 1,300 µg/L, drinking fountain outside room 710
CDF-32: 1,500 µg/L, drinking fountain in Classroom 206
OF-44: 1,400 µg/L, faucet in NW corner of Girl's Locker Room
OF-50: 2,400 µg/L, faucet in Classroom 115

Attached are the analytical results and a sample location map. The link below will allow you to download pictures of each of these fixtures.

<https://efulcrum.sharefile.com/d-sb1a1a483d8f4b109>

Fulcrum recommends these fixtures be taken out of service until replacement or resampling.

Please feel free to contact us with any questions or concerns.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.