

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Monday, January 30, 2017 10:23 AM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Sampling Results - Legacy High School
Attachments: Sample Location Map - Legacy High School.pdf; W612113_Final Report_162017.pdf; LHS-CF-02.JPG

Keith-

Fulcrum received drinking water analytical results for Legacy High School (LHS). Results report one sample with an elevated copper concentration. The sample number and location is provided below:

CF-02: 1,990 µg/L, faucet in Classroom 1

The blank included for this batch is labeled CF-06 and reports lead and copper concentrations below laboratory reporting limits. The spike included for this batch is labeled CF-07 and reports at 1240 µg/L for copper and 14 µg/L for lead.

Attached are the analytical results, a sample location map, and a picture of the fixture in question.

Fulcrum recommends these fixtures be taken out of service until replacement or resampling.

Please feel free to contact me with any questions or concerns.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.