

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Thursday, February 16, 2017 8:16 AM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Follow-Up Sampling - Legacy High School Results
Attachments: Rpt_1702133_Kennewick_School_District_-_Legacy_High_School_Final_v1.pdf

Keith-

Fulcrum received results of follow-up drinking water sampling conducted February 11, 2017 post aggressive flush at Legacy High School. A summary of results is below and analytical results from Fremont Analytical are attached.

Sample Identification and Location	Type of Fixture	Initial Copper Results (µg/L)	Follow-Up Copper Results (µg/L)
LHS122116-P-CF-02: Room 1	Classroom Faucet	1,990	1,850
LHS122116-P-CF-06: Laboratory Blank	Distilled Blank	<10	<0.5
LHS122116-P-CF-07: Laboratory Spike	Lead and Copper Spike	1,240	1,220
EPA Action Level		1,300	1,300

Based on analytical results, the aggressive flush was not successful at reducing copper concentrations below the action level for the fixture tested. This fixture should stay out of service until further testing or remediation brings the concentration at this location below the action level for copper.

Please feel free to contact me with any questions.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.