

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Monday, February 13, 2017 11:01 AM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Sampling - Park Middle School Initial Results
Attachments: W612122_Final Report_162017.pdf; Sample Location Map - Park Middle School.pdf

Keith-

Fulcrum received initial drinking water analytical results for Park Middle School (PMS). Results report six samples with an elevated copper concentration. The blank included for this batch is labeled CF-35 and reports lead and copper concentrations below laboratory reporting limits. The spike we included in this batch is labeled CF-36 in the analytical results and reports at 1,400 µg/L for copper and 14 µg/L for lead. We know the spike contains a copper concentration of 1,300 µg/L, so it is likely all results reporting at 1,400 µg/L or greater are at or above the action level for copper. A summary of samples and locations is listed below:

KF-01: 1,500 µg/L, sprayer at sink on north wall of kitchen
CDF-12: 1,400 µg/L, drinking fountain at sink in Music room/Stage
DF-14: 1,400 µg/L, drinking fountain in Girl's Locker Room
CDF-19: 1,500 µg/L, drinking fountain at sink in Room 214 (Art)
CF-30: 1,400 µg/L, faucet in Room 314
CF-34: 1,400 µg/L, faucet in Room 305

Attached are the analytical results and a sample location map. The link below will allow you to download pictures of the fixtures in question.

<https://efulcrum.sharefile.com/d-sb80f31d1c204155b>

Fulcrum recommends these fixtures be taken out of service until replacement or resampling.

Please feel free to contact me with any questions or concerns.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.