



**Fremont**  
*Analytical*

3600 Fremont Ave. N.  
Seattle, WA 98103  
T: (206) 352-3790  
F: (206) 352-7178  
info@fremontanalytical.com

**Fulcrum Environmental**

Ryan Mathews  
406 N. 2nd Street  
Yakima, WA 98901

**RE: Kennewick SD - Ridgeview Elementary Follow-Up Sampling  
Work Order Number: 1702038**

February 07, 2017

**Attention Ryan Mathews:**

Fremont Analytical, Inc. received 14 sample(s) on 2/3/2017 for the analyses presented in the following report.

***Drinking Water Metals by EPA Method 200.8***

This report consists of the following:

- Case Narrative
- Analytical Results
- Applicable Quality Control Summary Reports
- Chain of Custody

All analyses were performed consistent with the Quality Assurance program of Fremont Analytical, Inc. Please contact the laboratory if you should have any questions about the results.

Thank you for using Fremont Analytical.

Sincerely,

Chelsea Ward  
Project Manager

DoD/ELAP Certification #L2371, ISO/IEC 17025:2005  
ORELAP Certification: WA 100009-007 (NELAP Recognized)

**CLIENT:** Fulcrum Environmental  
**Project:** Kennewick SD - Ridgeview Elementary Follo  
**Work Order:** 1702038

## Work Order Sample Summary

Lab Sample ID	Client Sample ID	Date/Time Collected	Date/Time Received
1702038-001	RVE12817-P-KF-03	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-002	RVE12817-S-KF-03	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-003	RVE12817-T-KF-03	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-004	RVE12817-P-CF-17	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-005	RVE12817-S-CF-17	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-006	RVE12817-T-CF-17	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-007	RVE12817-P-CF-26	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-008	RVE12817-S-CF-26	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-009	RVE12817-T-CF-26	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-010	RVE12817-P-CF-38	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-011	RVE12817-S-CF-38	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-012	RVE12817-T-CF-38	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-013	RVE12817-P-CF-41	01/28/2017 10:00 AM	02/03/2017 3:12 PM
1702038-014	RVE12817-P-CF-42	01/28/2017 10:00 AM	02/03/2017 3:12 PM

---

**CLIENT:** Fulcrum Environmental**Project:** Kennewick SD - Ridgeview Elementary Follow-Up Sampling

---

## WorkOrder Narrative:

## I. SAMPLE RECEIPT:

Samples receipt information is recorded on the attached Sample Receipt Checklist.

## II. GENERAL REPORTING COMMENTS:

Results are reported on a wet weight basis unless dry-weight correction is denoted in the units field on the analytical report ("mg/kg-dry" or "ug/kg-dry").

Matrix Spike (MS) and MS Duplicate (MSD) samples are tested from an analytical batch of "like" matrix to check for possible matrix effect. The MS and MSD will provide site specific matrix data only for those samples which are spiked by the laboratory. The sample chosen for spike purposes may or may not have been a sample submitted in this sample delivery group. The validity of the analytical procedures for which data is reported in this analytical report is determined by the Laboratory Control Sample (LCS) and the Method Blank (MB). The LCS and the MB are processed with the samples and the MS/MSD to ensure method criteria are achieved throughout the entire analytical process.

## III. ANALYSES AND EXCEPTIONS:

Exceptions associated with this report will be footnoted in the analytical results page(s) or the quality control summary page(s) and/or noted below.

## Prep Sample Comments:

1702038-001A 205387: Prep Comments for EPA200.8, Sample 1702038-001A: Turbidity: 0.05 NTU  
1702038-002A 205388: Prep Comments for EPA200.8, Sample 1702038-002A: Turbidity: 0.01 NTU  
1702038-003A 205389: Prep Comments for EPA200.8, Sample 1702038-003A: Turbidity: 0.01 NTU  
1702038-004A 205390: Prep Comments for EPA200.8, Sample 1702038-004A: Turbidity: 0.07 NTU  
1702038-005A 205391: Prep Comments for EPA200.8, Sample 1702038-005A: Turbidity: 0.01 NTU  
1702038-006A 205392: Prep Comments for EPA200.8, Sample 1702038-006A: Turbidity: 0.01 NTU  
1702038-007A 205393: Prep Comments for EPA200.8, Sample 1702038-007A: Turbidity: 0.08 NTU  
1702038-008A 205394: Prep Comments for EPA200.8, Sample 1702038-008A: Turbidity: 0.01 NTU  
1702038-009A 205395: Prep Comments for EPA200.8, Sample 1702038-009A: Turbidity: 0.01 NTU  
1702038-010A 205396: Prep Comments for EPA200.8, Sample 1702038-010A: Turbidity: 0.05 NTU  
1702038-011A 205397: Prep Comments for EPA200.8, Sample 1702038-011A: Turbidity: 0.01 NTU  
1702038-012A 205398: Prep Comments for EPA200.8, Sample 1702038-012A: Turbidity: 0.08 NTU  
1702038-013A 205399: Prep Comments for EPA200.8, Sample 1702038-013A: Turbidity: 0.03 NTU  
1702038-014A 205400: Prep Comments for EPA200.8, Sample 1702038-014A: Turbidity: 0.01 NTU

**Qualifiers:**

- \* - Flagged value is not within established control limits
- B - Analyte detected in the associated Method Blank
- D - Dilution was required
- E - Value above quantitation range
- H - Holding times for preparation or analysis exceeded
- I - Analyte with an internal standard that does not meet established acceptance criteria
- J - Analyte detected below Reporting Limit
- N - Tentatively Identified Compound (TIC)
- Q - Analyte with an initial or continuing calibration that does not meet established acceptance criteria (<20%RSD, <20% Drift or minimum RRF)
- S - Spike recovery outside accepted recovery limits
- ND - Not detected at the Reporting Limit
- R - High relative percent difference observed

**Acronyms:**

- %Rec - Percent Recovery
- CCB - Continued Calibration Blank
- CCV - Continued Calibration Verification
- DF - Dilution Factor
- HEM - Hexane Extractable Material
- ICV - Initial Calibration Verification
- LCS/LCSD - Laboratory Control Sample / Laboratory Control Sample Duplicate
- MB or MBLANK - Method Blank
- MDL - Method Detection Limit
- MS/MSD - Matrix Spike / Matrix Spike Duplicate
- PDS - Post Digestion Spike
- Ref Val - Reference Value
- RL - Reporting Limit
- RPD - Relative Percent Difference
- SD - Serial Dilution
- SGT - Silica Gel Treatment
- SPK - Spike
- Surr - Surrogate



## Analytical Report

Work Order: 1702038  
Date Reported: 2/7/2017

**CLIENT:** Fulcrum Environmental

**Project:** Kennewick SD - Ridgeview Elementary Follow-Up Sampling

**Lab ID:** 1702038-001

**Client Sample ID:** RVE12817-P-KF-03

**Collection Date:** 1/28/2017 10:00:00 AM

**Matrix:** Drinking Water

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

**Drinking Water Metals by EPA Method 200.8**

Batch ID: 16139

Analyst: TN

Lead	15.8	1.00		µg/L	1	2/6/2017 4:08:57 PM
------	------	------	--	------	---	---------------------

**Lab ID:** 1702038-004

**Client Sample ID:** RVE12817-P-CF-17

**Collection Date:** 1/28/2017 10:00:00 AM

**Matrix:** Drinking Water

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

**Drinking Water Metals by EPA Method 200.8**

Batch ID: 16139

Analyst: TN

Lead	4.05	1.00		µg/L	1	2/6/2017 4:19:46 PM
------	------	------	--	------	---	---------------------

**Lab ID:** 1702038-007

**Client Sample ID:** RVE12817-P-CF-26

**Collection Date:** 1/28/2017 10:00:00 AM

**Matrix:** Drinking Water

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

**Drinking Water Metals by EPA Method 200.8**

Batch ID: 16139

Analyst: TN

Lead	6.54	1.00		µg/L	1	2/6/2017 4:37:51 PM
------	------	------	--	------	---	---------------------



## Analytical Report

Work Order: 1702038  
Date Reported: 2/7/2017

**CLIENT:** Fulcrum Environmental

**Project:** Kennewick SD - Ridgeview Elementary Follow-Up Sampling

**Lab ID:** 1702038-010

**Collection Date:** 1/28/2017 10:00:00 AM

**Client Sample ID:** RVE12817-P-CF-38

**Matrix:** Drinking Water

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

**Drinking Water Metals by EPA Method 200.8**

Batch ID: 16139

Analyst: TN

Copper	1,180	0.500		µg/L	1	2/6/2017 4:48:40 PM
--------	-------	-------	--	------	---	---------------------

**Lab ID:** 1702038-013

**Collection Date:** 1/28/2017 10:00:00 AM

**Client Sample ID:** RVE12817-P-CF-41

**Matrix:** Drinking Water

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

**Drinking Water Metals by EPA Method 200.8**

Batch ID: 16139

Analyst: TN

Copper	1,320	0.500		µg/L	1	2/6/2017 4:59:29 PM
Lead	15.6	1.00		µg/L	1	2/6/2017 4:59:29 PM

**Lab ID:** 1702038-014

**Collection Date:** 1/28/2017 10:00:00 AM

**Client Sample ID:** RVE12817-P-CF-42

**Matrix:** Drinking Water

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

**Drinking Water Metals by EPA Method 200.8**

Batch ID: 16139

Analyst: TN

Copper	ND	0.500		µg/L	1	2/6/2017 5:03:05 PM
Lead	ND	1.00		µg/L	1	2/6/2017 5:03:05 PM



**Work Order:** 1702038  
**CLIENT:** Fulcrum Environmental  
**Project:** Kennewick SD - Ridgeview Elementary Foll

## QC SUMMARY REPORT

### Drinking Water Metals by EPA Method 200.8

Sample ID	MB-16139	SampType:	MBLK		Units:	µg/L		Prep Date:	2/6/2017		RunNo:	34291		
Client ID:	MBLKW	Batch ID:	16139						Analysis Date:	2/6/2017		SeqNo:	653797	
Analyte		Result	RL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual		
Copper		ND	0.500											
Lead		ND	1.00											

Sample ID	LCS-16139	SampType:	LCS		Units:	µg/L		Prep Date:	2/6/2017		RunNo:	34291		
Client ID:	LCSW	Batch ID:	16139						Analysis Date:	2/6/2017		SeqNo:	653798	
Analyte		Result	RL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual		
Copper		100	0.500	100.0	0	100	85	115						
Lead		52.7	1.00	50.00	0	105	85	115						

Sample ID	1702037-001ADUP	SampType:	DUP		Units:	µg/L		Prep Date:	2/6/2017		RunNo:	34291		
Client ID:	BATCH	Batch ID:	16139						Analysis Date:	2/6/2017		SeqNo:	653800	
Analyte		Result	RL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual		
Copper		1,680	0.500						1,726	2.81	30			
Lead		1.68	1.00						1.735	2.94	30			

Sample ID	1702037-001AMS	SampType:	MS		Units:	µg/L		Prep Date:	2/6/2017		RunNo:	34291		
Client ID:	BATCH	Batch ID:	16139						Analysis Date:	2/6/2017		SeqNo:	653801	
Analyte		Result	RL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual		
Copper		1,880	0.500	200.0	1,726	78.8	70	130						
Lead		100	1.00	100.0	1.735	98.7	70	130						

Sample ID	1702037-001AMSD	SampType:	MSD		Units:	µg/L		Prep Date:	2/6/2017		RunNo:	34291		
Client ID:	BATCH	Batch ID:	16139						Analysis Date:	2/6/2017		SeqNo:	653802	
Analyte		Result	RL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual		
Copper		1,860	0.500	200.0	1,726	67.3	70	130	1,883	1.22	30	S		

**Work Order:** 1702038  
**CLIENT:** Fulcrum Environmental  
**Project:** Kennewick SD - Ridgeview Elementary Foll

## QC SUMMARY REPORT

### Drinking Water Metals by EPA Method 200.8

Sample ID	1702037-001AMSD	SampType:	MSD	Units:	µg/L	Prep Date:	2/6/2017	RunNo:	34291		
Client ID:	BATCH	Batch ID:	16139			Analysis Date:	2/6/2017	SeqNo:	653802		
Analyte	Result	RL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.1	1.00	100.0	1.735	96.3	70	130	100.4	2.37	30	

**NOTES:**

S - Outlying spike recovery(ies) observed. A duplicate analysis was performed and recovered within range.





Work Order Number: **1702038**  
Date Received: **2/3/2017 3:12:00 PM**

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐

2. How was the sample delivered? FedEx

3. Coolers are present?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>
4. Shipping container/cooler in good condition?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
5. Custody Seals present on shipping container/cooler? (Refer to comments for Custody Seals not intact)	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	Not Required <input type="checkbox"/>
6. Was an attempt made to cool the samples?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	NA <input type="checkbox"/>

7. Were all items received at a temperature of >0°C to 10.0°C*	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>
8. Sample(s) in proper container(s)?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
9. Sufficient sample volume for indicated test(s)?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
10. Are samples properly preserved?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
11. Was preservative added to bottles?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>
			HNO <sub>3</sub>
12. Is there headspace in the VOA vials?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>
13. Did all samples containers arrive in good condition(unbroken)?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
14. Does paperwork match bottle labels?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
15. Are matrices correctly identified on Chain of Custody?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
16. Is it clear what analyses were requested?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	
17. Were all holding times able to be met?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	

18. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified:  Date:   
 By Whom:  Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person  
 Regarding:   
 Client Instructions:

HNO<sub>3</sub> added to: 002A, 003A, 005A, 006A, 008A, 009A, 011A, 012A

Item #	Temp °C
Cooler	9.4
Sample	10.3

Original



# Fremont

Analytical

3600 Fremont Ave N.  
Seattle, WA 98103

Tel: 206-352-3790  
Fax: 206-352-7178

## Chain of Custody Record and Laboratory Services Agreement

Date: 1/28/2017

Laboratory Project No (Internal):

1702038

Page: 1 of 2

Client: Fulcrum Environmental Consulting  
Address: 406 North Second Street  
City, State, Zip: Yakima, WA 98901  
Telephone: 509.574.0839 Fax: 509.545.8453

Project Name: Kennewick SD - Ridgeview Elementary Follow-Up Sampling  
Project No: 162017  
Location: Ridgeview Elementary School, Kennewick, WA  
Report To (PM): Ryan Mathews  
PM Email: rmathews@fulcrum.net; cc: aenbysk@fulcrum.net

\*Matrix Codes: A = Air, AQ = Aqueous, B = Bulk, O = Other, P = Product, S = Soil, SD = Sediment, SL = Solid, W = Water, DW = Drinking Water, GW = Ground Water, SW = Storm Water, WW = Waste Water

Sample Name	Sample Date	Sample Time	Sample Type (Matrix)*	VOCs (EPA 8260 / 624)	GYBTEX	BTEX	Gasoline Range Organics (GX)	Hydrocarbon Identification (HCID)	SVOs (EPA 8270 / 625)	PAHs (EPA 8270 - SIM)	PCBs (EPA 8082 / 608)	Metals** (EPA 6020 / 200.8)	Total (T)   Dissolved (D)	Anions (IC)***	EDs (8011)	Comments
RVE12817-P-KF-D3	1/28/2017	1000	DW													HNO3 preserved; Analyte for Pb only
RVE12817-S-KF-D3																HNO3 - unp.
RVE12817-T-KF-D3																HNO3 - unp.
RVE12817-P-CF-17																HNO3 pres; Analyte for Pb only
RVE12817-S-CF-17																HNO3 - unp.
RVE12817-T-CF-17																HNO3 pres; Analyte for Pb only
RVE12817-P-CF-26																HNO3 pres; Analyte for Pb only
RVE12817-S-CF-26																HNO3 - unp.
RVE12817-T-CF-26																HNO3 pres; Analyte for Pb only
RVE12817-P-CF-38																HNO3 pres; Analyte for Cu only

\*\*Metals Analysis (Circle): MTCA-5 RCRA-8 Priority Pollutants TAL Individual: Ag Al As B Ba Be Ca Cd Co Cr Cu Fe Hg K Mg Mn Mo Na Ni Pb Sb Se Sr Sn Ti U V Zn

\*\*\*Anions (Circle): Nitrate Nitrite Chloride Sulfate Bromide O-Phosphate Fluoride Nitrate+Nitrite Turn-around times for samples received after 4:00pm will begin on the following business day.

I represent that I am authorized to enter into this Agreement with Fremont Analytical on behalf of the Client named above, that I have verified Client's agreement to each of the terms on the front and backside of this Agreement.

Relinquished	Date/Time	Received	Date/Time
<i>[Signature]</i>	1/28/2017, 1530	<i>[Signature]</i>	2/3/17 1512
Relinquished	Date/Time	Received	Date/Time
x		x	



