



RJ LeeGroup, Inc. | Columbia Basin Analytical Laboratories

2710 North 20th Avenue, Pasco WA 99301

Tel: (509) 545-4989 | Fax: (509) 544-6010

Fulcrum Environmental  
406 N. 2nd St.  
Yakima, WA 98901

### Subject: Chemical Analysis Report

Columbia Basin Analytical Laboratories received 32 sample(s) on 12/22/16 for analysis. These sample(s) have been assigned a login order number of W612117. Enclosed is the final report that consists of a summary report of the sample(s), and a copy of the chain of custody.

### General Lab Comments

The results provided in this report relate only to the items tested. Sample(s) were received in acceptable conditions unless otherwise noted in the comments above. Sample(s) have not been field blank corrected unless otherwise noted in the general set comments above. The sample(s) were prepared in accordance with EPA 200.8 and analyzed in compliance with EPA 200.8. This test report shall not be reproduced, except in full, without written approval of Columbia Basin Analytical Laboratories. Any questions, please contact our office.

*All samples were diluted 1:10.*

*X - Samples that exceeded the instrument calibration range were rerun at a 1:100 dilution, necessitating a 10-fold increase in the PQL.*

Release of the data contained in the hard copy report has been authorized by the Laboratory Director or a designee as verified by the following signature. This report has been administratively reviewed by the following individual:

02/02/17

Project Coordinator II, M. Fernanda Pincheira

Date

If you have any questions please feel free to contact Fernanda Pincheira at [MPincheira@rjleegroup.com](mailto:MPincheira@rjleegroup.com).



## Laboratory Report

Ryan Mathews  
Fulcrum Environmental  
406 N. 2nd St.  
Yakima, WA 98901

RJ Lee Group No.: W612117  
COC No.: Kennewick  
Samples Received: 12/22/16  
Analysis/Prep Date: 01/25/17  
Report Date: 02/02/17

Client Project:

Fulcrum Kennewick

**Sample Name:** SCE122216-P-KF-01 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-01 **Date Analyzed:** 01/25/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.49	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-KF-02 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-02 **Date Analyzed:** 01/25/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.85	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-WC-03 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-03 **Date Analyzed:** 01/25/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.27	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-WC-04 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-04 **Date Analyzed:** 01/25/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.22	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-WC-05 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-05 **Date Analyzed:** 01/25/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.16	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Columbia Basin Analytical Laboratories | 2710 North 20th Avenue, Pasco WA 93301 | 509.545.4989

WWW.RJLEEGROUP.COM

Report Template: GenMetalReportFull\_v12.rpt

Approved: 02/2/17 16:12  
Report Time Stamp: 02/02/17 17:04



**Sample Name:** SCE122216-P-CF-06 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-06 **Date Analyzed:** 01/25/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.81	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CDF-07 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-07 **Date Analyzed:** 01/25/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.9	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CDF-08 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-08 **Date Analyzed:** 01/25/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.4	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CF-09 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-09 **Date Analyzed:** 01/25/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.67	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-WC-10 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-10 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.26	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-WC-11 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-11 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.23	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



**Sample Name:** SCE122216-P-NF-12 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-12 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.4	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-OF-13 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-13 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.3	0.1	X
Lead	EPA 200.8	0.001	0.001	

**Sample Name:** SCE122216-P-OF-14 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-14 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.0	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CDF-15 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-15 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.5	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CF-16 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-16 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.1	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CDF-17 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-17 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.4	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	



**Sample Name:** SCE122216-P-CF-18 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-18 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.4	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-KF-19 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-19 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.2	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-KF-20 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-20 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.0	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CDF-21 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-21 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.1	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CF-22 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-22 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	2.1	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CDF-23 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-23 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.9	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	



**Sample Name:** SCE122216-P-CF-24 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-24 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.8	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-OF-25 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-25 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.8	0.1	X
Lead	EPA 200.8	0.001	0.001	

**Sample Name:** SCE122216-P-WC-26 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-26 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.21	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-WC-27 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-27 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.17	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CDF-28 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-28 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.6	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CF-29 **Matrix:** Potable Water **Date Received:** 12/22/16  
**RJ Lee Grp. ID:** W612117-29 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.9	0.1	X
Lead	EPA 200.8	0.001	0.001	

**Sample Name:** SCE122216-P-CF-30**Matrix:** Potable Water**Date Received:** 12/22/16**RJ Lee Grp. ID:** W612117-30**Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.9	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CF-31**Matrix:** Potable Water**Date Received:** 12/22/16**RJ Lee Grp. ID:** W612117-31**Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	< 0.010	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

**Sample Name:** SCE122216-P-CDF-32**Matrix:** Potable Water**Date Received:** 12/22/16**RJ Lee Grp. ID:** W612117-32**Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.3	0.1	X
Lead	EPA 200.8	0.015	0.001	

**Report Qualifiers:***A = Target Analyte media breakthrough suspect, see analytical report**D = Analyte analyzed in a dilution**E = Report concentration was above the instrument calibration range**J = Analyte detected below quantitation limits, concentration is estimated**P = Library spectrum match, rsd >90% w RT match**Q = Result out of method specific acceptance QC criteria**S = Spike Recovery outside accepted recovery limits**Z = Not ELAP accredited analyte**ND = Not Detected**B = Analyte detected in the associated blank**d = Data that exceeds the RSD criteria set by the SOP**H = Holding times for preparation or analysis exceeded**L = Sample condition at receipt out of compliance with method defined conditions**R = RPD (relative percent difference) outside accepted recovery limits**U = Analyte analyzed for but not detected**N/A = Not Applicable*
**Scientist II DeNomy Dage**

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, RJ Lee Group will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee will be assessed for the return of any samples. Unless otherwise noted, samples were received in an acceptable condition. This laboratory operates in accordance with ISO 17025 guidelines, and holds limited scopes of accreditation under ORELAP Lab Code 4061 AIHA-LAP, LLC Lab ID 178656 EPA ID WA01195 and WA DOE Lab ID C859. This report may not be used to claim product endorsement by any laboratory accrediting agency. The results contained in this report relate only to the items tested or to the sample(s) as received by the laboratory. Any reproduction of this document must be in full for the report to be valid. Quality control data is available upon request.

Columbia Basin Analytical Laboratories | 2710 North 20th Avenue, Pasco WA 93301 | 509.545.4989

WWW.RJLEEGROUP.COM

Report Template: GenMetalReportFull\_v12.rpt

Approved: 02/2/17 16:12  
Report Time Stamp: 02/02/17 17:04

# Request for Environmental and IH Laboratory Analytical Services

W612117

Page 1 of 3

W612117, Page 8 of 10

ATTENTION TO: RYAN MATHEWS		Client No.:		Purchase Order No.:		Client Job No.:	
Project No.:		Logged In By:		Standard: <b>Yes</b> No		If No, No. of Business Days:	
Name: Amanda Embysk, Ryan Mathews		Company: Fulcrum Environmental Consulting		Sample Purpose: <b>Information X</b> Regulatory <input type="checkbox"/> Accreditation (please list below):			
Address: 406 North 2nd Street		City, State, Zip: Yakima, WA, 98901		System ID #:			
Phone: (509) 574-0839		Fax: (509) 575-8453		DOH Source #:			
Call with Verbal Results:		Email Results To: aembysk@fulcrum.net, CC: rmathews@fulcrum.net		Multiple Sources #s:			
Fax Results To:		Name: Lorrie Boutillier		Sample Purpose: A <input type="checkbox"/> B <input type="checkbox"/> Other <input type="checkbox"/>			
Company: Fulcrum Environmental		Email: lboutillier@fulcrum.net		Preservation: Unpres H <sub>2</sub> SO <sub>4</sub> Matrix: WW=Wastewater GW=Groundwater S=Soil/Sludge E=Extract Container: P=Plastic G=Glass W=Wipe A=Air (filter or tube)			
Address: 406 North 2nd Street		City, State, Zip: Yakima, WA, 98901		Filtration: 4°C HCl NaOH Na <sub>2</sub> SO <sub>4</sub> Other			
Phone: (509) 574-0839		Fax: (509) 575-8453		Analysis Requested			
Special Instructions	Client Sample ID	Sample Description	Sample Date	Sample Time		Wipe Area / Air Volume	EPA 200.8: Pb, Cu
				Start	Stop		
	SC122316-P-KF-01	Kitchen, food prep counter/sink	12/22/16				X
	SC122316-P-KF-02	Kitchen, hand wash	12/22/16				
	SC122316-P-WC-03	Cafeteria/multipurpose	12/22/16				
	SC122316-P-WC-04	Gymnasium bathroom,	12/22/16				
	SC122316-P-WC-05	Gymnasium bathroom,	12/22/16				
	SC122316-P-WC-06	Classrooms 14	12/22/16				
	SC122316-P-WC-07	Classrooms 15	12/22/16				
	SC122316-P-CDF-08	Classroom 12	12/22/16				
	SC122316-P-CF-09	Classroom 10	12/22/16				
	SC122316-P-WC-10	Main Entrance,	12/22/16				
	SC122316-P-WC-11	Main entrance,	12/22/16				
Chain of Custody		Relinquished By (Signature): <i>[Signature]</i>	Date: 12/22/16	Time: 1345		Chain of Custody	
Chain of Custody		Relinquished By (Print Name):	Relinquished To:		Method of Shipment:		Received By (Signature): <i>[Signature]</i>
Chain of Custody		Company Name:	Date:		Time:		Received By (Print Name):
Chain of Custody		Relinquished By (Signature):	Date:	Time:		Received By (Signature):	
Chain of Custody		Relinquished By (Print Name):	Relinquished To:		Method of Shipment:		Received By (Print Name):
Chain of Custody		Company Name:	Date:		Time:		Received By (Print Name):

Pennsylvania - HQ  
350 Hochberg Road  
Monroeville, PA 15146  
724.325.1776 Phone  
724.733.1799 Fax

Washington  
Columbia Basin Analytical Laboratories  
2710 North 20th Avenue  
Pasco, WA 99301  
509.545.4989 Phone  
509.544.6010 Fax



RA\_12032015



# Request for Environmental and IH Laboratory Analytical Services

ATTENTION TO: <b>RYAN MATHEWS</b>		Purchase Order No.:		Client Job No.:		<b>162017</b>		
Lab Use Only	Project No.:	Client No.:	Standard:	Yes	No	If 'No,' No. of Business Days:		
Report Results To	Date Logged In:	Logged In By:	System ID #:	Sample Purpose: <b>Information X</b> Regulatory <input type="checkbox"/> Accreditation (please list below):				
Send Invoice To	Name: Amanda Emyysk, Ryan Mathews	Company: Fulcrum Environmental Consulting	DOH Source #:	Multiple Sources #s:				
	Address: 406 North 2nd Street		Sample Purpose: A <input type="checkbox"/> B <input type="checkbox"/> Other <input type="checkbox"/>					
	City, State, Zip: Yakima, WA, 98901		Phone: (509) 574-0839	Fax: (509) 575-8453	Presentation: Unpres H <sub>2</sub> SO <sub>4</sub> Matrix: WW=Wastewater, GW=Groundwater, S=Soil/Sludge, E=Extract			
	City, State, Zip: Yakima, WA, 98901		Phone: (509) 574-0839	Fax: (509) 575-8453	Container: P=Plastic, G=Glass, W=Wipe, A=Air (filter or tube)			
Special Instructions	Name: Lorrie Boutillier	Company: Fulcrum Environmental	Chemistry Analysis Key: HNO <sub>3</sub> , NaOH, Na <sub>2</sub> SO <sub>4</sub> , Other					
Client Sample ID	Address: 406 North 2nd Street	City, State, Zip: Yakima, WA, 98901	Analysis Requested					
	Phone: (509) 574-0839	Fax: (509) 575-8453	Pres. Upon Receipt (Y/N)					
Sample Description	Sample Date	Sample Time	Wipe Area / Air Volume	EPA 200.8: Pb, Cu	UNPR.	DW	pH	No. Containers
SCE122216-P-NF-12	Nurse's office	10/24/16		X				15.8
SCE122216-P-0F-13	Workroom adjacent staff lounge							15.8
SCE122216-P-0F-14	Staff lounge							15.8
SCE122216-P-CGF-15	Classroom 9							15.8
SCE122216-P-CF-16	Classroom 7							16.0
SCE122216-P-CGF-17	Classroom b							16.0
SCE122216-P-CF-18	Classroom 4							16.0
SCE122216-P-KF-19	Classroom 2							16.0
SCE122216-P-KF-20	Classroom 3							15.9
SCE122216-P-CGF-21	Classroom 23							15.9
SCE122216-P-CF-22	Classroom 22							15.9
Chain of Custody	Relinquished By (Signature): <i>[Signature]</i>	Date: 12/28/16	Time: 1345	Chain of Custody	Received By (Signature): <i>[Signature]</i>	Date: DEC 27 2016	Time: 1340	
Chain of Custody	Relinquished By (Print Name):	Method of Shipment:		Chain of Custody	Received By (Print Name):	Method of Shipment:		
Chain of Custody	Relinquished By (Signature):	Date:	Time:	Chain of Custody	Received By (Signature):	Date:	Time:	
Chain of Custody	Relinquished By (Print Name):	Method of Shipment:		Chain of Custody	Received By (Print Name):	Method of Shipment:		

Pennsylvania - HQ  
350 Hochberg Road  
Monroeville, PA 15146  
724.325.1776 Phone  
724.733.1799 Fax

Washington  
Columbia Basin Analytical Laboratories  
2710 North 20th Avenue  
Pasco, WA 99301  
509.545.4989 Phone  
509.544.6010 Fax



# Request for Environmental and IH Laboratory Analytical Services

ATTENTION TO: <b>RYAN MATHEWS</b>		Client Job No.: <b>162017</b>	
Lab Use Only	Project No.: Date Logged In: Logged In By:	Turnaround Request	Standard: <b>Yes</b> No If 'No,' No. of Business Days: Accreditation (please list below):
Report Results To	Name: Amanda Enbysk, Ryan Mathews Company: Fulcrum Environmental Consulting Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453 Call with Verbal Results: Email Results To: aenbysk@fulcrum.net, CC: rmathews@fulcrum.net Fax Results To:	Drinking Water Sample Only	Sample Purpose: <b>Information X</b> Regulatory <input type="checkbox"/> Accreditation (please list below): DOH Source #: Multiple Sources #:
Send Invoice To	Name: Lorrie Boutillier Company: Fulcrum Environmental Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453	Chemistry Analysis Key	Preservation: <input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> Other <input type="checkbox"/> Matrix: <input type="checkbox"/> W=Wastewater <input type="checkbox"/> GW=Groundwater <input type="checkbox"/> S=Soil/Sludge <input type="checkbox"/> E=Extract SW=Surface Water DW=Drinking Water O=Oil X=Other Container: P=Plastic G=Glass W=Wipe A=Air (filter or tube)
Special Instructions		Analysis Requested	
Client Sample ID	Sample Description	Sample Date	Sample Time
		Start	Stop
		Wipe Area / Air Volume	
SCE120216-P-COF-23	Classroom 25	12/20/16	
SCE120216-P-CF-24	Classroom 27		
SCE120216-P-OF-25	Library workroom		
SCE120216-P-WC-26	Upstairs,		
SCE120216-P-WC-27	Upstairs,		
SCE120216-P-COF-28	Classroom 29		
SCE120216-P-CF-29	Classroom 31		
SCE120216-P-CF-30	Classroom 33		
SCE120216-P-CF-31	Classroom 34		
SCE120216-P-COF-32	Classroom 35		
Chain of Custody	Relinquished By (Signature): <i>[Signature]</i> Relinquished By (Print Name): Company Name:	Chain of Custody	Received By (Signature): <i>[Signature]</i> Received By (Print Name): Company Name:
Chain of Custody	Relinquished By (Signature): Relinquished By (Print Name): Company Name:	Chain of Custody	Received By (Signature): Received By (Print Name): Company Name:
	Date: 12/20/16 Time: 1345		Date: 12/22/16 Time: 1340
	Method of Shipment:		Method of Shipment:
	Date: Time:		Date: Time:
	Method of Shipment:		Method of Shipment:
		Pres. Upon Receipt (Y/N)	
		Preservation	
		Matrix	
		Container Type	
		pH	
		No. Containers	

Pennsylvania - HQ  
350 Hochberg Road  
Montroeville, PA 15146  
724.325.1776 Phone  
724.733.1799 Fax

Washington  
Columbia Basin Analytical Laboratories  
2710 North 20th Avenue  
Pasco, WA 99301  
509.545.4989 Phone  
509.544.6010 Fax

