

## Dustin Fisk

---

**From:** Amanda Enbysk <aenbysk@efulcrum.net>  
**Sent:** Tuesday, April 11, 2017 10:53 AM  
**To:** Keith Colee  
**Cc:** Dustin Fisk; Ryan Mathews  
**Subject:** Drinking Water Sampling - Sunset View Elementary Follow-Up Results  
**Attachments:** Rpt\_1704068\_Kennewick\_SD\_Drinking\_Water-Sunset\_View\_Elementary\_Final\_v1.pdf

Keith-

Fulcrum received results from a second follow-up sampling event conducted 4/5/2017 on one fixture remaining above the copper action level at Sunset View Elementary. A summary of results is below and analytical results from Fremont Analytical are attached.

Sample Identification and Location	Type of Fixture	Initial Copper Results (µg/L)	3/4/17 Follow-Up Copper Results (µg/L)	4/5/17 Follow-Up Copper Results (µg/L)
SVE4517-P-OF-03: Library work room	Classroom Drinking Fountain	1,400	1,320	105
SVE4517-P-BF-52: Laboratory Blank	Distilled Water Blank	<10	<0.5	<0.5
SVE4517-P-DF-53: Laboratory Spike	Lead and Copper Spike	1,100	1,260	1,270
<b>EPA Action Level</b>		<b>1,300</b>	<b>1,300</b>	<b>1,300</b>

Based on analytical results, the remediation was successful at reducing copper concentrations below the action level at all fixtures initially identified with elevated copper concentrations. As such, the remaining fixture still above the action level can be put back into service.

No further testing or remediation is necessary at Sunset View Elementary at this time.

Please let me know if you have any questions.

Thank you,

Amanda Enbysk, GIT  
Environmental Geologist  
Fulcrum Environmental Consulting, Inc.  
406 North Second Street  
Yakima, WA 98901  
P: 509.574.0839 F: 505.575.8453

*Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.*