



RJ LeeGroup, Inc. | Columbia Basin Analytical Laboratories

2710 North 20th Avenue, Pasco WA 99301

Tel: (509) 545-4989 | Fax: (509) 544-6010

Fulcrum Environmental
406 N. 2nd St.
Yakima, WA 98901

Subject: Chemical Analysis Report

Columbia Basin Analytical Laboratories received 40 sample(s) on 12/21/16 for analysis. These sample(s) have been assigned a login order number of W612109. Enclosed is the final report that consists of a summary report of the sample(s), and a copy of the chain of custody.

General Lab Comments

The results provided in this report relate only to the items tested. Sample(s) were received in acceptable conditions unless otherwise noted in the comments above. Sample(s) have not been field blank corrected unless otherwise noted in the general set comments above. The sample(s) were prepared in accordance with EPA 200.8 and analyzed in compliance with EPA 200.8. This test report shall not be reproduced, except in full, without written approval of Columbia Basin Analytical Laboratories. Any questions, please contact our office.

-Samples were analyzed on January 18, 2017 and samples requiring dilutions were analyzed on January 19, 2017.

All samples were diluted 1:10.

X - Samples that exceeded the instrument calibration range were rerun at a 1:100 dilution, necessitating a 10-fold increase in the PQL.

Release of the data contained in the hard copy report has been authorized by the Laboratory Director or a designee as verified by the following signature. This report has been administratively reviewed by the following individual:

01/23/17

Project Coordinator II, M. Fernanda Pincheira

Date

If you have any questions please feel free to contact Fernanda Pincheira at MPincheira@rjleegroup.com.



Laboratory Report

Amanda Enbysk
Fulcrum Environmental
406 N. 2nd St.
Yakima, WA 98901

RJ Lee Group No.: W612109
COC No.: Kennewick
Samples Received: 12/21/16
Analysis/Prep Date: 01/18/17
Report Date: 01/23/17

Client Project:

Fulcrum Kennewick

Sample Name: 122116-VE-P-OF-01 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-01 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.87	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-OF-02 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-02 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.81	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CF-03 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-03 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.79	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-04 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-04 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.54	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CF-05 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-05 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.86	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Columbia Basin Analytical Laboratories | 2710 North 20th Avenue, Pasco WA 93301 | 509.545.4989

WWW.RJLEEGROUP.COM

Report Template: GenMetalReportFull_v12.rpt

Approved: 01/23/17 8:59
Report Time Stamp: 01/23/17 12:42



Sample Name: 122116-VE-P-CDF-06 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-06 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.76	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CF-07 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-07 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.84	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-08 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-08 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.84	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CF-09 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-09 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.94	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-10 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-10 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.01	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-11 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-11 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.77	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



Sample Name: 122116-VE-P-CDF-12 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-12 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.89	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CF-17 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-13 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.92	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-18 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-14 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.63	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CF-19 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-15 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.76	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-20 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-16 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.73	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CF-21 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-17 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.96	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



Sample Name: 122116-VE-P-CDF-22 **Matrix:** Potable Water
RJ Lee Grp. ID: W612109-18

Date Received: 12/21/16
Date Analyzed: 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.70	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-OF-23 **Matrix:** Potable Water
RJ Lee Grp. ID: W612109-19

Date Received: 12/21/16
Date Analyzed: 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.89	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CF-24 **Matrix:** Potable Water
RJ Lee Grp. ID: W612109-20

Date Received: 12/21/16
Date Analyzed: 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.80	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-25 **Matrix:** Potable Water
RJ Lee Grp. ID: W612109-21

Date Received: 12/21/16
Date Analyzed: 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.91	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CF-26 **Matrix:** Potable Water
RJ Lee Grp. ID: W612109-22

Date Received: 12/21/16
Date Analyzed: 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.00	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-27 **Matrix:** Potable Water
RJ Lee Grp. ID: W612109-23

Date Received: 12/21/16
Date Analyzed: 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.85	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



Sample Name: 122116-VE-P-CF-28 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-24 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.76	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-29 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-25 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.89	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-KF-30 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-26 **Date Analyzed:** 01/19/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.0	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-KF-31 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-27 **Date Analyzed:** 01/19/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.1	0.1	X
Lead	EPA 200.8	0.001	0.001	

Sample Name: 122116-VE-P-KF-32 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-28 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.32	0.01	
Lead	EPA 200.8	0.001	0.001	

Sample Name: 122116-VE-P-KF-33 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-29 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.89	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



Sample Name: 122116-VE-P-CF-34 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-30 **Date Analyzed:** 01/19/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.3	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-35 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-31 **Date Analyzed:** 01/19/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.7	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-BF-36 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-32 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.48	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-DF-37 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-33 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.43	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-NF-38 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-34 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.75	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-BF-39 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-35 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	< 0.010	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



Sample Name: 122116-VE-P-BF-40 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-36 **Date Analyzed:** 01/19/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.2	0.1	X
Lead	EPA 200.8	0.016	0.001	

Sample Name: 122116-VE-P-CF-13 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-37 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.60	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-OF-14 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-38 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.66	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CF-15 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-39 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.92	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: 122116-VE-P-CDF-16 **Matrix:** Potable Water **Date Received:** 12/21/16
RJ Lee Grp. ID: W612109-40 **Date Analyzed:** 01/18/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.95	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



Report Qualifiers:

A = Target Analyte media breakthrough suspect, see analytical report

D = Analyte analyzed in a dilution

E = Report concentration was above the instrument calibration range

J = Analyte detected below quantitation limits, concentration is estimated

P = Library spectrum match, $rsd > 90\%$ w RT match

Q = Result out of method specific acceptance QC criteria

S = Spike Recovery outside accepted recovery limits

Z = Not ELAP accredited analyte

ND = Not Detected

B = Analyte detected in the associated blank

d = Data that exceeds the RSD criteria set by the SOP

H = Holding times for preparation or analysis exceeded

L = Sample condition at receipt out of compliance with method defined conditions

R = RPD (relative percent difference) outside accepted recovery limits

U = Analyte analyzed for but not detected

N/A = Not Applicable

Scientist III J Grissmerson

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, RJ Lee Group will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee will be assessed for the return of any samples. Unless otherwise noted, samples were received in an acceptable condition. This laboratory operates in accordance with ISO 17025 guidelines, and holds limited scopes of accreditation under ORELAP Lab Code 4061 AIHA-LAP, LLC Lab ID 178656 EPA ID WA01195 and WA DOE Lab ID C859. This report may not be used to claim product endorsement by any laboratory accrediting agency. The results contained in this report relate only to the items tested or to the sample(s) as received by the laboratory. Any reproduction of this document must be in full for the report to be valid. Quality control data is available upon request.

Request for Environmental and IH Laboratory Analytical Services

W612109

ATTENTION TO: RYAN MATHEWS		Purchase Order No.: 162017	Client Job No.: 162017
Lab Use Only	Project No.: Date Logged In: Name: Amanda Enbyk, Ryan Mathews Company: Fulcrum Environmental Consulting Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453	Client No.: Logged In By:	
Report Results To	Call with Verbal Results: Email Results To: aenbyk@fulcrum.net, CC: rmathews@fulcrum.net Fax Results To: Name: Lorrie Boutilier Company: Fulcrum Environmental Email: lboutilier@fulcrum.net Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453	Turnaround Request	Standard: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If 'No,' No. of Business Days: Sample Purpose: <input checked="" type="checkbox"/> Information <input checked="" type="checkbox"/> Regulatory <input type="checkbox"/> Accreditation (please list below): System ID #: DOH Source #: Multiple sources #s:
Send Invoice To	Company: Fulcrum Environmental Email: lboutilier@fulcrum.net Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453	Drinking Water Sample Only	Sample Purpose: A <input type="checkbox"/> B <input type="checkbox"/> Other <input type="checkbox"/> Preservation: Unpres H ₂ SO ₄ Matrix: WW=Wastewater SW=Surface Water 4°C HCl GW=Groundwater DW=Drinking Water HNO ₃ NaOH S=Soil/Sludge O=Oil Other Na ₂ SO ₄ E=Extract X=Other A=Air (filter or tube)
Special Instructions		Chemistry Analysis Key	Container: P=Plastic G=Glass W=Whipe A=Air (filter or tube)
Client Sample ID	Sample Description	Analysis Requested	
122116-VE-P-0401	Rm 21 Sink		Pres. Upon Receipt (Y/N) <input checked="" type="checkbox"/>
122116-VE-P-0402	Teacher's lounge		UNPR
122116-VE-P-0403	Rm 12 Sink		DW
122116-VE-P-0404	Rm 12 DF		
122116-VE-P-0405	Rm 11 Sink		
122116-VE-P-0406	Rm 11 DF		
122116-VE-P-0407	Rm 13 Sink		
122116-VE-P-0408	Rm 13 DF		
122116-VE-P-0409	Rm 14 Sink		
122116-VE-P-0410	Rm 14 DF		
122116-VE-P-0411	Rm 16 Sink		
Chain of Custody	Relinquished By (Signature): Relinquished By (Print Name): Logan Lopez Company Name:	Chain of Custody	Received By (Signature): Received By (Print Name): Company Name:
	Date: 12/21 Time: 12:30		Date: 12/21 Time: 12:45
Chain of Custody	Relinquished By (Signature): Relinquished By (Print Name): Company Name:	Chain of Custody	Received By (Signature): Received By (Print Name): Company Name:
	Date: Time:		Date: Time:

Pennsylvania - HQ
350 Hochberg Road
Monroeville, PA 15146
724.325.1776 Phone
724.733.1799 Fax

Washington
Columbia Basin Analytical Laboratories
2710 North 20th Avenue
Pasco, WA 99301
509.545.4989 Phone
509.544.6010 Fax



Request for Environmental and IH Laboratory Analytical Services

W612109

ATTENTION TO: RYAN MATHEWS			Purchase Order No.:			Client Job No.:		
Project No.:			Standard: Yes No			If 'No', No. of Business Days:		
Date Logged In:			Sample Purpose: Information X Regulatory <input type="checkbox"/> Accreditation (please list below):			162017		
Logged In By:			System ID #:					
Name: Amanda Enbysk, Ryan Mathews			DOH Source #:					
Company: Fulcrum Environmental Consulting			Multiple Sources #:					
Address: 406 North 2nd Street			Sample Only					
City, State, Zip: Yakima, WA, 98901			Drinking Water					
Phone: (509) 574-0839			Matrix: <input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> Other <input type="checkbox"/>					
Fax: (509) 575-8453			Preservation: <input type="checkbox"/> Unpres <input type="checkbox"/> H ₂ SO ₄					
Call with Verbal Results:			4 °C <input type="checkbox"/> HCl					
Email Results To: aenbysk@fulcrum.net, CC: rmathews@fulcrum.net			HNO ₃ <input type="checkbox"/> NaOH					
Fax Results To:			Other <input type="checkbox"/> Na ₂ SO ₄					
Name: Lorrie Boutillier			E-Extract <input type="checkbox"/>					
Company: Fulcrum Environmental			Matrix: <input type="checkbox"/> W=Wastewater <input type="checkbox"/> SW=Surface Water					
Address: 406 North 2nd Street			GW=Groundwater					
City, State, Zip: Yakima, WA, 98901			S=Soil/Sludge					
Phone: (509) 574-0839			E=Extract					
Fax: (509) 575-8453			O=Oil					
Email: lboutillier@fulcrum.net			X=Other					
Send Invoice To			Analysis Requested					
Special Instructions			EPA 200.8: Pb, Cu					
Client Sample ID			Sample Date			Sample Time		
Sample Description			Start			Stop		
Sample Date			Wipe Area / Air Volume					
122116-VE-P-CD=162			12/21					
122116-VE-P-CE-17								
122116-VE-P-CD=18								
122116-VE-P-CE-19								
122116-VE-P-CD=20								
122116-VE-P-CE-21								
122116-VE-P-CD=22								
122116-VE-P-DE-23								
122116-VE-P-CE-24								
122116-VE-P-CD=25								
122116-VE-P-CE-26								
Relinquished By (Signature):			Date: 12/21/16			Time: 12:30		
Relinquished By (Print Name): Togan Lopez			Relinquished To:			Time: 12:30		
Company Name:			Method of Shipment:					
Chain of Custody			Chain of Custody			Chain of Custody		
Relinquished By (Signature):			Received By (Signature):			Date: 12/21/2016		
Relinquished By (Print Name):			Received By (Print Name):			Time: 12:30		
Company Name:			Company Name:			Method of Shipment:		
Date:			Date:			Time:		
Relinquished To:			Relinquished To:			Time:		
Method of Shipment:			Method of Shipment:					

Pennsylvania - HQ
350 Hochberg Road
Monroeville, PA 15146
724.325.1776 Phone
724.733.1799 Fax

Washington
Columbia Basin Analytical Laboratories
2710 North 20th Avenue
Pasco, WA 99301
509.545.4989 Phone
509.544.6010 Fax



Request for Environmental and IH Laboratory Analytical Services

W612109

Page 3 of 4

ATTENTION TO: RYAN MATHEWS		Project No.:		Client No.:		Purchase Order No.:		Client Job No.:	
Lab Use Only		Date Logged In:		Logged In By:		Standard: Yes No		If 'No,' No. of Business Days:	
Report Results To		Name: Amanda Embysk, Ryan Mathews		Company: Fulcrum Environmental Consulting		Sample Purpose: Information X Regulatory <input type="checkbox"/> Accreditation (please list below):			
To		Address: 406 North 2nd Street		City, State, Zip: Yakima, WA, 98901		System ID #:			
		Phone: (509) 574-0839		Fax: (509) 575-8453		DOH Source #:			
		Call with Verbal Results:		Email Results To: aembysk@fulcrum.net, CC: rmathews@fulcrum.net		Multiple Sources #s:			
		Fax Results To:		Name: Lorrie Boutillier		Sample Purpose: <input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> Other <input type="checkbox"/>			
Send Invoice To		Company: Fulcrum Environmental		Email: lboutillier@fulcrum.net		Preservation: <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HCl <input type="checkbox"/> NaOH <input type="checkbox"/> Na ₂ SO ₄ <input type="checkbox"/> Other		Matrix: <input type="checkbox"/> WW=Wastewater <input type="checkbox"/> GW=Groundwater <input type="checkbox"/> S=Soil/Sludge <input type="checkbox"/> E=Extract	
		Address: 406 North 2nd Street		City, State, Zip: Yakima, WA, 98901		SW=Surface Water <input type="checkbox"/> DW=Drinking Water <input type="checkbox"/> O=Oil <input type="checkbox"/> X=Other		Container: <input type="checkbox"/> P=Plastic <input type="checkbox"/> G=Glass <input type="checkbox"/> W=Wipe <input type="checkbox"/> A=Air (filter or tube)	
Special Instructions		Phone: (509) 574-0839		Fax: (509) 575-8453		Analysis Requested			
Client Sample ID		Sample Description		Sample Date		Sample Time		Wipe Area / Air Volume	
				Start		Stop			
122116-VE-P-CDF-27		Rm 10 DE		12/21					
122116-VE-P-CF-28		Rm 7 SHK							
122116-VE-P-CDF-29		Rm 7 DE							
122116-VE-P-CF-30		West Kitchen							
122116-VE-P-KF-31		Hand prep							
122116-VE-P-KF-32		Veggie Riser							
122116-VE-P-KF-33		East Counter							
122116-VE-P-CF-34		Music Sink							
122116-VE-P-LDF-35		Music DE							
122116-VE-P-BF-36		DE w/BF							
122116-VE-P-DF-37		DE outside km							
Chain of Custody		Relinquished By (Signature):		Date: 12/21		Time: 12:30		Chain of Custody	
		Relinquished By (Print Name): Logan Lopez		Relinquished To:		Method of Shipment:		Received By (Signature):	
		Company Name:		Date:		Time:		Received By (Print Name):	
Chain of Custody		Relinquished By (Signature):		Date:		Time:		Received By (Signature):	
		Relinquished By (Print Name):		Date:		Time:		Received By (Print Name):	
		Company Name:		Date:		Time:		Received By (Print Name):	

Pennsylvania - HQ
350 Hochberg Road
Monroeville, PA 15146
724.325.1776 Phone
724.733.1799 Fax

Washington
Columbia Basin Analytical Laboratories
2710 North 20th Avenue
Pasco, WA 99301
509.545.4989 Phone
509.544.6010 Fax



Request for Environmental and IH Laboratory Analytical Services

W612109

Page 4 of 4

ATTENTION TO: RYAN MATHEWS		Purchase Order No.:	Client Job No.:		162017
Lab Use Only	Project No.:	Date Logged In:	Client No.:	Logged In By:	
Report Results To	Name: Amanda Enbysk, Ryan Mathews	Company: Fulcrum Environmental Consulting	Address: 406 North 2nd Street	City, State, Zip: Yakima, WA, 98901	Phone: (509) 574-0839 Fax: (509) 575-8453
Send Invoice To	Name: Lorrie Boutilier	Company: Fulcrum Environmental	Address: 406 North 2nd Street	City, State, Zip: Yakima, WA, 98901	Phone: (509) 574-0839 Fax: (509) 575-8453
Special Instructions					
Chain of Custody	Relinquished By (Signature): <i>[Signature]</i>	Date: 12/21	Time: 12:30	Relinquished To:	Method of Shipment:
Chain of Custody	Relinquished By (Print Name): <i>Logan Lopez</i>	Date:	Time:	Relinquished To:	Method of Shipment:
Chain of Custody	Relinquished By (Signature):	Date:	Time:	Relinquished To:	Method of Shipment:
Chain of Custody	Relinquished By (Print Name):	Date:	Time:	Relinquished To:	Method of Shipment:

Client Sample ID	Sample Description	Sample Date	Start	Stop	Wipe Area / Air Volume	Turnaround Request	Standard: Yes No	If 'No,' No. of Business Days:	Accreditation (please list below):	Pres. Upon Receipt (Y/N)	Preservation	Matrix	Container Type	pH	No. Containers
122116-VE-P-NF-38	Nurses Office 12/21					Drinking Water	Yes			X	UNPR	DW			20.1
122116-VE-P-BF-39	Boys Locker					Chemistry Analysis Key									18.1
122116-VE-P-BF-40	Girls Locker					Sample Only									19.6
122116-VE-P-CE-13	Rm 15 Sink					Chemistry Analysis Key									20.1
122116-VE-P-DF-14	Rm 15 DF					Chemistry Analysis Key									19.4
122116-VE-P-DF-15	Rm 17 Sink					Chemistry Analysis Key									20.8
122116-VE-P-DF-16	Rm 17 DF					Chemistry Analysis Key									19.6

Pennsylvania - HQ
350 Hochberg Road
Monroeville, PA 15146
724.325.1776 Phone
724.733.1799 Fax

Washington
Columbia Basin Analytical Laboratories
2710 North 20th Avenue
Pasco, WA 99301
509.545.4989 Phone
509.544.6010 Fax

