

Dustin Fisk

From: Amanda Enbysk <aenbysk@efulcrum.net>
Sent: Tuesday, February 14, 2017 3:59 PM
To: Keith Colee
Cc: Dustin Fisk; Ryan Mathews
Subject: Drinking Water Follow-Up Sampling (2/11/2017) - Vista Elementary Results
Attachments: Rpt_1702134_Kennewick_School_District_-_Vista_Elementary_Drink_Final_v1.pdf

Keith-

Fulcrum received results of follow-up drinking water sampling conducted February 11, 2017 post fixture replacement and precondition flush at Vista Elementary. A summary of results is below and analytical results from Fremont Analytical are attached.

Sample Identification and Location	Type of Fixture	Initial Copper Results (µg/L)	Follow-Up Copper Results (µg/L)
21117-VE-P-CF-34: Music room	Classroom Faucet	1,300	655
21117-VE-P-CDF-35: Music room	Classroom Drinking Faucet	1,700	802
21117-VE-P-BF-39: Laboratory Blank	Distilled Blank	<10	1.15
21117-VE-P-BF-40: Laboratory Spike	Lead and Copper Spike	1,200	1,210
EPA Action Level		1,300	1,300

Based on analytical results, the fixture replacement and precondition flush was successful at reducing copper concentrations below the action level at both the drinking fountain and faucet at the sink in the Music Room. As such, these fixtures can be put back into service.

Please feel free to contact me with any questions.

Thank you,

Amanda Enbysk, Environmental Technician
Fulcrum Environmental Consulting, Inc.
406 North Second Street
Yakima, WA 98901
P: 509.574.0839 F: 505.575.8453

Disclaimer: The information contained in this message, including any attachments and correspondence may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, please be advised that you are legally prohibited from retaining, using, copying, distributing, or otherwise disclosing this information in any manner. If you have received this email message in error, please reply immediately to the sender and delete all copies of this message and any attachments. Thank you.