



RJ LeeGroup, Inc. | Columbia Basin Analytical Laboratories

2710 North 20th Avenue, Pasco WA 99301

Tel: (509) 545-4989 | Fax: (509) 544-6010

Fulcrum Environmental
406 N. 2nd St.
Yakima, WA 98901

Subject: Chemical Analysis Report

Columbia Basin Analytical Laboratories received 39 sample(s) on 12/22/16 for analysis. These sample(s) have been assigned a login order number of W612118. Enclosed is the final report that consists of a summary report of the sample(s), and a copy of the chain of custody.

General Lab Comments

The results provided in this report relate only to the items tested. Sample(s) were received in acceptable conditions unless otherwise noted in the comments above. Sample(s) have not been field blank corrected unless otherwise noted in the general set comments above. The sample(s) were prepared in accordance with EPA 200.8 and analyzed in compliance with EPA 200.8. This test report shall not be reproduced, except in full, without written approval of Columbia Basin Analytical Laboratories. Any questions, please contact our office.

All samples were diluted 1:10.

X-Samples that exceeded the instrument calibration range were rerun at a 1:100 dilution, necessitating a 10-fold increase in the PQL.

Release of the data contained in the hard copy report has been authorized by the Laboratory Director or a designee as verified by the following signature. This report has been administratively reviewed by the following individual:

02/01/17

Project Coordinator II, M. Fernanda Pincheira

Date

If you have any questions please feel free to contact Fernanda Pincheira at MPincheira@rjleegroup.com.



Laboratory Report

Amanda Enbysk
Fulcrum Environmental
406 N. 2nd St.
Yakima, WA 98901

RJ Lee Group No.: W612118
COC No.: Kennewick
Samples Received: 12/22/16
Analysis/Prep Date: 01/30/17
Report Date: 02/01/17

Client Project:

Fulcrum Kennewick

Sample Name: WE122216-P-KF-01 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-01 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.53	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-KF-02 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-02 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.34	0.01	
Lead	EPA 200.8	0.001	0.001	

Sample Name: WE122216-P-KF-03 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-03 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.26	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CF-04 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-04 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.46	0.01	
Lead	EPA 200.8	0.002	0.001	

Sample Name: WE122216-P-CDF-05 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-05 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.66	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Columbia Basin Analytical Laboratories | 2710 North 20th Avenue, Pasco WA 93301 | 509.545.4989

WWW.RJLEEGROUP.COM

Report Template: GenMetalReportFull_v12.rpt

Approved: 02/1/17 16:32
Report Time Stamp: 02/01/17 16:56



Sample Name: WE122216-P-CF-06 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-06 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.53	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CDF-07 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-07 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.0	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CF-08 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-08 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.45	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CDF-09 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-09 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.70	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CF-10 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-10 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.0	0.1	X
Lead	EPA 200.8	0.002	0.001	

Sample Name: WE122216-P-CDF-11 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-11 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.1	0.1	X
Lead	EPA 200.8	0.002	0.001	



Sample Name: WE122216-P-CF-12 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-12 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.39	0.01	
Lead	EPA 200.8	0.002	0.001	

Sample Name: WE122216-P-CDF-13 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-13 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.2	0.1	X
Lead	EPA 200.8	0.002	0.001	

Sample Name: WE122216-P-OF-14 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-14 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.53	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-OF-15 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-15 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.36	0.01	
Lead	EPA 200.8	0.001	0.001	

Sample Name: WE122216-P-CF-16 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-16 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.32	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CDF-17 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-17 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.75	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



Sample Name: WE122216-P-CF-18 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-18 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.49	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-WC-19 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-19 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.14	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-BF-20 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-20 **Date Analyzed:** 01/30/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.11	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CDF-21 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-21 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.88	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CF-22 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-22 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.37	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CF-23 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-23 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.42	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



Sample Name: WE122216-P-CDF-24 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-24 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.04	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-WC-25 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-25 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.58	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-WC-26 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-26 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.57	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-BF-27 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-27 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.44	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-NF-28 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-28 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.79	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-OF-29 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-29 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.4	0.1	X
Lead	EPA 200.8	0.002	0.001	



Sample Name: WE122216-P-CDF-30 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-30 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.0	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CF-31 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-31 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.58	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CDF-32 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-32 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.2	0.1	X
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CF-33 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-33 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.68	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CDF-34 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-34 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.95	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CF-35 **Matrix:** Potable Water **Date Received:** 12/22/16
RJ Lee Grp. ID: W612118-35 **Date Analyzed:** 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.45	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



Sample Name: WE122216-P-CF-36
RJ Lee Grp. ID: W612118-36

Matrix: Potable Water

Date Received: 12/22/16
Date Analyzed: 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.54	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CF-37
RJ Lee Grp. ID: W612118-37

Matrix: Potable Water

Date Received: 12/22/16
Date Analyzed: 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	0.45	0.01	
Lead	EPA 200.8	< 0.0010	0.001	

Sample Name: WE122216-P-CF-38
RJ Lee Grp. ID: W612118-38

Matrix: Potable Water

Date Received: 12/22/16
Date Analyzed: 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	1.1	0.1	X
Lead	EPA 200.8	0.013	0.001	

Sample Name: WE122216-P-CF-39
RJ Lee Grp. ID: W612118-39

Matrix: Potable Water

Date Received: 12/22/16
Date Analyzed: 01/31/17

Analyte	Method	Result (mg/L)	PQL (mg/L)	Qualifiers
Copper	EPA 200.8	< 0.010	0.01	
Lead	EPA 200.8	< 0.0010	0.001	



Report Qualifiers:

A = Target Analyte media breakthrough suspect, see analytical report

D = Analyte analyzed in a dilution

E = Report concentration was above the instrument calibration range

J = Analyte detected below quantitation limits, concentration is estimated

P = Library spectrum match, $rsd > 90\%$ w RT match

Q = Result out of method specific acceptance QC criteria

S = Spike Recovery outside accepted recovery limits

Z = Not ELAP accredited analyte

ND = Not Detected

B = Analyte detected in the associated blank

d = Data that exceeds the RSD criteria set by the SOP

H = Holding times for preparation or analysis exceeded

L = Sample condition at receipt out of compliance with method defined conditions

R = RPD (relative percent difference) outside accepted recovery limits

U = Analyte analyzed for but not detected

N/A = Not Applicable

Scientist II DeNomy Dage

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, RJ Lee Group will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee will be assessed for the return of any samples. Unless otherwise noted, samples were received in an acceptable condition. This laboratory operates in accordance with ISO 17025 guidelines, and holds limited scopes of accreditation under ORELAP Lab Code 4061 AIHA-LAP, LLC Lab ID 178656 EPA ID WA01195 and WA DOE Lab ID C859. This report may not be used to claim product endorsement by any laboratory accrediting agency. The results contained in this report relate only to the items tested or to the sample(s) as received by the laboratory. Any reproduction of this document must be in full for the report to be valid. Quality control data is available upon request.

Request for Environmental and IH Laboratory Analytical Services

W612118

ATTENTION TO: RYAN MATHEWS		Purchase Order No.: 162017	Client Job No.: 162017								
Lab Use Only	Project No.: Date Logged In: Client No.: Logged In By:	Standard: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	If 'No,' No. of Business Days: Accreditation (please list below):								
Report Results To	Name: Amanda Embysk, Ryan Mathews Company: Fulcrum Environmental Consulting Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453 Call with Verbal Results: Email Results To: aenbysk@fulcrum.net, CC: rmathews@fulcrum.net Fax Results To:	Sample Purpose: <input checked="" type="checkbox"/> Information <input type="checkbox"/> Regulatory <input type="checkbox"/> Accreditation	Container: P=Plastic G=Glass W=Wipe A=Air (filter or tube)								
Send Invoice To	Name: Lorrie Boutillier Company: Fulcrum Environmental Address: 406 North 2nd Street City, State, Zip: Yakima, WA, 98901 Phone: (509) 574-0839 Fax: (509) 575-8453	Drinking Water Sample Only	Matrix: WW=Wastewater GW=Groundwater S=Soil/Sediment E=Extract								
Special Instructions		Chemistry Analysis Key	Preservation: Unpres H ₂ SO ₄ 4°C HCl HNO ₃ NaOH Other Na ₂ SO ₄								
Client Sample ID	Sample Description	Sample Date	Sample Time	Wipe Area / Air Volume	Analysis Requested	Pres. Upon Receipt (Y/N)	Preservation	Matrix	Container Type	pH	No. Containers
WE122216-P-KF-Q1	Kitchen	12/22				X	UNPR	DW			19.7
WE122216-P-KF-Q2	Kitchen										19.7
WE122216-P-KF-Q3	Kitchen										18.2
WE122216-P-CF-Q4	Room 1										18.1
WE122216-P-CDF-Q5	Room 2										18.1
WE122216-P-CF-Q6	Room 3										18.4
WE122216-P-CDF-Q7	Room 4										18.2
WE122216-P-CF-Q8	Room 5										18.9
WE122216-P-CDF-Q9	Room 6										18.9
WE122216-P-CF-Q10	SUPPORT SERVICES A										19.7
WE122216-P-CDF-Q11	SUPPORT SERVICES A										18.8
Chain of Custody	Relinquished By (Signature): Relinquished By (Print Name): Company Name:	Date: 12/22 Relinquished To: Method of Shipment:	Time: 12:00		Received By (Signature): Received By (Print Name): Company Name:	Date: DEC 22 2016 Relinquished To: Method of Shipment:	Time: 12:00				
Chain of Custody	Relinquished By (Signature): Relinquished By (Print Name): Company Name:	Date: Relinquished To: Method of Shipment:	Time:		Received By (Signature): Received By (Print Name): Company Name:	Date: Relinquished To: Method of Shipment:	Time:				

Pennsylvania - HQ
350 Hochberg Road
Monroeville, PA 15146
724.325.1776 Phone
724.733.1799 Fax

Washington
Columbia Basin Analytical Laboratories
2710 North 20th Avenue
Pasco, WA 99301
509.545.4989 Phone
509.544.6010 Fax



Request for Environmental and IH Laboratory Analytical Services

ATTENTION TO: RYAN MATHEWS		Purchase Order No.:		Client Job No.:		162017	
Lab Use Only		Project No.:		Client No.:		Turnaround Request	
Date Logged In:		Logged In By:		Standard: Yes No		If 'No', No. of Business Days:	
Name: Amanda Embysk, Ryan Mathews		Company: Fulcrum Environmental Consulting		Sample Purpose: Information X Regulatory <input type="checkbox"/> Accreditation (please list below):			
Address: 406 North 2nd Street		City, State, Zip: Yakima, WA, 98901		System ID #:			
Phone: (509) 574-0839		Fax: (509) 575-8453		DOH Source #:			
Call with Verbal Results:		Email Results To: aembysk@fulcrum.net, CC: rmathews@fulcrum.net		Multiple Sources #s:			
Fax Results To:		Name: Lorrie Boutilier		Sample Purpose: <input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> Other <input type="checkbox"/>			
Company: Fulcrum Environmental		Email: lboutilier@fulcrum.net		Preservation: <input type="checkbox"/> UNPR <input type="checkbox"/> DW <input type="checkbox"/> A			
Address: 406 North 2nd Street		City, State, Zip: Yakima, WA, 98901		Matrix: <input type="checkbox"/> WW=Wastewater <input type="checkbox"/> GW=Groundwater <input type="checkbox"/> S=Soil/Sludge <input type="checkbox"/> E=Extract			
Phone: (509) 574-0839		Fax: (509) 575-8453		Container: <input type="checkbox"/> P=Plastic <input type="checkbox"/> G=Glass <input type="checkbox"/> W=Wipe <input type="checkbox"/> A=Air (filter or tube)			
Special Instructions		EPA 200.8: Pb, Cu		Analysis Requested			
Client Sample ID		Sample Description		Sample Date		Sample Time	
WE122216-P-CF-12		Support Servers B		12/12			
WE122216-P-CDF-13		Support Servers C					
WE122216-P-OF-14		Facility Lounge					
WE122216-P-OF-15		Consultors Office					
WE122216-P-CF-16		Room 7					
WE122216-P-CDF-17		Room 8					
WE122216-P-CF-18		Room 9					
WE122216-P-OR-19		Southmentary <i>Billings</i>					
WE122216-P-RBF-20		↓					
WE122216-P-CDF-21		Room 11					
WE122216-P-CF-22		Room 11					
Chain of Custody		Relinquished By (Signature): <i>Ryan Mathews</i>		Date: 12/12		Time: 1:20	
Relinquished By (Print Name): <i>Ryan Mathews</i>		Relinquished To:		Method of Shipment:			
Company Name:		Date:		Time:			
Chain of Custody		Relinquished By (Signature): <i>Steph Stoppel</i>		Date: DEC 22 2016		Time: 1:20	
Relinquished By (Print Name): <i>Steph Stoppel</i>		Relinquished To:		Method of Shipment:			
Company Name:		Date:		Time:			
Chain of Custody		Relinquished By (Signature):		Date:		Time:	
Relinquished By (Print Name):		Relinquished To:		Method of Shipment:			
Company Name:		Date:		Time:			

Pennsylvania - HQ
350 Hochberg Road
Monroeville, PA 15146

Washington
Columbia Basin Analytical Laboratories
2710 North 20th Avenue
Pasco, WA 99301

724.325.1776 Phone
724.733.1799 Fax

509.545.4989 Phone
509.544.6010 Fax



Request for Environmental and IH Laboratory Analytical Services

ATTENTION TO: RYAN MATHEWS		Purchase Order No.:	Client Job No.:	162017
Lab Use Only	Project No.:	Date Logged In:	Client No.:	Logged In By:
Report Results To	Name: Amanda Enbysk, Ryan Mathews	Company: Fulcrum Environmental Consulting	Address: 406 North 2nd Street	City, State, Zip: Yakima, WA, 98901
Phone: (509) 574-0839	Fax: (509) 575-8453	Call with Verbal Results:	Email Results To: aenbysk@fulcrum.net, CC: mathews@fulcrum.net	Fax Results To:
Send Invoice To	Name: Lorrie Boutilier	Company: Fulcrum Environmental	Address: 406 North 2nd Street	City, State, Zip: Yakima, WA, 98901
Phone: (509) 574-0839	Fax: (509) 575-8453	Special Instructions		
Client Sample ID	Sample Description	Sample Date	Sample Time	Wipe Area / Air Volume
WE12216-P-CF-23	Room 12	12/22		
WE12216-P-CF-24	Resource Room			
WE12216-P-WE-25	Sym outside gym			
WE12216-P-WE-26				
WE12216-P-BF-27	Nurses office			
WE12216-P-NF-28	Library work room			
WE12216-P-OF-29	Room 13			
WE12216-P-CF-30	Room 14			
WE12216-P-CF-31	Room 15			
WE12216-P-CF-32	Room 16			
WE12216-P-CF-33				
Chain of Custody	Relinquished By (Signature): <i>[Signature]</i>	Date: 12/22	Time: 1200	
Chain of Custody	Relinquished By (Print Name): <i>Kieran</i>	Method of Shipment:		
Chain of Custody	Relinquished By (Signature):	Date:	Time:	
Chain of Custody	Relinquished By (Print Name):	Method of Shipment:		
Turnaround Request	Standard: Yes No	If 'No', No. of Business Days:	Accreditation (please list below):	
Drinking Water Sample Only	Sample Purpose: Information X Regulatory <input type="checkbox"/>	System ID #:	DOH Source #:	Multiple Sources #s:
Chemistry Analysis Key	Preservation: Unpres 4°C HNO ₃ Other	Matrix: H ₂ SO ₄ HCl NaOH Na ₂ SO ₄	WW=Wastewater GW=Groundwater S=Soil/Sediment E=Extract	SW=Surface Water DW=Drinking Water O=Oil X=Other
Analysis Requested				
EPA 200.8: Pb, Cu	Pres. Upon Receipt (Y/N)	UNPR.	DW	
	Preservation	Matrix	Container Type	pH
				No. Containers
				17.7
				14.3
				14.4
				15.4
				14.8
				14.6
				17.4
				17.4
				18.6
				19.5
				19.5
				19.5

Pennsylvania - HQ
350 Hochberg Road
Monroeville, PA 15146
724.325.1776 Phone
724.733.1799 Fax

Washington
Columbia Basin Analytical Laboratories
2710 North 20th Avenue
Pasco, WA 99301
509.545.4989 Phone
509.544.6010 Fax



Request for Environmental and IH Laboratory Analytical Services

ATTENTION TO: RYAN MATHEWS		Purchase Order No.: 162017		Client Job No.: 162017	
Lab Use Only	Project No.: Date Logged In:	Client No.: Logged In By:			
Report Results To	Name: Amanda Enbysk, Ryan Mathews				
	Company: Fulcrum Environmental Consulting				
	Address: 406 North 2nd Street				
	City, State, Zip: Yakima, WA, 98901				
	Phone: (509) 574-0839 Fax: (509) 575-8453				
Call with Verbal Results: aenbysk@fulcrum.net, CC: rmathews@fulcrum.net					
Fax Results To: Fulcrum Environmental Email: lboutillier@fulcrum.net					
Name: Lorrie Boutillier					
Company: Fulcrum Environmental					
Address: 406 North 2nd Street					
City, State, Zip: Yakima, WA, 98901					
Phone: (509) 574-0839 Fax: (509) 575-8453					
Special Instructions					
Send Invoice To		Analysis Requested			
Client Sample ID		Sample Description	Sample Date	Sample Time	Wipe Area / Air Volume
WE122216-P-CF-34		Room 17	12/22		
WE122216-P-CF-35		Room 18			
WE122216-P-CF-36		P2			
WE122216-P-CF-37		P1			
WE122216-P-CF-38		P4			
WE122216-P-CF-39		P5			
Chain of Custody		Relinquished By (Signature): <i>[Signature]</i>	Date: 12/22	Time: 1:00P	
Chain of Custody		Relinquished By (Print Name): <i>[Name]</i>	Relinquished To:	Method of Shipment:	
Chain of Custody		Relinquished By (Signature): <i>[Signature]</i>	Date:	Time:	
Chain of Custody		Relinquished By (Print Name):	Relinquished To:	Method of Shipment:	
Chain of Custody		Received By (Signature): <i>[Signature]</i>	Date: DEC 22 2016	Time: 1:00P	
Chain of Custody		Received By (Print Name): <i>[Name]</i>	Relinquished To:	Method of Shipment:	
Chain of Custody		Received By (Signature):	Date:	Time:	
Chain of Custody		Received By (Print Name):	Relinquished To:	Method of Shipment:	

Pennsylvania - HQ
350 Hochberg Road
Monroeville, PA 15146
724.325.1776 Phone
724.733.1799 Fax

Washington
Columbia Basin Analytical Laboratories
2710 North 20th Avenue
Pasco, WA 99301
509.545.4989 Phone
509.544.6010 Fax

