



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Attention:

Monday, March 7, 2022

Certificate of Analysis

FINAL

Project Information:

Report for Lab No: 60415.
Samples flushed by Martel on November 2, 2021 sampled by Martel on November 3, 2021.
Project Identification: MD HB 270
School: Gale-Bailey ES PSC #08.029.

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 60415 1 CLIENT SAMPLE IDENTIFICATION GBES-1-DC [water fountain--loading dock corridor] Sample Date/Time 11/03/2021 06:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 19:14 BJ

MARTEL NO. 60415 2 CLIENT SAMPLE IDENTIFICATION GBES-2-FC [sink on left--kitchen] Sample Date/Time 11/03/2021 06:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 19:21 BJ

MARTEL NO. 60415 3 CLIENT SAMPLE IDENTIFICATION GBES-3-FC [sink in middle--kitchen] Sample Date/Time 11/03/2021 06:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.02	ug/l	EPA .200.8	2	01/14/2022 09:16 BJ

MARTEL NO. 60415 4 CLIENT SAMPLE IDENTIFICATION GBES-4-FC [sink on right--kitchen] Sample Date/Time 11/03/2021 06:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 19:24 BJ

MARTEL NO. 60415 6 CLIENT SAMPLE IDENTIFICATION GBES-6-IM [Ice Machine --kitchen] Sample Date/Time 11/03/2021 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 19:26 BJ

MARTEL NO. 60415 7 CLIENT SAMPLE IDENTIFICATION GBES-7-DC [water fountain--cafeteria] Sample Date/Time 11/03/2021 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.13	ug/l*	EPA .200.8	2	01/14/2022 09:18 BJ

MARTEL NO. 60415 8 CLIENT SAMPLE IDENTIFICATION GBES-8-DC [water fountain--main office] Sample Date/Time 11/03/2021 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 19:29 BJ

MARTEL NO. 60415 9 CLIENT SAMPLE IDENTIFICATION GBES-9-DC [water fountain--corridor] Sample Date/Time 11/03/2021 06:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 19:31 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60415 10	GBES-10-FC [sink--teachers lounge]				11/03/2021 06:28
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.00	ug/l*	EPA .200.8	2	03/01/2022 19:34 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60415 11	GBES-11-DB [bubbler--teachers lounge]				11/03/2021 06:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	removed		EPA .200.8	2	//

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60415 12	GBES-12-DC [water fountain--corridor]				11/03/2021 06:29
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 19:44 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60415 13	GBES-13-FC [sink--classroom 26]				11/03/2021 06:47
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.91	ug/l	EPA .200.8	2	03/01/2022 19:49 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60415 14	GBES-14-DB [bubbler--classroom 26]				11/03/2021 06:47
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.21	ug/l	EPA .200.8	2	03/01/2022 19:52 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60415 17	GBES-17-FC [sink--classroom 21 - K]				11/03/2021 06:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 19:54 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60415 18	GBES-18-DB [bubbler--classroom 21 - K]				11/03/2021 06:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 19:57 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
60415 21	GBES-21-FC [sink--classroom 105 - K]				11/03/2021 06:40
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 19:59 BJ



Certificate of Analysis

MARTEL NO. 60415 22 CLIENT SAMPLE IDENTIFICATION GBES-22-DB [bubbler--classroom 105 - K] Sample Date/Time 11/03/2021 06:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:02 BJ

MARTEL NO. 60415 23 CLIENT SAMPLE IDENTIFICATION GBES-23-FC [sink--classroom 107 - K] Sample Date/Time 11/03/2021 06:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:04 BJ

MARTEL NO. 60415 24 CLIENT SAMPLE IDENTIFICATION GBES-24-DB [bubbler--classroom 107 - K] Sample Date/Time 11/03/2021 06:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:07 BJ

MARTEL NO. 60415 25 CLIENT SAMPLE IDENTIFICATION GBES-25-FC [sink - Left--activity area - 106] Sample Date/Time 11/03/2021 06:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:09 BJ

MARTEL NO. 60415 26 CLIENT SAMPLE IDENTIFICATION GBES-26-FC [sink - Right--activity area - 106] Sample Date/Time 11/03/2021 06:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:17 BJ

MARTEL NO. 60415 27 CLIENT SAMPLE IDENTIFICATION GBES-27-DB [bubbler--activity area - 106] Sample Date/Time 11/03/2021 06:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.9	ug/l*	EPA .200.8	2	03/01/2022 20:25 BJ

MARTEL NO. 60415 28 CLIENT SAMPLE IDENTIFICATION GBES-28-FC [sink - Left--CR 108 (SP-Ed) Life Skills] Sample Date/Time 11/03/2021 06:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:27 BJ

MARTEL NO. 60415 29 CLIENT SAMPLE IDENTIFICATION GBES-29-FC [sink - Right--CR 108 (SP-Ed) Life Skills] Sample Date/Time 11/03/2021 06:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:30 BJ



MARTEL NO. 60415 30 CLIENT SAMPLE IDENTIFICATION GBES-30-DB [bubbler--CR 108 (SP-Ed) Life Skills] Sample Date/Time 11/03/2021 06:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:32 BJ

MARTEL NO. 60415 31 CLIENT SAMPLE IDENTIFICATION GBES-31-FC [sink--classroom 110B - Pre-K] Sample Date/Time 11/03/2021 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:35 BJ

MARTEL NO. 60415 32 CLIENT SAMPLE IDENTIFICATION GBES-32-DB [bubbler--classroom 110B - Pre-K] Sample Date/Time 11/03/2021 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:37 BJ

MARTEL NO. 60415 33 CLIENT SAMPLE IDENTIFICATION GBES-33-DC [water fountain--corridor] Sample Date/Time 11/03/2021 06:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:40 BJ

MARTEL NO. 60415 34 CLIENT SAMPLE IDENTIFICATION GBES-34-FC [sink--classroom 109] Sample Date/Time 11/03/2021 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.96	ug/l	EPA .200.8	2	03/01/2022 20:43 BJ

MARTEL NO. 60415 35 CLIENT SAMPLE IDENTIFICATION GBES-35-DB [bubbler--classroom 109] Sample Date/Time 11/03/2021 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.47	ug/l	EPA .200.8	2	03/01/2022 20:45 BJ

MARTEL NO. 60415 38 CLIENT SAMPLE IDENTIFICATION GBES-38-FC [sink--classroom 111] Sample Date/Time 11/03/2021 06:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 20:55 BJ

MARTEL NO. 60415 39 CLIENT SAMPLE IDENTIFICATION GBES-39-DB [bubbler--classroom 111] Sample Date/Time 11/03/2021 06:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.18	ug/l	EPA .200.8	2	03/01/2022 21:00 BJ



Certificate of Analysis

MARTEL NO. 60415 42 CLIENT SAMPLE IDENTIFICATION GBES-42-FC [sink--classroom 113] Sample Date/Time 11/03/2021 06:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.45	ug/l	EPA .200.8	2	01/14/2022 09:21 BJ

MARTEL NO. 60415 43 CLIENT SAMPLE IDENTIFICATION GBES-43-DB [bubbler--classroom 113] Sample Date/Time 11/03/2021 06:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.30	ug/l	EPA .200.8	2	03/01/2022 21:03 BJ

MARTEL NO. 60415 44 CLIENT SAMPLE IDENTIFICATION GBES-44-FC [sink--classroom 112] Sample Date/Time 11/03/2021 06:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	27.5	ug/l*	EPA .200.8	2	03/01/2022 21:05 BJ

MARTEL NO. 60415 45 CLIENT SAMPLE IDENTIFICATION GBES-45-DB [bubbler--classroom 112] Sample Date/Time 11/03/2021 06:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.7	ug/l*	EPA .200.8	2	03/01/2022 21:08 BJ

MARTEL NO. 60415 46 CLIENT SAMPLE IDENTIFICATION GBES-46-DC [water fountain--corridor] Sample Date/Time 11/03/2021 06:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 21:10 BJ

MARTEL NO. 60415 47 CLIENT SAMPLE IDENTIFICATION GBES-47-FC [sink--classroom 114] Sample Date/Time 11/03/2021 06:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.82	ug/l	EPA .200.8	2	03/01/2022 21:13 BJ

MARTEL NO. 60415 48 CLIENT SAMPLE IDENTIFICATION GBES-48-DB [bubbler--classroom 114] Sample Date/Time 11/03/2021 06:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.48	ug/l	EPA .200.8	2	03/01/2022 21:15 BJ

MARTEL NO. 60415 49 CLIENT SAMPLE IDENTIFICATION GBES-49-FC [sink--classroom 115] Sample Date/Time 11/03/2021 06:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.4	ug/l*	EPA .200.8	2	03/01/2022 21:18 BJ



MARTEL NO. 60415 50 CLIENT SAMPLE IDENTIFICATION GBES-50-DB [bubbler--classroom 115] Sample Date/Time 11/03/2021 06:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.52	ug/l	EPA .200.8	2	03/01/2022 21:26 BJ

MARTEL NO. 60415 55 CLIENT SAMPLE IDENTIFICATION GBES-55-FC [sink--classroom 205] Sample Date/Time 11/03/2021 07:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 21:34 BJ

MARTEL NO. 60415 56 CLIENT SAMPLE IDENTIFICATION GBES-56-DC [water fountain--corridor] Sample Date/Time 11/03/2021 07:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 21:36 BJ

MARTEL NO. 60415 57 CLIENT SAMPLE IDENTIFICATION GBES-57-FC [sink--classroom 119] Sample Date/Time 11/03/2021 07:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 21:39 BJ

MARTEL NO. 60415 58 CLIENT SAMPLE IDENTIFICATION GBES-58-DB [bubbler--classroom 119] Sample Date/Time 11/03/2021 07:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 21:41 BJ

MARTEL NO. 60415 59 CLIENT SAMPLE IDENTIFICATION GBES-59-FC [sink--classroom 120] Sample Date/Time 11/03/2021 07:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 21:44 BJ

MARTEL NO. 60415 60 CLIENT SAMPLE IDENTIFICATION GBES-60-DB [bubbler--classroom 120] Sample Date/Time 11/03/2021 07:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 21:46 BJ

MARTEL NO. 60415 61 CLIENT SAMPLE IDENTIFICATION GBES-61-FC [sink--classroom 121] Sample Date/Time 11/03/2021 07:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 21:49 BJ



MARTEL NO. 60415 62 CLIENT SAMPLE IDENTIFICATION GBES-62-DB [bubbler--classroom 121] Sample Date/Time 11/03/2021 07:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 21:51 BJ

MARTEL NO. 60415 63 CLIENT SAMPLE IDENTIFICATION GBES-63-FC [sink--classroom 123] Sample Date/Time 11/03/2021 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 21:54 BJ

MARTEL NO. 60415 64 CLIENT SAMPLE IDENTIFICATION GBES-64-DB [bubbler--classroom 123] Sample Date/Time 11/03/2021 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.41	ug/l	EPA .200.8	2	03/01/2022 22:04 BJ

MARTEL NO. 60415 67 CLIENT SAMPLE IDENTIFICATION GBES-67-FC [sink--classroom 117] Sample Date/Time 11/03/2021 06:59

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.21	ug/l	EPA .200.8	2	03/01/2022 22:09 BJ

MARTEL NO. 60415 68 CLIENT SAMPLE IDENTIFICATION GBES-68-DB [bubbler--classroom 117] Sample Date/Time 11/03/2021 06:59

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.02	ug/l	EPA .200.8	2	03/01/2022 22:12 BJ

MARTEL NO. 60415 69 CLIENT SAMPLE IDENTIFICATION GBES-69-DC [water fountain--corridor] Sample Date/Time 11/03/2021 07:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 22:14 BJ

MARTEL NO. 60415 70 CLIENT SAMPLE IDENTIFICATION GBES-70-FC [sink--CR 122 (Sp-Ed) Pull Out] Sample Date/Time 11/03/2021 07:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.91	ug/l*	EPA .200.8	2	01/14/2022 09:24 BJ

MARTEL NO. 60415 71 CLIENT SAMPLE IDENTIFICATION GBES-71-DB [bubbler--CR 122 (Sp-Ed) Pull Out] Sample Date/Time 11/03/2021 07:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.7	ug/l*	EPA .200.8	2	03/01/2022 22:17 BJ



MARTEL NO. 60415 76 CLIENT SAMPLE IDENTIFICATION GBES-76-FC [Sink--CR 20 (Sp-Ed) SOAR] Sample Date/Time 11/03/2021 06:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.63	ug/l	EPA .200.8	2	03/01/2022 22:20 BJ

MARTEL NO. 60415 77 CLIENT SAMPLE IDENTIFICATION GBES-77-DB [Bubbler--CR 20 (Sp-Ed) SOAR] Sample Date/Time 11/03/2021 06:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.32	ug/l	EPA .200.8	2	03/01/2022 22:22 BJ

MARTEL NO. 60415 80 CLIENT SAMPLE IDENTIFICATION GBES-80-BU [Bottle Filler--Corridor] Sample Date/Time 11/03/2021 06:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 22:25 BJ

MARTEL NO. 60415 81 CLIENT SAMPLE IDENTIFICATION GBES-81-BU [Bottle Filler--Main Office] Sample Date/Time 11/03/2021 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 22:27 BJ

MARTEL NO. 60415 82 CLIENT SAMPLE IDENTIFICATION GBES-82-BU [Bottle Filler--cafeteria] Sample Date/Time 11/03/2021 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.5	ug/l*	EPA .200.8	2	03/01/2022 22:35 BJ

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO₃ Analysis: Lead (EPA 200.8)

FLUSH: 11/2/21 18:48
 Sample Start Date/Time: 11/2/21 18:48

FLUSH: 11/2/21 20:05
 End Date/Time: 11/2/21 20:05

SAMPLE: 11/3/21 6:17

SAMPLE: 11/3/21 7:07

Sampler/Relinquished By: [Signature] Received at Martel by: [Signature] Date/Time: 11/3/21 15:00

03 Gale-Bailey Elementary School PSC #08.029
 4740 Pisgah-Marbury Road Marbury, MD 20658

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

18:48
20:05
Flush
Martel NO: 60415

Martel #	Sample #	Location ID #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)</small>	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush Date	Sample Time
1	1	GBES-1-DC	water fountain	DC	loading dock corridor	C	✓	6:22
2	2	GBES-2-FC	sink on left	FC	kitchen	C	✓	6:23
3	3	GBES-3-FC	sink in middle	FC	kitchen	C	✓	↓
4	4	GBES-4-FC	sink on right	FC	kitchen	C	✓	↓
5	6	GBES-6-IM	Ice Machine	IM	kitchen	C	✓	6:24
6	7	GBES-7-DC	water fountain	DC	cafeteria	C	✓	6:21
7	8	GBES-8-DC	water fountain	DC	main office	C	✓	6:19
8	9	GBES-9-DC	water fountain	DC	corridor	C	✓	6:17
9	10	GBES-10-FC	sink	FC	teachers lounge	C	✓	6:28
10	11	GBES-11-DB	bubbler	DB	teachers lounge	C	✓	REMOVED
11	12	GBES-12-DC	water fountain	DC	corridor	C	✓	6:29
12	13	GBES-13-FC	sink	FC	classroom 26	C	✓	6:47
13	14	GBES-14-DB	bubbler	DB	classroom 26	C	✓	↓
14	17	GBES-17-FC	sink	FC	classroom 21 - K	C	✓	6:42
15	18	GBES-18-DB	bubbler	DB	classroom 21 - K	C	✓	↓
16	21	GBES-21-FC	sink	FC	classroom 105 - K	C	✓	6:40
17	22	GBES-22-DB	bubbler	DB	classroom 105 - K	C	✓	↓
18	23	GBES-23-FC	sink	FC	classroom 107 - K	C	✓	6:39
19	24	GBES-24-DB	bubbler	DB	classroom 107 - K	C	✓	↓
20	25	GBES-25-FC	sink - Left	FC	activity area - 106	C	✓	6:38
21	26	GBES-26-FC	sink - Right	FC	activity area - 106	C	✓	↓
22	27	GBES-27-DB	bubbler	DB	activity area - 106	C	✓	↓
23	28	GBES-28-FC	sink - Left	FC	CR 108 (SP-Ed) Life Skills	C	✓	6:37
24	29	GBES-29-FC	sink - Right	FC	CR 108 (SP-Ed) Life Skills	C	✓	↓
25	30	GBES-30-DB	bubbler	DB	CR 108 (SP-Ed) Life Skills	C	✓	↓

03 Gale-Bailey Elementary School PSC #08.029

4740 Pisgah-Marbury Road Marbury, MD 20658

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush **60415**

26	31	GBES-31-FC	sink	FC	classroom 110B - Pre-K	C	✓	6:34
27	32	GBES-32-DB	bubbler	DB	classroom 110B - Pre-K	C	✓	↓
28	33	GBES-33-DC	water fountain	DC	corridor	C	✓	6:35
29	34	GBES-34-FC	sink	FC	classroom 109	C	✓	6:33
30	35	GBES-35-DB	bubbler	DB	classroom 109	C	✓	↓
31	38	GBES-38-FC	sink	FC	classroom 111	C	✓	6:31
32	39	GBES-39-DB	bubbler	DB	classroom 111	C	✓	↓
33	42	GBES-42-FC	sink	FC	classroom 113	C	✓	6:53
34	43	GBES-43-DB	bubbler	DB	classroom 113	C	✓	↓
35	44	GBES-44-FC	sink	FC	classroom 112	C	✓	6:52
36	45	GBES-45-DB	bubbler	DB	classroom 112	C	✓	↓
37	46	GBES-46-DC	water fountain	DC	corridor	C	✓	6:51
38	47	GBES-47-FC	sink	FC	classroom 114	C	✓	6:55
39	48	GBES-48-DB	bubbler	DB	classroom 114	C	✓	↓
40	49	GBES-49-FC	sink	FC	classroom 115	C	✓	6:56
41	50	GBES-50-DB	bubbler	DB	classroom 115	C	✓	↓
42	55	GBES-55-FC	sink	FC	classroom 205	C	✓	7:03
43	56	GBES-56-DC	water fountain	DC	corridor	C	✓	7:04
44	57	GBES-57-FC	sink	FC	classroom 119	C	✓	7:05
45	58	GBES-58-DB	bubbler	DB	classroom 119	C	✓	↓
46	59	GBES-59-FC	sink	FC	classroom 120	C	✓	7:06
47	60	GBES-60-DB	bubbler	DB	classroom 120	C	✓	↓
48	61	GBES-61-FC	sink	FC	classroom 121	C	✓	7:07
49	62	GBES-62-DB	bubbler	DB	classroom 121	C	✓	↓
50	63	GBES-63-FC	sink	FC	classroom 123	C	✓	6:57
51	64	GBES-64-DB	bubbler	DB	classroom 123	C	✓	↓
52	67	GBES-67-FC	sink	FC	classroom 117	C	✓	6:59
53	68	GBES-68-DB	bubbler	DB	classroom 117	C	✓	↓
54	69	GBES-69-DC	water fountain	DC	corridor	C	✓	7:00
55	70	GBES-70-FC	sink	FC	CR 122 (Sp-Ed) Pull Out	C	✓	7:01
56	71	GBES-71-DB	bubbler	DB	CR 122 (Sp-Ed) Pull Out	C	✓	↓
57	76	GBES-76-FC	Sink	FC	CR 20 (Sp-Ed) SOAR	C	✓	6:46
58	77	GBES-77-DB	Bubbler	DB	CR 20 (Sp-Ed) SOAR	C	✓	↓

03 Gale-Bailey Elementary School PSC #08.029

4740 Pisgah-Marbury Road Marbury, MD 20658

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN
SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush **60415**

59	80	GBES-80-BU	Bottle Filler	BU	Corridor	C	✓	6:17
60	81	GBES-81-BU	Bottle Filler	BU	Main Office	C	✓	6:19
61	82	GBES-82-BU	Bottle Filler	BU	cafeteria	C	✓	6:21