



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Attention:

Monday, March 14, 2022

Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 60445.
Samples flushed by Martel on December 17, 2021, sampled by Martel on December 18, 2021.
Project Identification: MD HB 270
School: 21 C. Paul Barnhart ES PSC #08.034

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.


Project Manager



MARTEL NO. 60445 1 CLIENT SAMPLE IDENTIFICATION PBES-1-FC [sink 2 compartment --kitchen 2 comp sink] Sample Date/Time 12/18/2021 07:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.94	ug/l*	EPA .200.8	2	02/25/2022 09:05 BJ

MARTEL NO. 60445 2 CLIENT SAMPLE IDENTIFICATION PBES-2-FC [island sink next to 2 comp sink--kitchen sink] Sample Date/Time 12/18/2021 07:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 09:08 BJ

MARTEL NO. 60445 3 CLIENT SAMPLE IDENTIFICATION PBES-3-FC [island sink--kitchen sink] Sample Date/Time 12/18/2021 07:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.14	ug/l	EPA 200.8	2	02/25/2022 09:10 BJ

MARTEL NO. 60445 4 CLIENT SAMPLE IDENTIFICATION PBES-4-DC [water fountain--kitchen] Sample Date/Time 12/18/2021 07:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 09:12 BJ

MARTEL NO. 60445 5 CLIENT SAMPLE IDENTIFICATION PBES-5-IM [Ice Machine --kitchen] Sample Date/Time 12/18/2021 07:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	02/25/2022 09:15 BJ

MARTEL NO. 60445 6 CLIENT SAMPLE IDENTIFICATION PBES-6-FC [Sink - Left fixture--Kitchen - Left Fixture on] Sample Date/Time 12/18/2021 07:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.36	ug/l	EPA .200.8	2	02/25/2022 09:17 BJ

MARTEL NO. 60445 7 CLIENT SAMPLE IDENTIFICATION PBES-7-FC [Sink - Right fixture--Kitchen - Right Fixture o] Sample Date/Time 12/18/2021 07:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.02	ug/l	EPA .200.8	2	02/25/2022 09:20 BJ

MARTEL NO. 60445 8 CLIENT SAMPLE IDENTIFICATION PBES-8-FC [sink--music room] Sample Date/Time 12/18/2021 07:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.67	ug/l	EPA 200.8	2	02/25/2022 09:29 BJ



MARTEL NO. 60445 9 CLIENT SAMPLE IDENTIFICATION PBES-9-DB [bubbler--music room] Sample Date/Time 12/18/2021 07:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	02/25/2022 09:34 BJ

MARTEL NO. 60445 10 CLIENT SAMPLE IDENTIFICATION PBES-10-DC [water fountain--corridor] Sample Date/Time 12/18/2021 07:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	02/25/2022 09:37 BJ

MARTEL NO. 60445 11 CLIENT SAMPLE IDENTIFICATION PBES-11-DC [water fountain--corridor] Sample Date/Time 12/18/2021 07:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 09:39 BJ

MARTEL NO. 60445 12 CLIENT SAMPLE IDENTIFICATION PBES-12-FC [sink--teacher lounge] Sample Date/Time 12/18/2021 07:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.71	ug/l	EPA .200.8	2	02/25/2022 09:42 BJ

MARTEL NO. 60445 13 CLIENT SAMPLE IDENTIFICATION PBES-13-DB [bubbler--teacher lounge] Sample Date/Time 12/18/2021 07:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 09:44 BJ

MARTEL NO. 60445 28 CLIENT SAMPLE IDENTIFICATION PBES-28-FC [sink on right--Classroom - K] Sample Date/Time 12/18/2021 07:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 09:46 BJ

MARTEL NO. 60445 29 CLIENT SAMPLE IDENTIFICATION PBES-29-FC [sink on left--Classroom - K] Sample Date/Time 12/18/2021 07:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.14	ug/l	EPA .200.8	2	02/25/2022 09:49 BJ

MARTEL NO. 60445 30 CLIENT SAMPLE IDENTIFICATION PBES-30-FC [sink--Classroom 114 - K] Sample Date/Time 12/18/2021 07:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.63	ug/l	EPA .200.8	2	02/25/2022 09:51 BJ



MARTEL NO. 60445 31 CLIENT SAMPLE IDENTIFICATION PBES-31-DB [bubbler--Classroom 114 - K] Sample Date/Time 12/18/2021 07:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 09:54 BJ

MARTEL NO. 60445 32 CLIENT SAMPLE IDENTIFICATION PBES-32-FC [sink--Classroom 113 - K] Sample Date/Time 12/18/2021 07:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:06 BJ

MARTEL NO. 60445 33 CLIENT SAMPLE IDENTIFICATION PBES-33-DB [bubbler--Classroom 113 - K] Sample Date/Time 12/18/2021 07:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:19 BJ

MARTEL NO. 60445 34 CLIENT SAMPLE IDENTIFICATION PBES-34-FC [sink--Classroom 105 - K] Sample Date/Time 12/18/2021 07:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.64	ug/l	EPA .200.8	2	02/25/2022 10:21 BJ

MARTEL NO. 60445 35 CLIENT SAMPLE IDENTIFICATION PBES-35-DB [bubbler--Classroom 105 - K] Sample Date/Time 12/18/2021 07:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:23 BJ

MARTEL NO. 60445 36 CLIENT SAMPLE IDENTIFICATION PBES-36-FC [sink--Classroom 109 - K] Sample Date/Time 12/18/2021 07:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:26 BJ

MARTEL NO. 60445 37 CLIENT SAMPLE IDENTIFICATION PBES-37-DB [bubbler--Classroom 109 - K] Sample Date/Time 12/18/2021 07:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:28 BJ

MARTEL NO. 60445 38 CLIENT SAMPLE IDENTIFICATION PBES-38-FC [sink - Right--Classroom 3 - Pre-K] Sample Date/Time 12/18/2021 07:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:31 BJ



MARTEL NO. 60445 39 CLIENT SAMPLE IDENTIFICATION PBES-39-DB [bubbler--Classroom 3 - Pre-K] Sample Date/Time 12/18/2021 07:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.21	ug/l	EPA .200.8	2	02/25/2022 10:33 BJ

MARTEL NO. 60445 40 CLIENT SAMPLE IDENTIFICATION PBES-40-FC [sink - Left--Classroom 3 - Pre-K] Sample Date/Time 12/18/2021 07:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:36 BJ

MARTEL NO. 60445 41 CLIENT SAMPLE IDENTIFICATION PBES-41-FC [sink - Right--Classroom 2 - Pre-K] Sample Date/Time 12/18/2021 07:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.72	ug/l	EPA .200.8	2	02/25/2022 10:38 BJ

MARTEL NO. 60445 42 CLIENT SAMPLE IDENTIFICATION PBES-42-DB [bubbler--Classroom 2 - Pre-K] Sample Date/Time 12/18/2021 07:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:48 BJ

MARTEL NO. 60445 43 CLIENT SAMPLE IDENTIFICATION PBES-43-FC [sink - Left--Classroom 2 - Pre-K] Sample Date/Time 12/18/2021 07:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:53 BJ

MARTEL NO. 60445 44 CLIENT SAMPLE IDENTIFICATION PBES-44-DC [water fountain--corridor] Sample Date/Time 12/18/2021 07:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:56 BJ

MARTEL NO. 60445 45 CLIENT SAMPLE IDENTIFICATION PBES-45-DC [water fountain--corridor] Sample Date/Time 12/18/2021 07:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 10:58 BJ

MARTEL NO. 60445 46 CLIENT SAMPLE IDENTIFICATION PBES-46-FC [sink - Left--CR 1 - Pre-K] Sample Date/Time 12/18/2021 07:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 11:01 BJ



MARTEL NO. 60445 47 CLIENT SAMPLE IDENTIFICATION PBES-47-DB [bubbler--CR 1 - Pre-K] Sample Date/Time 12/18/2021 07:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 11:03 BJ

MARTEL NO. 60445 48 CLIENT SAMPLE IDENTIFICATION PBES-48-FC [sink - Right--CR 1 - Pre-K] Sample Date/Time 12/18/2021 07:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 11:05 BJ

MARTEL NO. 60445 49 CLIENT SAMPLE IDENTIFICATION PBES-49-FC [sink - Left--Pre-K] Sample Date/Time 12/18/2021 07:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.29	ug/l	EPA .200.8	2	02/25/2022 11:08 BJ

MARTEL NO. 60445 50 CLIENT SAMPLE IDENTIFICATION PBES-50-DB [bubbler--Pre-K] Sample Date/Time 12/18/2021 07:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/25/2022 11:10 BJ

MARTEL NO. 60445 51 CLIENT SAMPLE IDENTIFICATION PBES-51-FC [sink - Right--Pre-K] Sample Date/Time 12/18/2021 07:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.32	ug/l	EPA .200.8	2	02/25/2022 11:13 BJ

MARTEL NO. 60445 52 CLIENT SAMPLE IDENTIFICATION PBES-52-DC [water fountain--corridor] Sample Date/Time 12/18/2021 07:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 08:10 BJ

MARTEL NO. 60445 53 CLIENT SAMPLE IDENTIFICATION PBES-53-FC [sink--nurse office] Sample Date/Time 12/18/2021 07:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.75	ug/l*	EPA .200.8	2	03/01/2022 08:23 BJ

MARTEL NO. 60445 56 CLIENT SAMPLE IDENTIFICATION PBES-56-DC [water fountain--corridor (2nd Floor)] Sample Date/Time 12/18/2021 07:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 08:25 BJ



MARTEL NO. 60445 57 CLIENT SAMPLE IDENTIFICATION PBES-57-DC [water fountain--corridor (2nd Floor)] Sample Date/Time 12/18/2021 07:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 08:27 BJ

MARTEL NO. 60445 62 CLIENT SAMPLE IDENTIFICATION PBES-62-FC [sink--CR 23 (Sp-Ed) Pull Out (2nd Floor)] Sample Date/Time 12/18/2021 07:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 08:30 BJ

MARTEL NO. 60445 63 CLIENT SAMPLE IDENTIFICATION PBES-63-DB [bubbler--CR 23 (Sp-Ed) Pull Out (2nd Floor)] Sample Date/Time 12/18/2021 07:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 08:32 BJ

MARTEL NO. 60445 80 CLIENT SAMPLE IDENTIFICATION PBES-80-DC [water fountain--corridor (2nd Floor)] Sample Date/Time 12/18/2021 07:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 08:35 BJ

MARTEL NO. 60445 81 CLIENT SAMPLE IDENTIFICATION PBES-81-DC [water fountain--corridor (2nd Floor)] Sample Date/Time 12/18/2021 07:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 08:37 BJ

MARTEL NO. 60445 90 CLIENT SAMPLE IDENTIFICATION PBES-90-FC [sink--CR 10 (Sp-Ed) Pull Out (2nd Floor)] Sample Date/Time 12/18/2021 07:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.71	ug/l	EPA .200.8	2	03/01/2022 08:40 BJ

MARTEL NO. 60445 91 CLIENT SAMPLE IDENTIFICATION PBES-91-DB [bubbler--CR 10 (Sp-Ed) Pull Out (2nd Floor)] Sample Date/Time 12/18/2021 07:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.73	ug/l*	EPA .200.8	2	03/01/2022 08:42 BJ

MARTEL NO. 60445 95 CLIENT SAMPLE IDENTIFICATION PBES-95-FC [sink--(Sp-Ed) Pull Out (2nd Floor)] Sample Date/Time 12/18/2021 07:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.10	ug/l	EPA .200.8	2	03/01/2022 08:52 BJ



MARTEL NO. 60445	96	CLIENT SAMPLE IDENTIFICATION PBES-96-BU [Bottler Filler--Corridor]	Sample Date/Time 12/18/2021 07:14
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.21	ug/l	EPA .200.8	2	03/01/2022 08:57 BJ

MARTEL NO. 60445	97	CLIENT SAMPLE IDENTIFICATION PBES-97-BU [Bottler Filler--Corridor]	Sample Date/Time 12/18/2021 07:35
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	03/01/2022 09:00 BJ

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO₃ Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 12/18/21 0708 End Date/Time: 12/18/21 0746

Sampler/Relinquished By: DS Received at Martel by: [Signature] Date/Time: 12/20/21 1000

21 C. Paul Barnhart Elementary School PSC #08.034
4800 Lancaster Circle Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

60445

Martel #	Sample #	Location ID #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)</small>	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush	Sample Time
							Flush Date	
1	1	PBES-1-FC	sink 2 compartment	FC	kitchen 2 comp sink	C	12/17/21	0708
2	2	PBES-2-FC	island sink next to 2 comp sink	FC	kitchen sink	C		0708
3	3	PBES-3-FC	island sink	FC	kitchen sink	C		0708
4	4	PBES-4-DC	water fountain	DC	kitchen	C		0709
5	5	PBES-5-IM	Ice Machine	IM	kitchen	C		0709
6	6	PBES-6-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C		0710
7	7	PBES-7-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C		0710
8	8	PBES-8-FC	sink	FC	music room	C		0712
9	9	PBES-9-DB	bubbler	DB	music room	C		0712
10	10	PBES-10-DC	water fountain	DC	corridor	C		0713
11	11	PBES-11-DC	water fountain	DC	corridor	C		0713
12	12	PBES-12-FC	sink	FC	teacher lounge	C		0715
13	13	PBES-13-DB	bubbler	DB	teacher lounge	C		0715
14	28	PBES-28-FC	sink on right	FC	Classroom - K	C		0719
15	29	PBES-29-FC	sink on left	FC	Classroom - K	C		0719
16	30	PBES-30-FC	sink	FC	Classroom 114 - K	C		0718
17	31	PBES-31-DB	bubbler	DB	Classroom 114 - K	C		0718
18	32	PBES-32-FC	sink	FC	Classroom 113 - K	C		0722
19	33	PBES-33-DB	bubbler	DB	Classroom 113 - K	C		0722
20	34	PBES-34-FC	sink	FC	Classroom 105 - K	C		0720
21	35	PBES-35-DB	bubbler	DB	Classroom 105 - K	C		0720
22	36	PBES-36-FC	sink	FC	Classroom 109 - K	C		0721
23	37	PBES-37-DB	bubbler	DB	Classroom 109 - K	C		0721
24	38	PBES-38-FC	sink - Right	FC	Classroom 3 - Pre-K	C		0717
25	39	PBES-39-DB	bubbler	DB	Classroom 3 - Pre-K	C		0717

21 C. Paul Barnhart Elementary School PSC #08.034

4800 Lancaster Circle Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 11 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush **60445**

	26	40	PBES-40-FC	sink - Left	FC	Classroom 3 - Pre-K	C	0717
*	27	41	PBES-41-FC	sink - Right	FC	Classroom 2 - Pre-K	C	0733
*	28	42	PBES-42-DB	bubbler	DB	Classroom 2 - Pre-K	C	0733
*	29	43	PBES-43-FC	sink - Left	FC	Classroom 2 - Pre-K	C	0733
	30	44	PBES-44-DC	water fountain	DC	corridor	C	0725
	31	45	PBES-45-DC	water fountain	DC	corridor	C	0725
	32	46	PBES-46-FC	sink - Left	FC	CR 1 - Pre-K	C	0726
	33	47	PBES-47-DB	bubbler	DB	CR 1 - Pre-K	C	0726
	34	48	PBES-48-FC	sink - Right	FC	CR 1 - Pre-K	C	0726
*	35	49	PBES-49-FC	sink - Left	FC	Pre-K	C	0731
*	36	50	PBES-50-DB	bubbler	DB	Pre-K	C	0731
*	37	51	PBES-51-FC	sink - Right	FC	Pre-K	C	0731
	38	52	PBES-52-DC	water fountain	DC	corridor	C	0731
	39	53	PBES-53-FC	sink	FC	nurse office	C	0728
	40	56	PBES-56-DC	water fountain	DC	corridor (2nd Floor)	C	0746
	41	57	PBES-57-DC	water fountain	DC	corridor (2nd Floor)	C	0746
	42	62	PBES-62-FC	sink	FC	CR 23 (Sp-Ed) Pull Out (2nd Floor)	C	0737
	43	63	PBES-63-DB	bubbler	DB	CR 23 (Sp-Ed) Pull Out (2nd Floor)	C	0737
	44	80	PBES-80-DC	water fountain	DC	corridor (2nd Floor)	C	0735
	45	81	PBES-81-DC	water fountain	DC	corridor (2nd Floor)	C	0735
	46	90	PBES-90-FC	sink	FC	CR 10 (Sp-Ed) Pull Out (2nd Floor)	C	0741
	47	91	PBES-91-DB	bubbler	DB	CR 10 (Sp-Ed) Pull Out (2nd Floor)	C	0741
	48	95	PBES-95-FC	sink	FC	(Sp-Ed) Pull Out (2nd Floor)	C	0742
	49	96	PBES-96-BU	Bottler Filler	BU	Corridor	C	0714
	50	97	PBES-97-BU	Bottler Filler	BU	Corridor	C	0735