



Philip Caputo, Supervisor of Buildings, Grounds & Transportation

120 Paterson Avenue, East Rutherford, NJ 07073 | Phone: (201) 935-3007 | Fax: (201) 935-5639

April 2, 2022

Lead Drinking Water Testing Sampling Plan

All testing was performed in accordance with the Department of Environmental Protection. On Friday, December 3, 2021 we closed the building at 9:00 p.m. The building had to sit unaccompanied for 8 hours before testing. Wescheston Environmental arrived Saturday December 4, 2021 at 8:00 a.m. and performed the first draw samples on all sinks and water fountains that need to be tested.

We received the results of the first draw on December 16, 2021. Any sinks or water fountains that tested above the 15.5 parts per billion were repaired or removed from the system.

All repairs that were needed to correct the problems were performed by the Becton Regional Maintenance staff. We replaced faucets that were needed and removed 6 of the old style water fountains.

After receiving the systems flush results February 23, 2022 all results came back under the 15.5 parts per billion.

Philip Caputo

Supervisor of Buildings, Grounds & Transportation





Results Report

Order ID: 1L02392

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: Becton Regional HS
120 Paterson Ave
East Rutherford, NJ 07073

Attn: Noel Abraham

Regulatory ID:

Sample Number: 1L02392-01
Collector: NPA

Site: POE, Boiler Room
Collect Date: 12/05/2021 8:00 am

Sample ID:
Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/14/21 19:15 MKR

Sample Number: 1L02392-02
Collector: NPA

Site: Boys Locker RM Left DW
Collect Date: 12/05/2021 8:02 am

Sample ID:
Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 3.03 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/14/21 19:18 MKR

Sample Number: 1L02392-03
Collector: NPA

Site: Boys Locker RM Right DW
Collect Date: 12/05/2021 8:04 am

Sample ID:
Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/14/21 19:22 MKR

Sample Number: 1L02392-04
Collector: NPA

Site: Kitchen Sink 1
Collect Date: 12/05/2021 8:06 am

Sample ID:
Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 10.8 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/14/21 19:25 MKR

Sample Number: 1L02392-05
Collector: NPA

Site: Kitchen Sink 2
Collect Date: 12/05/2021 8:08 am

Sample ID:
Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 5.19 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 17:23 MKR

Report Generated On: 12/16/2021 6:41 pm 1L02392
STL_Results Revision #1.9 Effective: 04/16/2020





Results Report

Order ID: 1L02389

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: Becton Regional HS
120 Paterson Ave
East Rutherford, NJ 07073

Attn: Noel Abraham

Regulatory ID:

Sample Number: 1L02389-05
Collector: NPA

Site: Kitchen Sink 3-F
Collect Date: 12/05/2021 8:08 am

Sample ID:
Sample Type: Grab

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 3.11 µg/L EPA 200.8 1.00 1 01/20/22 RPV 01/24/22 13:32 MKR

Sample Number: 1L02389-06
Collector: NPA

Site: Kitchen Sink 4-F
Collect Date: 12/05/2021 8:10 am

Sample ID:
Sample Type: Grab

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 6.24 µg/L EPA 200.8 1.00 1 01/20/22 RPV 01/24/22 13:34 MKR

Sample Number: 1L02389-07
Collector: NPA

Site: Kitchen Sink 5-F
Collect Date: 12/05/2021 8:12 am

Sample ID:
Sample Type: Grab

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 4.55 µg/L EPA 200.8 1.00 1 01/20/22 RPV 01/24/22 13:38 MKR

Sample Number: 1L02389-12
Collector: NPA

Site: Girls Locker Rm DW-F
Collect Date: 12/05/2021 8:24 am

Sample ID:
Sample Type: Grab

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 2.85 µg/L EPA 200.8 1.00 1 02/22/22 MKR 02/22/22 13:58 MKR

Sample Number: 1L02389-24
Collector: NPA

Site: Hall O/S Rm 221 Right DW-F
Collect Date: 12/05/2021 8:48 am

Sample ID:
Sample Type: Grab

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 5.22 µg/L EPA 200.8 1.00 1 02/17/22 RPV 02/18/22 13:41 MKR

Report Generated On: 02/23/2022 11:07 am 1L02389
STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1L02392-13 Site: Girls Side Gym DW Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:24 am Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.33 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 17:49 MKR

Sample Number: 1L02392-14 Site: Girls Locker Rm DW Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:26 am Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 18.6 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 17:51 MKR

Sample Number: 1L02392-15 Site: Nurse Sink Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:28 am Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.95 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 17:53 MKR

Sample Number: 1L02392-16 Site: Aud. Hallway Right WC/BF Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:30 am Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 17:55 MKR

Sample Number: 1L02392-17 Site: BOE Conf. Rm Sink Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:32 am Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 17:58 MKR

Sample Number: 1L02392-18 Site: Faculty Rm Sink Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:34 am Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 5.60 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 18:00 MKR

Sample Number: 1L02392-19 Site: Hall O/S Rm 110 Right WC/BF Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:36 am Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 18:02 MKR

Report Generated On: 12/16/2021 6:41 pm 1L02392
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

| | | |
|---------------------------|----------------------------------|--------------|
| Sample Number: 1L02392-20 | Site: Home EC 1 | Sample ID: |
| Collector: NPA | Collect Date: 12/05/2021 8:38 am | Sample Type: |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 1.67 | µg/L | EPA 200.8 | 1.00 | 1 | 12/08/21 | JNM | 12/15/21 18:04 | MKR |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

| | | |
|---------------------------|----------------------------------|--------------|
| Sample Number: 1L02392-21 | Site: Home EC 2 | Sample ID: |
| Collector: NPA | Collect Date: 12/05/2021 8:40 am | Sample Type: |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 6.53 | µg/L | EPA 200.8 | 1.00 | 1 | 12/08/21 | JNM | 12/15/21 18:10 | MKR |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

| | | |
|---------------------------|----------------------------------|--------------|
| Sample Number: 1L02392-22 | Site: Home EC 3 | Sample ID: |
| Collector: NPA | Collect Date: 12/05/2021 8:42 am | Sample Type: |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 1.55 | µg/L | EPA 200.8 | 1.00 | 1 | 12/08/21 | JNM | 12/15/21 18:12 | MKR |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

| | | |
|---------------------------|----------------------------------|--------------|
| Sample Number: 1L02392-23 | Site: Home EC 4 | Sample ID: |
| Collector: NPA | Collect Date: 12/05/2021 8:44 am | Sample Type: |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 2.00 | µg/L | EPA 200.8 | 1.00 | 1 | 12/08/21 | JNM | 12/15/21 18:14 | MKR |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

| | | |
|---------------------------|----------------------------------|--------------|
| Sample Number: 1L02392-24 | Site: Home EC 5 | Sample ID: |
| Collector: NPA | Collect Date: 12/05/2021 8:46 am | Sample Type: |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 2.52 | µg/L | EPA 200.8 | 1.00 | 1 | 12/08/21 | JNM | 12/15/21 18:18 | MKR |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

| | | |
|---------------------------|----------------------------------|--------------|
| Sample Number: 1L02392-25 | Site: Home EC 6 | Sample ID: |
| Collector: NPA | Collect Date: 12/05/2021 8:48 am | Sample Type: |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 5.76 | µg/L | EPA 200.8 | 1.00 | 1 | 12/08/21 | JNM | 12/15/21 18:46 | MKR |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

| | | |
|---------------------------|----------------------------------|-----------------------------|
| Sample Number: 1L02392-26 | Site: Hall O/S Rm 221 Right DW | Sample ID: |
| Collector: NPA | Collect Date: 12/05/2021 8:50 am | Sample Type: <i>REMOVED</i> |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 17.0 | µg/L | EPA 200.8 | 1.00 | 1 | 12/08/21 | JNM | 12/15/21 18:48 | MKR |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

Report Generated On: 12/16/2021 6:41 pm 1L02392
 STL_Results Revision #1.9 Effective: 04/16/2020

SUBURBAN TESTING LABS





SUBURBAN TESTING LABS

Sample Number: 1L02392-27 Site: Hall O/S Rm 221 Left DW Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:52 am Sample Type: *REMOVED*

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 5.85 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 18:51 MKR

Sample Number: 1L02392-28 Site: Hall O/S Rm 227 Right DW Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:54 am Sample Type: *REMOVED*

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 32.9 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 18:53 MKR

Sample Number: 1L02392-29 Site: Hall O/S Rm 227 Left DW Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:56 am Sample Type: *REMOVED*

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 26.8 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 18:55 MKR

Sample Number: 1L02392-30 Site: Hall O/S Rm 222 Left DW Sample ID:
 Collector: NPA Collect Date: 12/05/2021 8:58 am Sample Type: *REMOVED*

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 34.4 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 19:01 MKR

Sample Number: 1L02392-31 Site: Hall O/S Rm 222 Right DW Sample ID:
 Collector: NPA Collect Date: 12/05/2021 9:00 am Sample Type: *REMOVED*

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 9.05 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 19:04 MKR

Sample Number: 1L02392-32 Site: Hall O/S Rm 210 Right DW Sample ID:
 Collector: NPA Collect Date: 12/05/2021 9:02 am Sample Type:

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/08/21 JNM 12/15/21 19:06 MKR

Report Generated On: 12/16/2021 6:41 pm 1L02392
 STL_Results Revision #1.9 Effective: 04/16/2020

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00206
 NJDEP # PA281



SUBURBAN TESTING LABS

| | | |
|---------------------------|----------------------------------|--------------|
| Sample Number: 1L02392-33 | Site: Faculty Rm Sink | Sample ID: |
| Collector: NPA | Collect Date: 12/05/2021 9:04 am | Sample Type: |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|-----------|------|----|-----------|-----|----------------|-----|
| Metals | | | | | | | | | |
| Lead | 8.97 | µg/L | EPA 200.8 | 1.00 | 1 | 12/08/21 | JNM | 12/15/21 19:09 | MKR |

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 12/16/2021 6:41 pm 1L02392
 STL_Results Revision #1.9 Effective: 04/16/2020

