

SAFETY

The Superintendent shall develop rules governing school safety which shall include but not be limited to: pupil safety in school; care of injured pupils; vehicle safety programs; plant safety including removal and/or encapsulation of asbestos; labeling and storage of hazardous substances; emergency procedures; pupil safety in transit to and from school; and eye protection. In addition, pupils shall be provided with safety instruction in accordance with the law.

Use and Storage of Hazardous Substances

The Board shall not allow the use of any hazardous substances in or on any of the buildings or grounds of this district when children are present, except in emergencies. A list of substances that are legally exempted from this requirement can be obtained from the Superintendent.

The Superintendent shall inform the Board when hazardous substances may be used when children are present, and the Board shall determine if an emergency situation exists and such use is warranted.

If any hazardous substance is stored on any school site, the Superintendent shall make available the hazardous substance fact sheet for that substance to anyone who requests it.

At least two days prior to the start of any construction activity involving hazardous substances, the Superintendent shall post on a bulletin board at the school a notice that such construction will take place. The notice will state the activity to be conducted and the hazardous substance(s) to be used.

The Superintendent shall ensure that all parents/guardians receive a notice at least once a year informing them of the following:

- A. Notice of any construction or other activities involving hazardous substances will be posted on the bulletin board of their children's school;
- B. Hazardous substances may be stored at the school at various times throughout the year;
- C. Hazardous substance fact sheets for any of the hazardous substances being used or stored are available at the school.

~~The Superintendent shall appoint a district level administrator to serve as district safety coordinator. The district safety coordinator shall direct the district safety program; meet regularly with administrators in charge of school buildings to discuss safety issues; promote safety~~

SAFETY (continued)

~~awareness throughout the district; and supervise the prompt filing, follow up, and analysis of accident reports.~~

Soil Contamination on School Property

The Board, the principal or Superintendent shall ensure that notice of soil contamination on school property is provided. Notice will be provided to each parent or guardian of a student enrolled at the school, and to each staff member of the school. Notice will be provided within 10 business days of the discovery of the soil contamination, when the contamination is found by the Department of Environmental Protection or a licensed site remediation professional to exceed the department's direct contact soil remediation standards for residential use.

The notice shall include:

- A. A description of the soil contamination and the conditions under which a student or staff member may be exposed to the contamination;
- B. A description and timetable of the steps that have been taken and will be taken to ensure that there is no contact by any student or staff member with the contamination;
- C. A description and timetable of the steps that have been taken and will be taken to remediate the soil contamination.

The notice may be provided by:

- A. Written notice sent home with the student and provided to the staff member;
- B. Telephone call;
- C. Direct contact;
- D. Electronic mail.

The district shall also post a copy of the notice in a conspicuous location near the site of the contamination to notify any other users of the school grounds of the existence of the contamination.

Safe Drinking Water

~~The Board of Education shall assure the availability of potable drinking water through sanitary means in school facilities or upon school grounds in accordance with the Safe Drinking Water Act (N.J.S.A. 58:12A-1 et seq.).~~

~~The Board directs that lead sampling and analysis be conducted in all drinking water outlets to which a student or staff member has or may have access, in each school facility, other facility, or temporary facility no later than July 13, 2017. Sampling shall be conducted according to the lead sampling plan (<http://www.nj.gov/dep/watersupply/pdf/techguide.pdf>). The lead sampling plan shall include:~~

SAFETY (continued)

- A. A plumbing survey for each facility that identifies how water enters and flows through each facility, the types of plumbing materials used in the facility, such as the service line, piping, solder, fixtures, drinking water outlets where students or staff have or may have access, and point of use treatment, such as drinking water filters;
- B. The names and responsibilities of all individuals involved in sampling; and
- C. The following sampling procedures:
 - 1. Samples shall be taken after water has sat, undisturbed in the school pipes for at least eight hours but no more than 48 hours before the sample is taken;
 - 2. At least eight hours prior to sampling, signs shall be posted to indicate that water shall not be used and access to the buildings subject to the sampling shall be restricted to all but authorized staff members;
 - 3. Existing aerators, screens, and filters shall not be replaced or removed prior to or during sampling; and
 - 4. All samples shall be collected in pre-cleaned high-density polyethylene (HDPE) 250 milliliter (mL) wide-mouth single-use rigid sample containers that are properly labeled.

The Board shall test all drinking water outlets within six years following the initial testing and every six years thereafter. Sampling shall be prioritized in buildings and facilities that previously had outlets with results above the action level or identified in the plumbing profile as high risk for lead. The water outlets in these buildings and facilities shall be sampled first in accordance with the sampling plan. In addition, sampling for lead shall be conducted after the replacement of any drinking water outlet or any other alteration to plumbing or service lines that may impact lead levels at the outlet.

Drinking Water Sample Analysis

Analysis of water samples shall be conducted by a certified laboratory to analyze for lead in drinking water. The laboratory shall use an approved analytical method pursuant to the Federal Safe Drinking Water Act at 40 CFR 141.23(k)(1). Sample analysis shall be conducted in accordance with a Quality Assurance Project Plan (QAPP)**, which shall be signed by the Board of Education, the certified laboratory, and the individual responsible for conducting sampling. The QAPP shall include:

- A. Identification of analytical methods;
- B. Chain of custody procedures;
- C. Data validation and reporting processes;
- D. Detection limits;
- E. Reporting to three significant figures;
- F. Field blanks; and
- G. Quality control measures required by the certified method

SAFETY (continued)

Water Sample Analysis Results: Notifications

Within 24 hours after the board has reviewed and verified the final laboratory results, the Board shall make the test results of all water samples publicly available at the school facility and on the district website. If any results exceed the permissible lead action level, written notification shall be provided to the parents/guardians of all students attending the facility, as well as to the New Jersey Department of Education (NJDOE). This notification shall include a description of the measures taken by the board to:

- A. Immediately end use of each drinking water outlet where water quality exceeds the permissible lead action level;
- B. Ensure that alternate drinking water has been made available to all students and staff members, and information regarding the health effects of lead is provided.

The Board shall annually submit a statement of assurance to the NJDOE that lead testing was completed, that notifications were provided, and that alternate drinking water continues to be made available to all students and staff in accordance law and Board policy.

Within six years of the adoption of this policy, and within each six-year period thereafter, the Board must test all drinking water outlets; sampling shall be prioritized in facilities previously identified with excessive lead results or identified as high risk in the sampling plan.

Implementation

Rules and procedures implementing this policy shall be reviewed and adopted by the Board as required by law and shall be disseminated to staff and pupils annually, and whenever any changes are made.

SAFETY (continued)

Possible

<u>Cross References:</u>	1330	Use of school facilities
	1410	Local units
	3510	Operation and maintenance of plant
	5141.1	Accidents
	5142	Pupil safety
	5142.1	Safety patrols
	6114	Emergencies and disaster preparedness
	6142.12	Career education
	7110	Long-range facilities planning

Key Words

Safety, Pupil Safety, Employee Safety, Asbestos, Hazardous Materials, Student Safety

Date Adopted: 08/23/2005

Date Revised: 02/16/2010

Rationale: Removed the requirement to designate a district level safety coordinator. Added requirements to ensure safe drinking water.