

Bethany Community School Gymnasium Air Conditioning Project
Vendor Questions & Answers
April 5, 2022

Question: Corrected Trane Model #

Answer: Thh240GR0B0000, 20 Ton Unit

Question: Install roof curb on concrete pad?

Answer: Yes

Question: Remove existing ductwork (exhaust)?

Answer: Yes

Question: ADT contact?

Answer: Dave Scheets