



Results Report

Order ID: 1K03010

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: Pequannock Township SD - Hillview
206 Boulevard
Pompton Plains, NJ

Attn: Noel Abraham

Regulatory ID:

Sample Number: 1K03010-01	Site: PHE-1FL-POE-Boiler Room	Sample ID: Boiler Room
Collector: NPA	Collect Date: 11/05/2021 9:43 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.05	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/11/21 12:05	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03010-02	Site: PHE-1FL-BF-O/S Nurse Office	Sample ID: O/S Nurse Office
Collector: NPA	Collect Date: 11/05/2021 9:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/11/21 12:12	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03010-03	Site: PHE-1FL-NS-Nurse Office	Sample ID: Nurse Office
Collector: NPA	Collect Date: 11/05/2021 9:47 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	23.4	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/11/21 12:20	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03010-04	Site: PHE-1FL-BF-Hall O/S Gym	Sample ID: Hall o/s Gym
Collector: NPA	Collect Date: 11/05/2021 9:49 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	CMV	11/11/21 12:18	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 11/15/2021 4:01 pm 1K03010
STL_Results Revision #1.9 Effective: 04/16/2020

